

FIRE DOOR LISTING PROGRAM

Customer: BASF SE
 Class: Fire Doors
 Location: Frankenthal, Germany
 Website: www.basf.com

Listing No. F411-1
 Project No. F411-1 Edition 5
 Effective Date: October 12, 2012
 Last Revised Date: September 20, 2016
 Expires: N/A

Standards: CAN/ULC-S104 *Standard Method for Fire Tests of Door Assemblies.*
 UL 10(b) *Fire Tests of Doors Assemblies.*
 UL 10(c) *Fire Tests of Doors Assemblies.*
 NFPA 252 *Standard Methods of Fire Tests of Door Assemblies.*

Product: 90 min Rated Fire Doors

Markings: See [FD001 - Fire Door Labeling requirements](#)

Models: **90-MINUTE LAMINATED CORE PANEL DOORS:**

Minimum 1-3/4" Thickness

Swing Type:	Maximum Dimensions		Panel Type:	Latching:
	Width:	Length:		
Single Swing	3'6" (1067 mm)	9'0" (2438 mm)	Flat or Raised	Single Point (Mortised or Cylindrical)
	4'0" (1067 mm)	7'0" (2134 mm)		
Pairs	6'0" (2134 mm)	8'0" (2438 mm)	Flat or Raised	3 point (Active: Mortised or Cylindrical) (Inactive: Surface Mounted Flush Bolts)
	7'0" (2134 mm)	8'0" (2438 mm)	Flat or Raised	4 point (Active: Mortised or Cylindrical) (Inactive: Surface Mounted Flush Bolts)
	8'0" (2438 mm)	7'0" (2134 mm)		
	7'0" (2134 mm)	9'0" (2438 mm)	Flush	

Minimum 2-1/4" Thickness

Swing Type:	Maximum Dimensions		Panel Type:	Latching:
	Width:	Length:		
Single Swing	4'0" (1067 mm)	10'0" (3048 mm)	Flush	2 point (Concealed or Surface Mounted)
Double Egress	8'0" (2438 mm)	10'0" (3048 mm)	Flush	4 point (Concealed or Surface Mounted)

*All door assemblies are certified for Shallow Arch door construction

Temperature rise

- @30 min = 250°F MAX where light do not exceed 100 in²
- @60 min = 450°F MAX where light do not exceed 100 in²

Limitations: (Review Machining Report for further detail)

- Cylindrical Latches (Listed and Labelled)
- Mortise Lockset (Listed and Labelled)
- Fire Exit Devices
 - Surface mounted vertical rod, RIM and concealed vertical rod exit devices
- Surface Mounted and concealed door closer (Listed and Labelled)
- Light Kit (Listed and Labelled)
 - Listed Steel Lite Kit – max. 1080 sq. in. (max. dimension of 36")
 - BASF Proprietary steel channel light kit – max. 600 sq. in.
- Electric Raceway (Can only be installed in the Mid Rail, never through the door core)
- Surface Mounted and concealed door bottom (Listed and Labelled)
 - Max mortise 1-3/4" deep by 1" wide by full width of the door
 - Pocket lined with Interdens 15 on all sides

Notes: *Refer to QAI evaluation report F411-1 and the applicable test reports for test assembly configurations used for fire endurance testing.*

Refer to the [QAI FD002 - Fire Door Guidelines for general guidelines of fire door assemblies](#)

Final acceptance of the product in the intended application is to be determined by the authority having jurisdiction (AHJ).

Product is to be installed in accordance with the manufacturer's published installation instructions by qualified installing personnel.

The materials, products or systems listed herein have been qualified to bear the QAI Listing Mark under the conditions stated with each Listing. Only those products bearing the QAI Listing Mark are considered to be listed by QAI. No warrantee is expressed or implied, and no guarantee is provided that any jurisdictional authority will accept the Listing found herein. The appropriate authorities should be contacted regarding the acceptability of any given Listing. Visit the QAI Online Listing Directory located at www.qai.org for the most up to date version of this Listing and to validate that this QAI Listing is active. Questions regarding this listing may be directed to info@qai.org. Please include the listing number in the request.
