

VANCOUVER, BC: LOS ANGELES, CA: WASHINGTON, DC: TULSA, OK: TORONTO, ON SEATTLE, WA 877.461.8378 ph. | 604.527.8368 fx. 909.483.0250 ph. | 909.483.0336 fx. 540.636.9445 ph. | 540.636.9414 fx. 918.437.8333 ph. | 918.437.8487 fx. 416.550.9280

ONTO, ON 416.550.9280 TTLE, WA 425.512.8419 WEBSITE: WWW.QAI.ORG

FIRE DOOR LISTING PROGRAM

Customer: CR Doors & Moulding LLC

Class: Fire Doors
Location: Springville, UT
Website: www.crdoors.net

Listing No. F451-1

Project No. F451-1 Edition 1

Effective Date: January 5, 2018 Last Revised Date: January 5, 2018

Standards: CAN/ULC-S104 Standard Method for Fire Tests of Door Assemblies.

UL 10(b) Fire Tests of Doors Assemblies.
UL 10(c) Fire Tests of Doors Assemblies.

NFPA 252 Standard Methods of Fire Tests of Door Assemblies.

Product: 20 min Rated Positive Pressure Fire Doors

Markings: See <u>FD001 - Fire Door Labeling requirements</u>

Models: 20-MINUTE LAMINATED CORE PANEL AND FLUSH DOORS:

Minimum 1-3/4" Thickness

Swing	Maximum Dimensions		Panel	Latching:
Type:	Width:	Length:	Type:	Latering.
Single Swing	3'6" (1067 mm) 4'0" (1219 mm) 3'6" (1067 mm) 4'0" (1219 mm)	8'0" (2743 mm) 7'0" (2438 mm) 9'0" (2743 mm) 8'0" (2438 mm)	Flat or Raised	Single Point (Mortised or Cylindrical)
Arched Top Single Swing	3'6" (1067 mm)	9'0" (2743 mm)	Flat or Raised	
Pairs	7'0" (2134 mm)	8'0" (2438 mm)	Flat or Raised	3 or 4 point (Active: Mortised or Cylindrical) (Inactive: Mortised (Manual or Automatic) and Surface Mounted Flush Bolts)
	8'0" (2438 mm)	7'0" (2134 mm)		
	8'0" (2438 mm)	8'0" (2438 mm)		
Double Egress	7'0" (2134 mm)	8'0" (2438 mm)	Flat or Raised	4 point (Concealed or Surface Mounted)

Minimum 1-3/8" Thickness

Swing Type:	Maximum Dimensions		Panel	Lotobing		
	Width:	Length:	Type:	Latching:		
Single Swing	3'0" (941 mm)	7'0" (2134 mm)	Flush	Single Point (Mortised or Cylindrical)		
Pairs	Not Permitted					
Double Egress	Not Permitted					

^{*}All door assemblies are certified for Shallow Arch door construction



VANCOUVER, BC: LOS ANGELES, CA: WASHINGTON, DC: TULSA, OK: TORONTO, ON SEATTLE, WA

877.461.8378 ph. | 604.527.8368 fx. 909.483.0250 ph. | 909.483.0336 fx. 540.636.9445 ph. | 540.636.9414 fx. 918.437.8333 ph. | 918.437.8487 fx. 416.550.9280 425.512.8419

WWW.OAI.ORG

Limitations: (Review Machining Report for further detail)

- Surface Mounted Hardware
- Mortise manual or automatic flush bolts
- Listed Viewers
- Cylindrical Latches (Listed and Labelled)
- Mortise Lockset (Listed and Labelled)
 - Assa Abloy Hospitality AS Vingcard Mortise Hardware
 - "VingCard Alu" or "Trio VingAccess Alu", Series 1050, 1060, 1070, 1080, 1090
 - 1000 Series; Models 1001, -02, -04, -07, -12, -14, -15, -57, -85 with 19.05 mm (3/4 in.) latch bolts; may include suffix letters -K, -KVC, -L or -I VC
 - "3000 DaVinci, Euro DaVinci and Presidio" battery operated units
 - "Signature Series, Euro, ANSI and US ANSI" battery operated units
 - "Allure Series, Euro, ANSI and US ANSI" battery operated units
 - "Essence Series, Euro, ANSI (DB) and US ANSI (DA)" battery operated units
- Fire Exit Devices
 - Surface mounted vertical rod, RIM and concealed vertical rod exit devices
- Surface Mounted and concealed door closer (Listed and Labelled)
- Light Kit (Listed and Labelled)
 - o Listed Steel Lite Kit max. 1296 sq. in. (max dimension of 54")
 - o BASF Proprietary clip light kit max. 2656 sq. in. (max. dimension of 83")
 - BASF Proprietary steel channel light kit max. 1296 sq. in. (max. dimension of 54")
- Electric Raceway
- Surface Mounted and concealed door bottom (Listed and Labelled)
 - Max mortise 1-3/4" deep by 1" wide by full width of the door

Notes: Refer to QAI evaluation report F451-1 and the applicable test reports for test assembly configurations used for fire endurance testing.

Refer to the QAI FD002 - Fire Door Guidelines for general guidelines of fire door assemblies

Final acceptance of the product in the intended application is to be determined by the authority having jurisdiction (AHJ).

Product is to be installed in accordance with the manufacturer's published installation instructions by qualified installing personnel.

The materials, products or systems listed herein have been qualified to bear the QAI Listing Mark under the conditions stated with each Listing. Only those products bearing the QAI Listing Mark are considered to be listed by QAI. No warrantee is expressed or implied, and no guarantee is provided that any jurisdictional authority will accept the Listing found herein. The appropriate authorities should be contacted regarding the acceptability of any given Listing. Visit the QAI Online Listing Directory located at www.qai.org for the most up to date version of this Listing and to validate that this QAI Listing is active. Questions regarding this listing may be directed to info@qai.org. Please include the listing number in the request.
