

FIRE DOOR LISTING PROGRAM

Customer: Daiek Woodworks
 Class: Fire Doors
 Location: Sterling Heights, Michigan
 Website: www.daiekwoodworks.com
 Listing No. F416
 Project No. F416-1 Edition 3
 Effective Date: May 3, 2016
 Last Revised: May 3, 2016
 Standards: CAN/ULC-S104
 UL 10(b)
 UL 10(c)
 NFPA 252

Standard Method for Fire Tests of Door Assemblies.
Fire Tests of Doors Assemblies.
Fire Tests of Doors Assemblies.
Standard Methods of Fire Tests of Door Assemblies.

Product: 45 min Rated Fire Doors

Label: See [FD001 - Fire Door Labeling requirements](#)

Models / Ratings: **45-MINUTE LAMINATED CORE PANEL DOORS:**

MAXIMUM DOOR SIZES:

Minimum 1-3/4" Thickness

| Swing Type: | Maximum Dimensions | | Panel Type: | Latching: |
|-------------------------|--------------------|----------------|-----------------|--|
| | Width: | Length: | | |
| Single Swing | 3'6" (1067 mm) | 9'0" (2743 mm) | Flush or Raised | Single Point (Mortised or Cylindrical) |
| | 4'0" (1067 mm) | 7'0" (2134 mm) | | |
| | 4'0" (1067 mm) | 8'0" (2438 mm) | | |
| Arched Top Single Swing | 3'6" (1067 mm) | 8'0" (2438 mm) | | |
| Pairs | 7'0" (2134 mm) | 8'0" (2438 mm) | Flush or Raised | 3 or 4 point (Active: Mortised or Cylindrical) (Inactive: Mortised (Manual) and Surface Mounted Flush Bolts) |
| | 8'0" (2438 mm) | 7'0" (2134 mm) | | |
| Double Egress | 7'0" (2134 mm) | 8'0" (2438 mm) | Flush or Raised | 4 point (Concealed or Surface Mounted) |

Temperature rise

- @30 min = 250°F MAX where lites do not exceed 100 in²
- @30 min = 250°C MAX where lites do not exceed 100 in²

Minimum 1-3/8” Thickness

Communicating Door Frame

Two slabs must be installed into the same communicating door frame to achieve 45 min rating

| Swing Type: | Maximum Dimensions | | Panel Type: | Latching: |
|---------------|--------------------|----------------|-------------|---|
| | Width: | Length: | | |
| Single Swing | 3'0" (941 mm) | 7'0" (2134 mm) | Flush | Single Point (Mortised or Cylindrical) |
| Pairs | Not Permitted | | | |
| Double Egress | Not Permitted | | | |

Limitations: (Review Machining Report for further detail)

- Surface Mounted Hardware
- Cylindrical Latches (Listed and Labelled)
- Mortise Lockset (Listed and Labelled)
 - [Max. mortise pocket 4-7/16” deep x 6-1/16” high x 1” thick]
 - Assa Abloy Hospitality AS – Vingcard Mortise Hardware
 - "VingCard Alu" or "Trio VingAccess Alu", Series 1050, 1060, 1070, 1080, 1090
 - 1000 Series; Models 1001, -02, -04, -07, -12, -14, -15, -57, -85 with 19.05 mm (3/4 in.) latch bolts; may include suffix letters -K, -KVC, -L or -LVC
 - "3000 DaVinci, Euro DaVinci and Presidio" battery operated units
- Listed Viewers
- Fire Exit Devices
 - Surface mounted vertical rod, RIM and concealed vertical rod exit devices
- Surface Mounted and concealed door closer (Listed and Labelled)
 - Max mortise 22-1/2” long by 1-3/8” deep by 1-1/4” wide
- Light Kit (Listed and Labelled)
 - Listed Steel Lite Kit – max. 1296 sq. in. (max dimension of 54”)
 - BASF Proprietary clip light kit – max. 2656 sq. in. (max. dimension of 83”)
 - BASF Proprietary steel channel light kit – max. 600 sq. in. (max. dimension of 36”)
- Electric Raceway
- Surface Mounted and concealed door bottom (Listed and Labelled)
 - Max mortise 1-3/4” deep by 1” wide by full width of the door

Notes: Refer to QAI evaluation report F433-1 and the applicable test reports for test assembly configurations used for fire endurance testing.

Refer to the [QAI FD002 - Fire Door Guidelines for general guidelines of fire door assemblies](#)

Final acceptance of the product in the intended application is to be determined by the authority having jurisdiction (AHJ).

Product is to be installed in accordance with the manufacturer’s published installation instructions by qualified installing personnel.



VANCOUVER, BC: 877.461.8378 ph. | 604.527.8368 fx.
LOS ANGELES, CA: 909.483.0250 ph. | 909.483.0336 fx.
WASHINGTON, DC: 540.636.9445 ph. | 540.636.9414 fx.
TULSA, OK: 918.437.8333 ph. | 918.437.8487 fx.
TORONTO, ON: 416.550.9280
SEATTLE, WA: 425.512.8419
WEBSITE: WWW.QAI.ORG

The materials, products or systems listed herein have been qualified to bear the QAI Listing Mark under the conditions stated with each Listing. Only those products bearing the QAI Listing Mark are considered to be listed by QAI. No warrantee is expressed or implied, and no guarantee is provided that any jurisdictional authority will accept the Listing found herein. The appropriate authorities should be contacted regarding the acceptability of any given Listing. Visit the QAI Online Listing Directory located at www.qai.org for the most up to date version of this Listing and to validate that this QAI Listing is active. Questions regarding this listing may be directed to info@qai.org. Please include the listing number in the request.
