

FIRE DOOR LISTING PROGRAM

Customer: Daiek Woodworks
 Class: Fire Doors
 Location: Sterling Heights, Michigan
 Website: www.daiekwoodworks.com
 Listing No. F416
 Project No. F416-1 Edition 3
 Effective Date: May 3, 2016
 Last Revised: May 3, 2016
 Standards: CAN/ULC-S104 *Standard Method for Fire Tests of Door Assemblies.*
 UL 10(b) *Fire Tests of Doors Assemblies.*
 UL 10(c) *Fire Tests of Doors Assemblies.*
 NFPA 252 *Standard Methods of Fire Tests of Door Assemblies.*

Product: 60 min Rated Fire Doors

Label: See [FD001 - Fire Door Labeling requirements](#)

Models / **60-MINUTE LAMINATED CORE PANEL DOORS:**

Ratings:

MAXIMUM DOOR SIZES:

Minimum 1-3/4" Thickness

Swing Type:	Maximum Dimensions		Panel Type:	Latching:
	Width:	Length:		
Single Swing	3'6" (1067 mm)	8'0" (2438 mm)	Flush Milled, Flush or Raised	Single Point (Mortised or Cylindrical)
	4'0" (1067 mm)	7'0" (2134 mm)		
	4'0" (1067 mm)	8'0" (2438 mm)		
Arched Top Single Swing	3'6" (1067 mm)	8'0" (2438 mm)	Flush or Raised	3 or 4 point (Active: Mortised or Cylindrical) (Inactive: Surface Mounted Flush Bolts)
Pairs	7'0" (2134 mm)	8'0" (2438 mm)	Flush or Raised	
	8'0" (2438 mm)	7'0" (2134 mm)		
Double Egress	7'0" (2134 mm)	8'0" (2438 mm)	Flush or Raised	4 point (Concealed or Surface Mounted)

Temperature rise

- @30 min = 250°F MAX where lites do not exceed 100 in²
- @30 min = 250°C MAX where lites do not exceed 100 in²
- @60 min = 250°C MAX where light do not exceed 100 in²

Limitations: (Review Machining Report for further detail)

- Surface Mounted Hardware
- Cylindrical Latches (Listed and Labelled)
- Mortise Lockset (Listed and Labelled)
 - [Max. mortise pocket 4-7/16" deep x 6-1/16" high x 1" thick]
- Listed Viewers
- Fire Exit Devices
 - Surface mounted vertical rod, RIM and concealed vertical rod exit devices
- Surface Mounted and concealed door closer (Listed and Labelled)
 - Max mortise 22-1/2" long by 1-3/8" deep by 1-1/4" wide
- Light Kit (Listed and Labelled)
 - Listed Steel Lite Kit – max. 1296 sq. in. (max dimension of 54")
 - BASF Proprietary steel channel light kit – max. 600 sq. in. (max. dimension of 36")
- Electric Raceway
- Surface Mounted and concealed door bottom (Listed and Labelled)
 - Max mortise 1-3/4" deep by 1" wide by full width of the door

Notes: *Refer to QAI evaluation report F433-1 and the applicable test reports for test assembly configurations used for fire endurance testing.*

Refer to the [QAI FD002 - Fire Door Guidelines for general guidelines of fire door assemblies](#)

Final acceptance of the product in the intended application is to be determined by the authority having jurisdiction (AHJ).

Product is to be installed in accordance with the manufacturer's published installation instructions by qualified installing personnel.

The materials, products or systems listed herein have been qualified to bear the QAI Listing Mark under the conditions stated with each Listing. Only those products bearing the QAI Listing Mark are considered to be listed by QAI. No warrantee is expressed or implied, and no guarantee is provided that any jurisdictional authority will accept the Listing found herein. The appropriate authorities should be contacted regarding the acceptability of any given Listing. Visit the QAI Online Listing Directory located at www.qai.org for the most up to date version of this Listing and to validate that this QAI Listing is active. Questions regarding this listing may be directed to info@qai.org. Please include the listing number in the request.
