

FIRE DOOR LISTING PROGRAM

Customer: Distinctive Wood Designs Inc.
Class: Fire Resistant Doors and Frames
Location: Delta, British Columbia
Website: www.distinctivewood.com

Listing No. F423-1
Project No. F423-1 Edition 4

Effective Date: October 27, 2020
Last Revised Date: October 27, 2020
Expires: N/A

Standards: UL 10B *Fire Tests of Door Assemblies*
 UL 10C *Positive Pressure Fire Tests of Door Assemblies*
 NFPA 252 *Standard Methods of Fire Tests of Door Assemblies*
 CAN/ULC S104 *Standard Method for Fire Tests of Door Assemblies*

Product: 45 minute Positive Pressure rated Fire Doors

Markings: See [FD001 - Fire Door Labeling requirements](#)

Models: 45-MINUTE STILE AND RAIL WOOD PANEL DOORS:

Minimum 1-3/4" Thickness

Swing Type:	Maximum Dimensions		Panel Type:	Latching:
	Width:	Height:		
Single Swing	3'0" (914 mm)	8'0" (2438 mm)	Flush only	Single point (Mortised or Cylindrical) (Surface Mounted exit devices)

Limitations: (Review Machining Report for further detail)

Latch Sets (Listed and labeled for rated opening)

- Cylindrical Latches.
- Mortised Latch & Deadbolt Assembly:
 - Schlage L9010 mortise lockset.

Deadbolts (Listed and labeled for rated opening)

- Cylindrical Deadbolts:
 - Located a minimum of 2-1/4" center-line to center-line from the latch cutout.
- Mortised Latch & Deadbolt Assembly:
 - Schlage L9010 mortise lockset.

Hinges (Listed and labeled for rated opening)

- Hinges as per NFPA 80, Table 6.4.3.1

Fire Exit Devices (Listed and labeled for rated opening)

- Surface Mounted Vertical Rod Fire Touch Bar Exit Device may be less bottom rod.
- Rim Type Fire Exit Devices.

Door Closers (Listed and labeled for rated opening)

- Surface Mounted Door Closers.

Surface Mounted Protection Plates

- Steel, brass, bronze, aluminum, PVC, or plastic laminate max 48" high.

Viewers (Listed and labeled for rated opening)

- Maximum size of 1" diameter.
- Viewers located a minimum 12" away from edges of doors and other hardware.

Door Bottoms Seals (Listed and labeled for rated opening)

- Surface mounted automatic door bottom.

Glass Lights

- Not Permitted

Louvres

- Not Permitted

Notes: *Refer to QAI evaluation report F423-1 and the applicable test reports for test assembly configurations used for fire endurance testing.*

Refer to the [QAI FD002 - Fire Door Guidelines for general guidelines of fire door assemblies](#)

Final acceptance of the product in the intended application is to be determined by the authority having jurisdiction (AHJ).

Product is to be installed in accordance with the manufacturer's published installation instructions by qualified installing personnel.

The materials, products or systems listed herein have been qualified to bear the QAI Listing Mark under the conditions stated with each Listing. Only those products bearing the QAI Listing Mark are considered to be listed by QAI. No warranty is expressed or implied, and no guarantee is provided that any jurisdictional authority will accept the Listing found herein. The appropriate authorities should be contacted regarding the acceptability of any given Listing. Visit the QAI Online Listing Directory located at www.qai.org for the most up to date version of this Listing and to validate that this QAI Listing is active. Questions regarding this listing may be directed to info@qai.org. Please include the listing number in the request.
