

BUILDING PRODUCT LISTING PROGRAM

Customer: Duradek U.S. Inc.
Class: Polyvinyl-Chloride Roofing
Location: North Kansas City, MO
Website: www.duradek.com

Listing No. B1023-2
Project No. B1023-2 Edition 6

Effective Date: August 12, 2011
Last Revised Date: December 1, 2016
Expires: N/A

Standards: CAN/CGSB-37.54 "Polyvinyl Chloride Roofing and Waterproofing Membrane"
ASTM E108 "Standard Test Methods for Fire Tests of Roof Coverings"
CAN/ULC S107 "Methods of Fire Tests of Roof Coverings"
ANSI/SPRI ES-1 "Wind Design Standard for Edge Systems Used with Low Slope Roofing Systems"
ASTM G155 "Standard Practice for Operating Xenon Arc Light Apparatus for Exposure of Non-Metallic Materials"
CGSB 37-GP-52M "Roofing and Waterproofing Membrane, Sheet Applied, Elastomeric" (for impact resistance only)
ANSI/FM 4474 "Evaluating the Simulated Wind Uplift Resistance of Roof Assemblies Using Static Positive and/or Negative Differential Pressures"

Product: Duradek Ultra and Tiledek - Polyvinyl-Chloride (PVC) Roofing and Walking Deck Membrane

Markings: Each roll of Duradek Ultra or Tiledek is marked with a permanent label containing the following information:

- a) Manufacturers name or recognized trademark (Duradek)
- b) Product name or product number
- c) Batch Number for traceability
- d) QAI logo with 'c' and 'us' indicators
- e) QAI file number: B1023
- f) Type and class of the product in accordance with CAN/CGSB 37.54 (Type 3, Class B)
- g) QAI logo shown here:





Models / Ratings:

Model	Nominal thickness	Surface	Roll Width(s)
Duradek Ultra	1.5mm (60mil)	Embossed	72 inches
Duradek Tiledek	1.5mm (60mil)	Adhered non-woven polyester fabric finish	72 inches

Results:

Standard	Details	Rating
CAN/CGSB-37.54		Type 3, Class B membrane
ANSI/SPRI ES-1	2-1/4" x 3-1/4" PVC Metal Roof Edge Flashing system	Maximum test pressure of 305 psf (factor of safety of 2)
ASTM G155	After 2000 hours	Did not show any surface deterioration and there was no loss in tensile strength
CGSB 37-GP-52M	Impact Resistance Only	Pass
ASTM E108	See ASTM E108 & CAN/ULC S107: Decking Assembly Details	See ASTM E108 & CAN/ULC S107: Decking Assembly Details
CAN/ULC S107		

ASTM E108 & CAN/ULC S107: Decking Assembly Details

Rating:	Class A
Deck Slope:	1/4 : 12
Deck:	Non-combustible sheathing defined and installed in accordance with the applicable code.
Membrane:	Duradek Ultra (60 mils) adhered to the non-combustible substrate with Duradek D811 (solvent-based) or D763 (water-based) adhesive applied per Duradek installation instructions.

Rating:	Class A
Deck Slope:	1/4 : 12
Deck:	Non-combustible sheathing defined and installed in accordance with the applicable code.
Membrane:	Duradek Tiledek (60 mils) adhered to the non-combustible substrate with Duradek D811 (solvent-based) or D763 (water-based) adhesive applied per Duradek installation instructions.
Surface Covering:	Non-combustible tile adhered to Duradek Tiledek per Duradek installation instructions.



Rating:	Class C
Deck Slope:	1/4 : 12
Deck:	19/32" AC Exterior grade plywood, moisture content not greater than 8% fastened with #10 exterior wood screws. The fasteners are spaced 6" OC along edges and 8" OC along intermediate supports. All deck joints are covered evenly with Mapei PlaniPatch floor patch.
Membrane:	Duradek Ultra (60 mils) adhered to cement board with Duradek D811 (solvent-based) adhesive applied per Duradek installation instructions.

Rating:	Class C
Deck Slope:	1/4 : 12
Deck:	19/32" AC Exterior grade plywood, moisture content not greater than 8% fastened with #10 exterior wood screws. The fasteners are spaced 6" OC along edges and 8" OC along intermediate supports. All deck joints are covered evenly with Mapei PlaniPatch floor patch.
Membrane:	Duradek Tiledek adhered to cement board with Duradek D811 (solvent-based) adhesive applied per Duradek installation instructions.
Surface Covering:	Non-combustible tile adhered to Duradek Tiledek per manufacturer's installation instructions.

ANSI/FM 4474, Determined allowable uplift resistance

System No.	Substrate ^{3, 4}	Adhesive ⁵	Maximum Allowable Wind Uplift (psf) ^{1,2}
1	Cement board	Duradek D763	200
2	Cement board	Duradek D811	200
3	Plywood	Duradek D763	200
4	Plywood	Duradek D811	240

¹ A factor of safety of 2 is applied to the maximum allowable wind uplift results.

² The wind uplift test results can be related to the adhesion of the membrane to the substrate only. Results are not an indication of the bond of the substrate to the substructure and are not an indication of the strength of the deck substructure. The deck and framing to which the Duradek Ultra system is adhered must be designed for the applicable components and wind loads in accordance with the applicable code.

³ Plywood is minimum 5/8-inch-thick exterior-grade with tongue-and groove edges, complying with recognized standards.

⁴ Cement board is 'USG Durock Cement Board Next Gen' minimum 1/2-inch-thick (nominal).

⁵ Adhesive must be applied in accordance with the manufacturer's published installation instructions.

Notes: Products must be installed with the manufacturer's published installation instructions and in accordance with the building codes recognized by the authority having jurisdiction.

Listed manufacturers are subject to on-going inspections by QAI to ensure that the products outlined above remains as it is listed.

The materials, products or systems listed herein have been qualified to bear the QAI Listing Mark under the conditions stated with each Listing. Only those products bearing the QAI Listing Mark are considered to be listed by QAI. No warrantee is expressed or implied, and no guarantee is provided that any jurisdictional authority will accept the Listing found herein. The appropriate authorities should be contacted regarding the acceptability of any given Listing. Visit the QAI Online Listing Directory located at www.qai.org for the most up to date version of this Listing and to validate that this QAI Listing is active. Questions regarding this listing may be directed to info@qai.org. Please include the listing number in the request.
