

BUILDING PRODUCTS LISTING PROGRAM

Class: Exterior Insulation and Finish Systems

Customer: DuROCK Alfracing International, Ltd.
 Location: 101 B Roytec Road, Woodbridge, ON L4L 8A9
 Listing No. B1039-1
 Effective Date: August 2, 2011
 Last Revised: March 24, 2016
 Expires: N/A
 Website: <http://www.durock.ca/>

Product(s): DuROCK Exterior Insulation and Finish Systems (EIFS).

Standards: CAN/ULC S101 "Standard Methods of Fire Endurance Tests of Building Construction and Materials"

CAN/ULC S114 "Standard Method of Test for Determination of Non-Combustibility in Building Materials"

CAN/ULC S134 "Standard Method of Fire Test of Exterior Wall Assemblies"

Models: DuROCK PUCCS EIFS
 DuROCK ISULROCK EIFS

DuROCK Prep-Coat, Prep-Coat D, and Prep-Coat P are classified as noncombustible, and complies with CAN/ULC S114.

Ratings: The following DuROCK EIFS assemblies have been evaluated for use in noncombustible construction as outlined in Section 3.1.5.5 of the National Building Code of Canada through testing to CAN/ULC S134.

Table 1. DUROCK EIFS CAN/ULC S134 Certified Assemblies

QAI Design #	APPROVED SYSTEM	Heat Flux 3.5 m above Opening (kW/m ²)	Flame Spread Above Opening (meters)
B1039-1a¹	DuROCK PUCCS DuROCK InsulROCK	< 35	< 5.0

Note¹: See design listing B1039-1a for details regarding approved components and installation evaluated by QAI.

The following DuROCK EIFS assemblies have been evaluated for use for protection of exterior building face containing foam plastic insulation as outlined in Section 3.2.3.8 of the National Building Code of Canada through testing to CAN/ULC S101 for 15 minute stay in place.

Table 1. DUROCK EIFS CAN/ULC S101 15-Minute Stay-In-Place Assemblies

QAI Design #	APPROVED SYSTEM	FIRE ENDURANCE	OPENINGS
B1039-1b²	DuROCK PUCCS DuROCK InsulROCK	15 Minutes	No Openings Developed.

Note²: See design listing B1039-1b for details regarding approved components and installation evaluated by QAI. All noted DuROCK assemblies require installation with Basecoat component at thickness outlined in the noted QAI design listing.

Product is labeled by DuROCK Alfacing International, Ltd. including the following information:

- Label:
- Manufacturer's name (DuROCK),
 - Manufacturing location (City, Province)
 - Product name
 - Expanded Polystyrene Type (Type 1 or Type 2),
 - QAI logo with 'c' indicator
 - QAI Listing Number: B1039
 - Test standards or product specifications that are met under this listing program
 - Traceability Information

Note: The product must be installed in accordance with the code enforced by the authority having jurisdiction. Final acceptance of the product in the final installation is subject to inspection by the authority having jurisdiction.

The materials, products or systems listed herein have been qualified to bear the QAI Listing Mark under the conditions stated with each Listing. Only those products bearing the QAI Listing Mark are considered to be listed by QAI.

Visit the QAI Online Listing Directory located at www.qai.org for the most up to date version of this Listing and to validate that this QAI Listing is active.

Questions regarding this listing may be directed to info@qai.org. Please include the listing number in the request.
