

FIRE DOOR LISTING PROGRAM

Customer: Eggers Industries
 Class: Fire Resistant Doors and Frames
 Location: Two Rivers, Wisconsin
 Website: www.eggersindustries.com

Listing No. F443
 Projects No. F443-1 Edition 3
 F443-2 Edition 2

Effective Date: June 9, 2017
 Last Revised Date: August 15, 2018

Standards: UL 10B *Fire Tests of Door Assemblies*
 UL 10C *Positive Pressure Fire Tests of Door Assemblies*
 NFPA 252 *Standard Methods of Fire Tests of Door Assemblies*
 CAN/ULC S104 *Standard Method for Fire Tests of Door Assemblies*

Product: 20 to 90 minute Neutral & Positive Pressure Rated Category “A” and “B” Wood and Composite Fire Doors with and without Hose Stream and Fire Door Frames.

Markings: See [FD001 - Fire Door Labeling requirements](#)

Models / Ratings: **Fire Resistance Rated Doors**

Spec. Owner	Fire Rating	Category	Listing #	Description
Eggers	20 minute no hose stream	A	F443-1-1-20	Wood Core
Eggers	20 minute no hose stream	B	F443-1-2-20	Wood Core
Eggers	45 minute	A / B	F443-1-1-45	Composite Core
Eggers	60 minute	A / B	F443-1-1-60	Composite Core
Eggers	90 minute	A / B	F443-1-1-90	Composite Core
BASF SE	20 minute	A	F411-1-1-20	Wood Core
BASF SE	20 minute	A	F411-1-2-20	Composite Core
BASF SE	45 minute	A	F411-1-1-45	Composite Core
BASF SE	60 minute	A	F411-1-1-60	Composite Core
BASF SE	90 minute	A	F411-1-1-90	Composite Core

Fire Resistance Rated Door Frames

Spec Owner	Fire Rating	Category	Listing #	Description
BASF SE	20 minute	C	F411-2-20	Composite Frame
BASF SE	45 minute	C	F411-2-45	Composite Frame
BASF SE	60 minute	C	F411-2-60	Composite Frame
BASF SE	90 minute	C	F411-2-90	Composite Frame

- Notes:
- Refer to QAI evaluation reports F443-1 and F443-2 and the applicable test reports for test assembly configurations used for fire endurance testing.
 - Refer to the [QAI FD002 - Fire Door Guidelines for general guidelines of fire door assemblies](#)
 - Final acceptance of the product in the intended application is to be determined by the authority having jurisdiction (AHJ).
 - Product is to be installed in accordance with the manufacturer's published installation instructions by qualified installing personnel.

The materials, products or systems listed herein have been qualified to bear the QAI Listing Mark under the conditions stated with each Listing. Only those products bearing the QAI Listing Mark are considered to be listed by QAI. No warrantee is expressed or implied, and no guarantee is provided that any jurisdictional authority will accept the Listing found herein. The appropriate authorities should be contacted regarding the acceptability of any given Listing. Visit the QAI Online Listing Directory located at www.qai.org for the most up to date version of this Listing and to validate that this QAI Listing is active. Questions regarding this listing may be directed to info@qai.org. Please include the listing number in the request.
