

HORIZONTAL FIRE DOOR PROGRAM

Class: Horizontal Fire Door / Access Door

Customer: Fakro sp. Z o. o.
Location: Węgierska 144a Str
 33-300 Nowy Sacz,
 Poland

Listing No. B1083-1
Effective Date: October 30, 2015
Last Revised: No Revisions to Date.
Expires: N/A

Product: 43 min (ASTM E119, CAN/ULC S101) / 30 min (NFPA 288) Rated
 Horizontal Fire Door / Access Door

Standard: ASTM E119 *Standard Test Methods for Fire Tests of Building Construction Materials*
 CAN/ULC S101 *Standard Methods of Fire Endurance Tests of Building Construction and Materials*
 NFPA 288 *Standard Methods of Fire Tests of Horizontal Fire Door Assemblies Installed in Horizontal Fire Resistance-Rated Assemblies*

Label: See FD001 – Fire Door Labeling Requirements

Models: 43 min (ASTM E119, S101) / 30 min (NFPA 288) Fire Rated LMF, LWF and LST Attic Ladders

QAI Design #	Models	Maximum Dimensions	Installation	Rating
B1083-1A	LMF, LWF, LSF	54-3/8 in. (1382 mm) by 28-1/2 in. (724 mm)	See Design Listing	ASTM E119, CAN/ULC S101 – 43 min NFPA 288 – 30 min

Note:

The door assembly noted above is required to be installed per the manufacturer's installation instructions, and this listing. The installation requires installation into a listed fire rated floor / ceiling assembly.

The materials, products or systems listed herein have been qualified to bear the QAI Listing Mark under the conditions stated with each Listing. Only those products bearing the QAI Listing Mark are considered to be listed by QAI.

No warrantee is expressed or implied, and no guarantee is provided that any jurisdictional authority will accept the Listing found herein. The appropriate authorities should be contacted regarding the acceptability of any given Listing.

Visit the QAI Online Listing Directory located at www.qai.org for the most up to date version of this Listing and to validate that this QAI Listing is active.

Questions regarding this listing may be directed to info@qai.org. Please include the listing number in the request.
