

FACTORY CONSTRUCTED BUILDINGS AND STRUCTURES LISTING PROGRAM

Customer: Goscobec Inc.
Class: Business Commercial Industrial Structures – For Electrical Features Only
Location: Riviere-du-Loop, Quebec
Website: www.goscobec.com

Listing No. REC649-2
Project No. REC649-2 Edition 1
Effective Date: December 6, 2016
Last Revised Date: December 6, 2016
Expires: N/A

Standards: CSA A277 “Procedure for Factory Certification of Buildings”
Canadian Electrical Code Part 1

Product: Business Commercial Industrial Structures – For Electrical Features Only

Markings: All markings must be permanent and visible after installation.

The QAI compliance label (item 1069) is normally located in close proximity to the electrical panel.

The specification nameplate (item 1068, 8-1/2” x 14” in size) is located in close proximity to the electrical panel and includes:

- Manufacturer’s Name and Address
- Date of Manufacture
- Model Serial Number or Product Code
- Foundation Type (Perimeter Foundation Wall or Piers)
- Floor live Load
- Specified Snow Load (1/50)
- Seismic Response $S_a(0.2)$
- Hourly Wind Pressure (1/50)
- Envelope Effective Thermal Resistance
- Windows/Doors/Skylights Thermal Characteristics
- Outside Design Temperature (Heat Loss or Heat Gain)
- Factory Installed Appliances
- Site Installed Components, Assemblies, and Systems
- Electrical Systems Voltage, Frequency, and Amperage
- QAI logo shown here:



Other Markings as required by the relevant codes.

The QAI label and specification nameplate are available from QAI and must be applied at the factory.

Models / Ratings: The scope of Business Commercial Industrial Structures covered in this listing include:

Buildings:

Business Commercial Industrial Structures comprised of single or multiple modules. Structures included in this listing are typically offices, sleeping or dining cars, classrooms, and/or other similar units.

Electrical Ratings:

Up to a maximum of 600V AC, single or 3 phase systems, 60Hz, 600A maximum.

Notes: Business Commercial Industrial structures included in this listing are manufactured at a central facility and transported to the site. These modules, when completely assembled on site, are equipped with normal facilities for connection to municipal water, sewage, and electrical services. QAI certification covers the installation of the electrical system in the factory and is intended to obviate the necessity of further inspection by the local regulatory authorities except for site connections to services or to other modules and for site mounting features.

The materials, products or systems listed herein have been qualified to bear the QAI Listing Mark under the conditions stated with each Listing. Only those products bearing the QAI Listing Mark are considered to be listed by QAI. No warrantee is expressed or implied, and no guarantee is provided that any jurisdictional authority will accept the Listing found herein. The appropriate authorities should be contacted regarding the acceptability of any given Listing. Visit the QAI Online Listing Directory located at www.qai.org for the most up to date version of this Listing and to validate that this QAI Listing is active. Questions regarding this listing may be directed to info@qai.org. Please include the listing number in the request.
