

FIRE DOOR LISTING PROGRAM

Customer: Jeld-Wen Inc.
 Class: Fire Resistant Doors
 Location: Klamath Falls, Oregon
 Website: www.jeld-wen.com

Listing No. F441-1-1-20
 Project No. F441-1 Edition 5

Effective Date: May 9, 2017
 Last Revised Date: October 9, 2019

Standards: UL 10B *Fire Tests of Door Assemblies*
 UL 10C *Positive Pressure Fire Tests of Door Assemblies*
 NFPA 252 *Standard Methods of Fire Tests of Door Assemblies*

Product: 20 minute Positive Pressure rated Fire Doors without hose stream

Markings: See [FD001 - Fire Door Labeling requirements](#)

Models: **20 MINUTE WOOD CORE FIRE DOORS CATEGORY A (POSITIVE PRESSURE):**

Minimum 1-3/4" Thickness

Swing Type:	Maximum Dimensions		Panel Type:	Latching:
	Width:	Height:		
Single Swing	3'6" (1067 mm)	8'0" (2438 mm)	Flat or Raised	Single Point (Mortised or Cylindrical)
Pair	7'0" (2134 mm)	8'0" (2438 mm)	Flat or Raised	3 or 4 Point (Active: Mortised or Cylindrical) (Inactive: Mortised or Surface Mounted exit devices)
Double Egress	NOT PERMITTED			

- The above Category A Positive Pressure Fire Doors are manufactured with edge sealing gasketing. Doors do not require additional gasketing for positive pressure applications.

Additions / Limitations: (Review Machining Specifications Report for details)

Latch Sets (Listed and labeled for rated opening and door type)

- Cylindrical Latches
 - Maximum 2-3/4" backset.
 - Maximum 2-1/8" bore size.
- Mortised Latch
 - Max. mortise pocket 4-3/8" deep x 6-3/8" high x 1-1/8" thick.



Deadbolts (Listed and labeled for rated opening and door type)

- Maximum 2-3/4" backset.
- Maximum 2-1/8" bore size.
- Located a minimum of 6" center-line to center-line from the latch cutout.

Hinges (Listed and labeled for rated opening and door type)

- Hinges as per NFPA 80, Table 6.4.3.1
- Spring hinges (minimum of two per door leaf are required).
- Continuous hinges.

Fire Exit Devices (Listed and labeled for rated opening and door type)

- Surface Mounted Vertical Rod, Rim Exit Device, Mortised Exit Device.
- Installed with through-bolts.

Door Closers (Listed and labeled for rated opening and door type)

- Required on all fire doors:
 - Option 1 - Surface Mounted Closers installed with through-bolts.
 - Option 2 - Spring hinges, minimum of two per door leaf is required.

Surface Mounted Protection Plates

- Brass, bronze, steel, aluminum, polycarbonate, or decorative laminate plates
- Top of the plate shall be a maximum of 16" above the bottom of the door.
- May be on one or both sides of the door.

Viewers (Listed and labeled for rated opening and door type)

- Maximum 3/4" diameter opening.

Glass Lites (Listed and labeled for rated opening and door type)

- Glazing material shall be listed and labeled for rated opening, lite kit and door type.
- Permitted listed glazing include wired glass, Firelite, and Firelite Plus.
- Listed Steel Lite Kit – max. 987 sq. in. (max dimension of 39").
- Glazing installed in accordance with NFPA 80, and the listed lite kit frame installation instructions.

Door Bottoms Seals (Listed and labeled for rated opening and door type)

- Automatic door bottom (surface mounted only).

Surface Mounted and Flush Bolts

(Listed and labeled for rated opening and door type)

- Surface mounted and mortise manual bolts.
- Surface mounted and mortise automatic bolts.

- Notes:
- Refer to QAI evaluation report F441-1 and the applicable test reports for test assembly configurations used for fire endurance testing.
 - Refer to the [QAI FD002 - Fire Door Guidelines for general guidelines of fire door assemblies](#)
 - Final acceptance of the product in the intended application is to be determined by the authority having jurisdiction (AHJ).
 - Product is to be installed in accordance with the manufacturer's published installation instructions by qualified installing personnel.

The materials, products or systems listed herein have been qualified to bear the QAI Listing Mark under the conditions stated with each Listing. Only those products bearing the QAI Listing Mark are considered to be listed by QAI. No warrantee is expressed or implied, and no guarantee is provided that any jurisdictional authority will accept the Listing found herein. The appropriate authorities should be contacted regarding the acceptability of any given Listing. Visit the QAI Online Listing Directory located at www.qai.org for the most up to date version of this Listing and to validate that this QAI Listing is active. Questions regarding this listing may be directed to info@qai.org. Please include the listing number in the request.
