

BUILDING PRODUCTS LISTING PROGRAM

Class: Fiberglass Reinforced Polymer Panels

Customer: Kreysler & Associates
Location: 501 Green Island Rd., American Canyon, CA 94503

Listing No. B1033-1
Project No. B1033-1, Edition 3
Effective Date: August 30, 2011
Last Revised: May 20, 2013
Expires: N/A

Product: Fire resistant composite panels for interior and exterior architectural applications, constructed from fiberglass and fire retardant resin.

Label: Products are labeled with the following: Manufacturer's Name, Address of manufacture, Product name, Date of Manufacture, QAI logo with the "US" identifier, QAI listing number, Unique part number, "ASTM E84 Class A"

Standard: ASTM E84 – "Standard Test Method for Surface Burning Characteristics of Building Materials"

Models:	<u>Product Name</u>	<u>Flame Spread Index (FSI)</u>	<u>Smoke Developed Index (SDI)</u>	<u>Rating</u>	<u>Thickness Range</u>
	Kreysler Fireshield with Kastone	20	250	Class A	1/8-inch to 3/8-inch
	Kreysler Fireshield	20	250	Class A	1/8-inch to 3/8-inch
	Kreysler Fireshield 285 with Kastone	15	350	Class A	1/8-inch to 3/8-inch

Note: The product was tested in the flat configuration. Installation of this product must comply with local building codes and is subject to inspection by the authority having jurisdiction. The ASTM E84 standard does not address all possible end use concerns. It is the responsibility of the end user of the product to determine the suitability of the product for the intended application.
