

BUILDING PRODUCTS LISTING PROGRAM

Class: Insulated Metal Wall Panels

Customer: Metl-Span a division of NCI Group, Inc.
Location: 1720 Lakepointe Drive, Lewisville, Texas

Listing No. B1087-1
Effective Date: October 15, 2015
Last Revised: April 7, 2020
Expires: No Expiration

Website: <http://www.metlspan.com/>

Products: Metl-Span CleanSeam™ Wall and Ceiling Panels.

Metl-Span CleanSeam™ Joint Sealant
(FRP joint sealing material)

Standard(s): ASTM E84 “Standard Test Method for Surface Burning Characteristics of Building Materials”.

NFPA 286 “Standard Methods of Fire Tests for Evaluating Contribution of Wall and Ceiling Interior Finish to Room Fire Growth”.

International Building Code (IBC) 2018 Section 803.12 *Stability*.

Label: CleanSeam™ panels are marked with labels supplied by Metl-Span. The label includes:

- Manufacturer’s Name,
- Manufacturing Address,
- Product Name,
- Class A Flame Spread,
- QAI Logo with “C” and “US” indicator, and



- QAI Listing Number (B1087).

Note Metl-Span CleanSeam™ Wall and Ceiling Panels are also certified to Canadian requirements see [Canadian Listing](#)

Ratings: The following outlines Metl-Span CleanSeam™ Wall and Ceiling Panels with CleanSeam™ Joint Sealant connections performance determined in accordance with the noted standards. The ratings outlined in the tables below are achieved in assemblies that are defined in the QAI Design Listings.

Metl-Span CleanSeam™ Wall and Ceiling Panels with Joint Sealant ASTM E84 and NFPA 286 Results

QAI Design #	Flame Spread Index	Smoke Developed Index	Max. Panel Thickness	NFPA 286
B1087-1a ¹	≤ 25	≤ 450	6 Inches	Meets Section 2603.9 of IBC

Note 1: The above assembly has been evaluated and found compliant for use as Class A interior finish as outlined in the International Building Code Section 803.1.1 Interior Wall and Ceiling Finish Materials (or Section 803.1 on some code editions), and complies with Section 803.12 Stability (or Section 803.3 on some code editions).

The above assembly has been evaluated and found compliant for use as interior walls and ceilings in single story buildings of Type I, II, III, and IV construction per Chapter 26 of the International Building Code for use without a code prescribed thermal barrier per testing in accordance with Section 2603.9 Special Approval (or Section 2306.10 on some code editions).

This assembly is not evaluated for fire-resistance rated wall applications.

Notes: Final acceptance of the product in the intended application is to be determined by the authority having jurisdiction.

Product is to be installed in accordance with the QAI Design Listing and manufacturer's published installation instructions by qualified installing personnel.

The materials, products or systems listed herein have been qualified to bear the QAI Listing Mark under the conditions stated with each Listing. Only those products bearing the QAI Listing Mark are considered to be listed by QAI.

No warranty is expressed or implied, and no guarantee is provided that any jurisdictional authority will accept the Listing found herein. The appropriate authorities should be contacted regarding the acceptability of any given Listing.

Visit the QAI Online Listing Directory located at www.qai.org for the most up to date version of this Listing and to validate that this QAI Listing is active.

Questions regarding this listing may be directed to info@qai.org. Please include the listing number in the request.
