

FENESTRATION LISTING PROGRAM

Customer: Modern Aluminum & Vinyl Products Ltd.
 Class: Vinyl Windows
 Location: Powell River, BC
 Website: <https://modern.ca/>
 Listing No. W442
 Report No. W442-1 ED6
 Effective Date: April 17, 2009
 Last Revised Date: January 16, 2020
 Expires: <N/A>
 Standards: CSA A440.2-19 “Fenestration Energy Performance”
 Product: Vinyl Windows
 Markings: <Products are marked in a permanent manner where it is readily visible after installation with the following:
 a) Manufacturer’s name or trademark
 b) QAI file Number: W442
 c) Evaluation for energy performance only to CSA A440.2.
 d) Évaluation pour le performance d’énergie seulement a CSA A440.2.
 e) QAI logo shown here:



Models / Ratings:

Fenestration Product Model	Glazing Option Model Code	U-Value (W/m ² *K)	Energy Rating
3000 Picture Window	MAV-3000-PC-3,SB60(2)-3,CL-13AR90EE	1.52	N/A
3000 Picture Window	MAV-3000-PC-3,SB60(2)-3,i89(4)-13AR90EE	1.27	N/A
3000 Picture Window	MAV-3000-PC-3,SB70(2)-3,i89(4)-13AR90EE	1.25	N/A

Fenestration Product Model	Glazing Option Model Code	U-Value (W/m ² *K)	Energy Rating
3000 Single Slider Window	MAV-3000-SS-3,SB60(2)-3,CL-13AR90EE-R12	1.58	N/A
3000 Single Slider Window	MAV-3000-SS-3,SB60(2)-3,i89(4)-13AR90EE-R12	1.35	N/A
3000 Single Slider Window	MAV-3000-SS-3,SB70(2)-3,i89(4)-13AR90EE-R12	1.33	N/A
3000 Single Slider Window	MAV-3000-SS-3,SB60(2)-3,CL-13AR90EE-R18	1.58	N/A
3000 Single Slider Window	MAV-3000-SS-3,SB60(2)-3,i89(4)-13AR90EE-R18	1.35	N/A
3000 Single Slider Window	MAV-3000-SS-3,SB70(2)-3,i89(4)-13AR90EE-R18	1.33	N/A
3000 Single Slider Window	MAV-3000-SS-3,SB60(2)-3,CL-13AR90EE	1.56	N/A
3000 Single Slider Window	MAV-3000-SS-3,SB60(2)-3,i89(4)-13AR90EE	1.33	N/A
3000 Single Slider Window	MAV-3000-SS-3,SB70(2)-3,i89(4)-13AR90EE	1.31	N/A

Fenestration Product Model	Glazing Option Model Code	U-Value (W/m ² *K)	Energy Rating
3000 Single Hung Window	MAV-3000-SH-3,SB60(2)-3,CL-13AR90EE-R12	1.58	N/A
3000 Single Hung Window	MAV-3000-SH-3,SB60(2)-3,i89(4)-13AR90EE-R12	1.34	N/A
3000 Single Hung Window	MAV-3000-SH-3,SB70(2)-3,i89(4)-13AR90EE-R12	1.32	N/A
3000 Single Hung Window	MAV-3000-SH-3,SB60(2)-3,CL-13AR90EE-R18	1.58	N/A
3000 Single Hung Window	MAV-3000-SH-3,SB60(2)-3,i89(4)-13AR90EE-R18	1.34	N/A
3000 Single Hung Window	MAV-3000-SH-3,SB70(2)-3,i89(4)-13AR90EE-R18	1.32	N/A
3000 Single Hung Window	MAV-3000-SH-3,SB60(2)-3,CL-13AR90EE	1.56	N/A
3000 Single Hung Window	MAV-3000-SH-3,SB60(2)-3,i89(4)-13AR90EE	1.33	N/A
3000 Single Hung Window	MAV-3000-SH-3,SB70(2)-3,i89(4)-13AR90EE	1.31	N/A

Fenestration Product Model	Glazing Option Model Code	U-Value (W/m ² *K)	Energy Rating
4000 Picture Window	MAV-4000-PC-3,SB60(2)-3,CL-13AR90EE	1.50	N/A
4000 Picture Window	MAV-4000-PC-3,SB60(2)-3,i89(4)-13AR90EE	1.26	N/A
4000 Picture Window	MAV-4000-PC-3,SB70(2)-3,i89(4)-13AR90EE	1.23	N/A

Fenestration Product Model	Glazing Option Model Code	U-Value (W/m ² *K)	Energy Rating
4000 Awning Window	MAV-4000-AW-3,SB60(2)-3,CL-13AR90EE	1.49	N/A
4000 Awning Window	MAV-4000-AW-3,SB60(2)-3,i89(4)-13AR90EE	1.31	N/A
4000 Awning Window	MAV-4000-AW-3,SB70(2)-3,i89(4)-13AR90EE	1.30	N/A

Fenestration Product Model	Glazing Option Model Code	U-Value (W/m ² *K)	Energy Rating
4000 Casement Window	MAV-4000-CA-3,SB60(2)-3,CL-13AR90EE	1.51	N/A
4000 Casement Window	MAV-4000-CA-3,SB60(2)-3,i89(4)-13AR90EE	1.35	N/A
4000 Casement Window	MAV-4000-CA-3,SB70(2)-3,i89(4)-13AR90EE	1.33	N/A

Notes: Windows are not intended for installation in storefronts, non-operable portions of curtain wall, fixed glazing cast into precast concrete panels, greenhouses, skylights or sloped glazing. Test procedures are designed to test the performance of the test specimen only and are not necessarily used to test the performance of the installation, particularly the perimeter sealant joint and anchoring of the assembly.

The materials, products or systems listed herein have been qualified to bear the QAI Listing Mark under the conditions stated with each Listing. Only those products bearing the QAI Listing Mark are considered to be listed by QAI. No warrantee is expressed or implied, and no guarantee is provided that any jurisdictional authority will accept the Listing found herein. The appropriate authorities should be contacted regarding the acceptability of any given Listing. Visit the QAI Online Listing Directory located at www.qai.org for the most up to date version of this Listing and to validate that this QAI Listing is active. Questions regarding this listing may be directed to info@qai.org. Please include the listing number in the request.
