

PLUMBING PRODUCTS LISTING PROGRAM

Customer: Reliance Worldwide Corporation DBA HoldRite
 Class: Concrete Sleeves
 Location: 2400 7th Ave. SW, Cullman, AL 35055
 Website: www.rwc.com

Listing No. P343-3
 Project No. P343-3
 Effective Date: November 3, 2022
 Last Revised Date: January 24, 2023
 Expires: <N/A>

Standards: UL 2043 *Fire test for Heat and Visible Smoke Release for Discrete Products and their Accessories Installed in Air-Handling Spaces.*

Products: HoldRite HydroFlame™ Firestop Sleeves
 HoldRite HydroFlame™ Hollow Sleeves
 HoldRite HydroFlame™ Tub Box
 HoldRite HydroFlame™ Aerator Adapter Box
 HoldRite HydroFlame™ Cast Iron Drain Sleeves
 HoldRite HydroFlame™ Electrical Firestop Sleeves

Models:	Firestop Sleeves	Electrical Firestop Sleeves	Tub Boxes	Aerator Adaptor Boxes
	HFP-(P/M)1 HFP-(P/M)2 HFP-(P/M)3 HFP-(P/M)4 HFP-(P/M)5 HFP-(P/M)6 HF-(P/M)8 HF-(P/M)10 HF-(P/M)12	HFP-(G1/G1B) HFP-(G2/G2B) HFP-(G3/G3B) HFP-(G4/G4B) HFP-(G5/G5B) HFP-(G6/G6B)	HFPLTB-NP-0200-8 HFPLTB-TW-0200-8 HFPLTB-NP-0200-9 HFPLTB-TW-0200-9 HFPLTB-NP-0200-10 HFPLTB-TW-0200-10 HFPLTB-NP-0300-8 HFPLTB-TW-0300-8 HFPLTB-NP-0300-9 HFPLTB-TW-0300-9 HFPLTB-NP-0300-10 HFPLTB-TW-0300-10 HFPTB-TW-0200 HFPTB-NP-0200	HFPA2 HFPA3 HFPA4 HFPA5 HFPA6
	Hollow Sleeves	Cast Iron Drain Sleeves		
	HFP-H2 HFP-H3 HFP-H4 HFP-H5 HFP-H6 HFP-H7	HFP-2CI-DRN HFP-23CI-DRN HFP-34CI-DRN HFP-6CI-DRN		

Markings: All concrete sleeve products or packaging are marked with the following content:

- a) Manufacturer’s name or trademark
- b) Product Name
- c) Nominal Size
- d) UL 2043 Compliant
- e) QAI logo with ‘us’ identifier shown below:

Rating(s): **The following outlines the performance of the HoldRite Concrete Sleeve products determined in accordance with the noted standards.**

HoldRite Firestop Sleeves and Electrical Firestop Sleeves cast in places devices evaluated to UL 2043:

Models		Minimum Concrete Depth ¹	Rating ^{2,3}
Firestop Sleeves	Electrical Firestop Sleeves		
HFP-(P/M)1	HFP-(G1/G1B)	3.5” (89 mm)	UL 2043 Compliant
HFP-(P/M)2	HFP-(G2/G2B)		
HFP-(P/M)3	HFP-(G3/G3B)		
HFP-(P/M)4	HFP-(G4/G4B)		
HFP-(P/M)5	HFP-(G5/G5B)		
HFP-(P/M)6	HFP-(G6/G6B)		
HF-(P/M)8			
HF-(P/M)10			
HF-(P/M)12			

Note 1: Minimum concrete depth noted is for UL 2043 compliance only. Concrete depth required for structural loading and fire-resistance ratings (where required) are outside the scope of this listing.

Note 2: UL 2043 evaluation was for the noted HoldRite models only. Penetrating items attached or installed through the models are outside the scope of this listing.

Note 3: Rating is for compliance to UL 2043 only. Compliance for use as firestopping in fire-resistance rated applications are outside the scope of this listing.



HoldRite Hollow Sleeves and Cast-Iron Drain Sleeves cast in place devices evaluated to UL 2043:

Models		Minimum Concrete Depth ¹	Rating ^{2,3}
Hollow Sleeves	Cast Iron Drain Sleeves		
HFP-H2 HFP-H3 HFP-H4 HFP-H5 HFP-H6 HFP-H7	HFP-2CI-DRN HFP-23CI-DRN HFP-34CI-DRN HFP-6CI-DRN	3.5" (89 mm)	UL 2043 Compliant

Note 1: Minimum concrete depth noted is for UL 2043 compliance only. Concrete depth required for structural loading and fire-resistance ratings (where required) are outside the scope of this listing.

Note 2: UL 2043 evaluation was for the noted HoldRite models only. Penetrating items attached or installed through the models are outside the scope of this listing.

Note 3: Rating is for compliance to UL 2043 only. Compliance for use as firestopping in fire-resistance rated applications are outside the scope of this listing.

HoldRite Tub Boxes cast in place devices evaluated to UL 2043:

Models	Minimum Concrete Depth ¹	Rating ^{2,3}
HFPLTB-NP-0200-8 HFPLTB-TW-0200-8 HFPLTB-NP-0200-9 HFPLTB-TW-0200-9 HFPLTB-NP-0200-10 HFPLTB-TW-0200-10 HFPLTB-NP-0300-8 HFPLTB-TW-0300-8 HFPLTB-NP-0300-9 HFPLTB-TW-0300-9 HFPLTB-NP-0300-10 HFPLTB-TW-0300-10 HFPTB-TW-0200 HFPTB-NP-0200	3.5" (89 mm)	UL 2043 Compliant

Note 1: Minimum concrete depth noted is for UL 2043 compliance only. Concrete depth required for structural loading and fire-resistance ratings (where required) are outside the scope of this listing.

Note 2: UL 2043 evaluation was for the noted HoldRite models only. Penetrating items attached or installed through the models are outside the scope of this listing.

Note 3: Rating is for compliance to UL 2043 only. Compliance for use as firestopping in fire-resistance rated applications are outside the scope of this listing.

HoldRite Aerator Boxes cast in place devices evaluated to UL 2043:

Models	Minimum Concrete Depth ¹	Rating ^{2,3}
HFPA2 HFPA3 HFPA4 HFPA5 HFPA6	3.5" (89 mm)	UL 2043 Compliant

Note 1: Minimum concrete depth noted is for UL 2043 compliance only. Concrete depth required for structural loading and fire-resistance ratings (where required) are outside the scope of this listing.

Note 2: UL 2043 evaluation was for the noted HoldRite models only. Penetrating items attached or installed through the models are outside the scope of this listing.

Note 3: Rating is for compliance to UL 2043 only. Compliance for use as firestopping in fire-resistance rated applications are outside the scope of this listing.

Note: The materials, products or systems listed herein have been qualified to bear the QAI Listing Mark under the conditions stated with each Listing. Only those products bearing the QAI Listing Mark are considered to be listed by QAI. No warranty is expressed or implied, and no guarantee is provided that any jurisdictional authority will accept the Listing found herein. The appropriate authorities should be contacted regarding the acceptability of any given Listing. Visit the QAI Online Listing Directory located at www.qai.org for the most up to date version of this Listing and to validate that this QAI Listing is active. Questions regarding this listing may be directed to info@qai.org. Please include the listing number in the request.
