

## ELECTRICAL LISTING PROGRAM

Customer: Spider Electric Ltd.  
Class: Ordinary Location Panel Shop  
Location: Medicine Hat, AB, Canada  
Listing No. E10801  
Project No. E10801-1601  
Effective Date: October 1<sup>st</sup>, 2016  
Last Revised Date: N/A  
Expires: N/A

Standards: CSA C22.2 No. 14 “Industrial control equipment – Thirteenth Edition”

Product: cQAI Ordinary Location Panel Shop

Markings: Products are marked in a permanent manner where it is readily visible after installation with the following:

- a) Manufacturer’s name or trademark
- b) Model designation
- c) Month and year of manufacture
- d) Product ratings: voltage, amperage, phase and frequency
- e) QAI logo with ‘c’ identifier
- f) QAI file Number: E10801
- g) The wording “CSA C22.2 No. 14”
- h) Warning markings as required by the standards in English and French

Models / Ratings: 208-600 AC Volts, 100 Amps max, 3 Phase  
120 AC Volts, 20 Amps max, Single Phase  
24V DC Volts, 20 Amps max

Notes: Final acceptance of the panel is subject to inspection by the Authority Having Jurisdiction (AHJ.)

The materials, products or systems listed herein have been qualified to bear the QAI Listing Mark under the conditions stated with each Listing. Only those products bearing the QAI Listing Mark are considered to be listed by QAI. No warrantee is expressed or implied, and no guarantee is provided that any jurisdictional authority will accept the Listing found herein. The appropriate authorities should be contacted regarding the acceptability of any given Listing. Visit the QAI Online Listing Directory located at [www.qai.org](http://www.qai.org) for the most up to date version of this Listing and to validate that this QAI Listing is active. Questions regarding this listing may be directed to [info@qai.org](mailto:info@qai.org). Please include the listing number in the request.

\*\*\*