

BUILDING PRODUCTS LISTING PROGRAM

Customer: Superform Products, Ltd.
Class: Insulated Concrete Forms (ICF)
Location: Pincher Creek, Alberta
Website: www.superformicf.ca
Listing No. B1051-1
Project B1051-1, Edition 3
No.
Effective July 25, 2012
Date:
Last September 1, 2020
Revised:

Standards: CAN/ULC S717.1 *Standard for Flat Wall Insulating Concrete Form (ICF) Systems.*
ASTM E2634 *Standard Specification for Flat Wall Insulating Concrete Form (ICF) Systems.*
ASTM D1761 *Standard Test Methods for Mechanical Fasteners in Wood and Wood-Based Materials.*
CAN/ULC S701.1 *Thermal Insulation, Polystyrene, Boards and Pipe Covering.*
ASTM C578 *Standard Specification for Rigid, Cellular Polystyrene Thermal Insulation.*
CAN/ULC S102.2 *Standard Method of Test for Surface Burning Characteristics of Flooring, Floor Coverings, and Miscellaneous Materials and Assemblies.*
ASTM E84 *Standard Test Method for Surface Burning Characteristics of Building Materials.*
UBC-26-3 *Room Fire Test Standard for Interior of Foam Plastic Systems.*
ASTM D635 *Standard Test Method for Rate of Burning and/or Extent and Time of Burning of Plastics in a Horizontal Position.*
ASTM D1929 *Standard Test Method for Determining Ignition Temperature of Plastics.*
ASTM E119 *Standard Test Methods for Fire Tests of Building Construction and Materials.*
CAN/ULC S101 *Standard Methods of Fire Endurance Tests of Building Construction and Materials.*
UL 263 *Standard for Fire Tests of Building Construction and Materials.*

Product: Superform Insulated Concrete Forms (ICF)

Markings: Product is marked with labels supplied by Superform Products, Ltd. Products are marked in a permanent manner where it is readily visible after installation with the following:

- a) Manufacturer's name or trademark
- b) Product model designation
- c) Month and year of manufacture
- d) QAI file Number: B1051-1
- e) CAN/ULC S701 Type 2, ASTM C578 Type II, ASTM E84 FSI and SDI Rating, and CAN/ULC S102.2 FSI and SDI ratings.
- f) QAI logo shown here:



Models / **Superform ICF complies with specifications for flat-walled ICF in accordance**
 Ratings: **with CAN/ULC S717.1.**

Superform ICF complies with specifications for flat-walled insulated concrete forms in accordance with ASTM E2634.

Superform ICF cross ties have a spontaneous ignition temperature $\geq 650^{\circ}\text{F}$ when evaluated in accordance with ASTM D1929.

Superform ICF cross ties have a rate of burning of CC2 when evaluated in accordance with ASTM D635.

The following outlines Superform ICF test results determined in accordance with the noted standards.

Superform ICF has the following allowable fastener load capacities determined in accordance with ASTM E2634 and ASTM D1761:

FASTENER	ALLOWABLE WITHDRAWAL		ALLOWABLE LATERAL SHEAR	
	lbs	kg	lbs	kg
#6 Coarse Thread Drywall Screw, minimum penetration ¼ inch (19 mm) into Superform ICF Crossties.	26	12	47	21
#10 Coarse Thread Wood Screw, minimum penetration ¼ inch (19 mm) into Superform ICF Crossties.	31	14	56	25

#14 Coarse Thread Wood Screw, minimum penetration ¾ inch (19 mm) into Superform ICF Crossties.	30	14	67	30
16 Gauge ½ inch Crown Staple, minimum penetration 1 inch (25 mm) into Superform ICF Crossties.	5	2.5	17	8

Superform ICF Type 2 Specifications per CAN/ULC S701.1

PROPERTY	SUPERFORM SPECIFICATION
Thermal Resistance m ² *°C/W at 25 mm Thickness	Minimum 0.70
Water Vapour Permeance Ng/Pa*s*m ² at 25 mm Thickness	Maximum 200
Dimensional Stability % Linear Change	Maximum 1.5
Flexural Strength kPa	Minimum 240
Water Absorption % Volume	Maximum 4.0
Compressive Strength kPa at 10% Deformation	Minimum 110
Limiting Oxygen Index %	Minimum 24

Superform ICF Type II Specifications per ASTM C578

PROPERTY	SUPERFORM SPECIFICATION
Compressive Resistance psi at Yield or 10% Deformation	Minimum 15.0
Thermal Resistance F*ft ² *h/Btu at 1.00 Inch Thickness	Minimum 4.0
Flexural Strength psi	Minimum 35.0
Water Vapor Permeance Perms at 1.00 Inch Thickness	Maximum 3.5
Water Absorption % Volume	Maximum 3.0
Dimensional Stability % Change Dimensions	Maximum 2.0
Oxygen Index % Volume	Minimum 24.0
Density lbs/ft ³	Minimum 1.35

Superform ICF Surface Burning Characteristics per CAN/ULC S102.2

SUPERFORM COMPONENT	DENSITY	MAXIMUM THICKNESS	FLAME SPREAD INDEX (FSI)	SMOKE DEVELOPED INDEX (SDI)
Expanded Polystyrene (EPS Panel)	22 – 29 kg/m ³	100 mm Maximum	≤ 210	≥ 500

Superform ICF Surface Burning Characteristics per ASTM E84¹

SUPERFORM COMPONENT	DENSITY	MAXIMUM THICKNESS	FLAME SPREAD INDEX (FSI)	SMOKE DEVELOPED INDEX (SDI)
Expanded Polystyrene (EPS Panel)	1.35 – 1.80 lbs/ft ³	4.0 Inches Maximum	≤ 25	≤ 450

¹Ceiling Measurement Only. This measurement is conducted through determination of flame spread index and smoke developed index with the removal of any contribution of molten materials ignited on the floor of the tunnel assembly.

Superform UBC 26-3 Configuration

Meets requirements with ½ inch thickness gypsum fastened with 1 ¼ inch length standard drywall screws at 12 inches on center spacing in the field, and 6 inches on center spacing around the perimeter. Fasteners must be anchored into Superform ICF web ties.

Superform ICF CAN/ULC S101, UL 263, ASTM E119 – Wall Assemblies

QAI Design #	Wall Type:	Wall Load:	Fire Endurance Period:
B1051-1	Insulated Concrete Wall of minimum 6.5 inches concrete thickness	Load Bearing ¹	4-hours

Notes: Final acceptance of the product in the intended application is to be determined by the authority having jurisdiction.

Product is to be installed in accordance with the manufacturer’s published installation instructions by qualified installing personnel. Also see QAI CER_{US}-1001

The materials, products or systems listed herein have been qualified to bear the QAI Listing Mark under the conditions stated with each Listing. Only those products bearing the QAI Listing Mark are considered to be listed by QAI. No warranty is expressed or implied, and no guarantee is provided that any jurisdictional authority will accept the Listing found herein. The appropriate authorities should be contacted regarding the acceptability of any given Listing. Visit the QAI Online Listing Directory located at www.qai.org for the most up to date version of this Listing and to validate that this QAI Listing is active. Questions regarding this listing may be directed to info@qai.org. Please include the listing number in the request.
