

WINDOWS & DOORS LISTING PROGRAM

Customer: Supreme Windows (Calgary) Inc.
Class: Fenestration Products – Energy Performance
Location: Calgary, Alberta
Website: www.supremewindows.net

Listing No. W462-1
Report No. W462-1 ED5
Project No. W462-1 ED5
Effective Date: June 20, 2018
Last Revised Date: June 20, 2018
Expires: N/A

Standards: CSA A440.2 “Fenestration Energy Performance”

Product: Vinyl Windows

Markings: Products are marked with the following content in a permanent manner where it is readily visible after installation:

- a) Manufacturer’s name, Trademark or other recognized symbol or identification.
- b) QAI file Number: W462
- c) QAI logo shown here:



- d) “Evaluation for energy performance in accordance with CSA A440.2” / “Évalué pour la performance d’énergie en accord à la norme CSA A440.2”

Models / Ratings:

1638 Series Picture Window

Model Code	U-Value (W/m ² K)	Energy Rating
1638PIC-GO54	1.57	26
1638PIC-GO55	1.63	24
1638PIC-GO56	1.66	22
1638PIC-GO57	1.57	30
1638PIC-GO58	1.63	28
1638PIC-GO59	1.66	26
1638PIC-GO60	1.79	38
1638PIC-GO61	1.83	35

Model Code	U-Value (W/m ² K)	Energy Rating
1638PIC-GO62	1.86	33
1638PIC-GO63	1.30	31
1638PIC-GO64	1.35	29
1638PIC-GO65	1.37	27

1648 Series Picture Window

Model Code	U-Value (W/m ² K)	Energy Rating
1648PIC-GO54	1.50	27
1648PIC-GO55	1.56	25
1648PIC-GO56	1.61	23
1648PIC-GO57	1.50	31
1648PIC-GO58	1.56	28
1648PIC-GO59	1.61	27
1648PIC-GO60	1.71	38
1648PIC-GO61	1.76	36
1648PIC-GO62	1.80	34
1648PIC-GO63	1.23	32
1648PIC-GO64	1.29	30
1648PIC-GO65	1.32	28

2545 Series Legacy Picture Window

Model Code	U-Value (W/m ² K)	Energy Rating
2545PIC-GO1	1.50	25
2545PIC-GO2	1.56	24
2545PIC-GO3	1.60	22
2545PIC-GO4	1.15	33
2545PIC-GO5	1.18	31
2545PIC-GO6	1.19	30
2545PIC-GO7	1.17	32
2545PIC-GO8	1.20	30
2545PIC-GO9	1.22	29
2545PIC-GO10	0.85	37
2545PIC-GO11	0.88	35
2545PIC-GO12	0.91	34
2545PIC-GO13	0.89	36
2545PIC-GO14	0.92	34
2545PIC-GO15	0.96	33
2545PIC-GO16	1.67	34
2545PIC-GO17	1.72	32
2545PIC-GO18	1.75	30
2545PIC-GO19	1.28	40
2545PIC-GO20	1.30	39
2545PIC-GO21	1.31	37
2545PIC-GO22	1.04	44

Model Code	U-Value (W/m ² K)	Energy Rating
2545PIC-GO23	1.07	42
2545PIC-GO24	1.09	40
2545PIC-GO25	1.25	41
2545PIC-GO26	1.27	39
2545PIC-GO27	1.29	37
2545PIC-GO28	1.28	39
2545PIC-GO29	1.30	38
2545PIC-GO30	1.32	36
2545PIC-GO31	1.08	43
2545PIC-GO32	1.10	41
2545PIC-GO33	1.13	39
2545PIC-GO34	1.56	23
2545PIC-GO35	1.49	31
2545PIC-GO36	1.54	29
2545PIC-GO37	1.58	27
2545PIC-GO38	1.56	26
2545PIC-GO39	1.18	30
2545PIC-GO40	1.10	38
2545PIC-GO41	1.13	37
2545PIC-GO42	1.13	35
2545PIC-GO43	1.15	34
2545PIC-GO44	0.84	38
2545PIC-GO45	0.87	37
2545PIC-GO46	0.90	35
2545PIC-GO47	0.90	35
2545PIC-GO48	1.75	33
2545PIC-GO49	1.26	40
2545PIC-GO50	1.00	46
2545PIC-GO51	1.02	44
2545PIC-GO52	1.05	43
2545PIC-GO53	1.04	42

2600 Series Legacy Awning Window

Model Code	U-Value (W/m ² K)	Energy Rating
SWC-V26L-AWN-G1-4,035(2)-4,CL-11,Ar-SE	1.48	22
SWC-V26L-AWN-G2-4,035(2)-4,CL-11,Ar-SE-S	1.51	21
SWC-V26L-AWN-G3-4,035(2)-4,CL-11,Ar-SE-S	1.54	19
SWC-V26L-AWN-G4-3,035(2)-3,CL-3,CL-13,Ar-SE	1.19	27
SWC-V26L-AWN-G5-3,035(2)-3,CL-3,CL-13,Ar-SE-S	1.20	26
SWC-V26L-AWN-G6-3,035(2)-3,CL-3,CL-13,Ar-SE-S	1.21	25
SWC-V26L-AWN-G7-4,035(2)-4,CL-4,CL-11,Ar-SE	1.21	27
SWC-V26L-AWN-G8-4,035(2)-4,CL-4,CL-11,Ar-SE-S	1.22	26
SWC-V26L-AWN-G9-4,035(2)-4,CL-4,CL-11,Ar-SE-S	1.24	25
SWC-V26L-AWN-G10-3,035(2)-3,035(4)-3,CL-13,Ar-SE	0.96	30
SWC-V26L-AWN-G11-3,035(2)-3,035(4)-3,CL-13,Ar-SE-S	0.97	30
SWC-V26L-AWN-G12-3,035(2)-3,035(4)-3,CL-13,Ar-SE-S	0.99	29
SWC-V26L-AWN-G13-4,035(2)-4,035(4)-4,CL-11,Ar-SE	1.00	29
SWC-V26L-AWN-G14-4,035(2)-4,035(4)-4,CL-11,Ar-SE-S	1.02	28
SWC-V26L-AWN-G15-4,035(2)-4,035(4)-4,CL-11,Ar-SE-S	1.03	28

Model Code	U-Value (W/m ² K)	Energy Rating
SWC-V26L-AWN-G16-4,CL-4,148(3)-11,Ar-SE	1.64	30
SWC-V26L-AWN-G17-4,CL-4,148(3)-11,Ar-SE-S	1.66	29
SWC-V26L-AWN-G18-4,CL-4,148(3)-11,Ar-SE-S	1.69	27
SWC-V26L-AWN-G19-3,CL-3,148(3)-3,CL-13,Ar-SE	1.28	36
SWC-V26L-AWN-G20-3,CL-3,148(3)-3,CL-13,Ar-SE	1.28	35
SWC-V26L-AWN-G21-3,CL-3,148(3)-3,CL-13,Ar-SE	1.29	34
SWC-V26L-AWN-G22-3,CL-3,148(3)-3,148(5)-13,Ar-SE	1.08	39
SWC-V26L-AWN-G23-3,CL-3,148(3)-3,148(5)-13,Ar-SE-S	1.09	37
SWC-V26L-AWN-G24-3,CL-3,148(3)-3,148(5)-13,Ar-SE-S	1.10	37
SWC-V26L-AWN-G25-3,CL-3,148(5)-13,Ar-SE	1.25	36
SWC-V26L-AWN-G26-3,CL-3,148(5)-13,Ar-SE-S	1.26	35
SWC-V26L-AWN-G27-3,CL-3,CL-3,148(5)-13,Ar-SE-S	1.28	34
SWC-V26L-AWN-G28-4,CL-4,CL-4,148(5)-11,Ar-SE	1.29	35
SWC-V26L-AWN-G29-4,CL-4,CL-4,148(5)-11,Ar-SE-S	1.30	34
SWC-V26L-AWN-G30-4,CL-4,CL-4,148(5)-11,Ar-SE-S	1.31	33
SWC-V26L-AWN-G31-4,CL-4,148(3)-4,148(5)-11,Ar-SE	1.11	38
SWC-V26L-AWN-G32-4,CL-4,148(3)-4,148(5)-11,Ar-SE-S	1.13	36
SWC-V26L-AWN-G33-4,CL-4,148(3)-4,148(5)-11,Ar-SE-S	1.14	36
SWC-V26L-AWN-G34-4,035(2)-4,CL-13,Ar-SE-S	1.51	19
SWC-V26L-AWN-G35-4,CL-4,035(3)-13,Ar-SE	1.48	25
SWC-V26L-AWN-G36-4,CL-4,035(3)-13,Ar-SE-S	1.50	24
SWC-V26L-AWN-G37-4,CL-4,035(3)-13,Ar-SE-S	1.52	23
SWC-V26L-AWN-G38-4,CL-4,035(3)-13,Ar-SE-S	1.51	22
SWC-V26L-AWN-G39-3,035(2)-4,CL-3,CL-13,Ar-SE-S	1.19	25
SWC-V26L-AWN-G40-3,CL-4,CL-3,035(5)-13,Ar-SE	1.15	31
SWC-V26L-AWN-G41-3,CL-4,CL-3,035(5)-13,Ar-SE-S	1.17	30
SWC-V26L-AWN-G42-3,CL-4,CL-3,035(5)-13,Ar-SE-S	1.19	29
SWC-V26L-AWN-G43-3,CL-4,CL-3,035(5)-13,Ar-SE-S	1.18	28
SWC-V26L-AWN-G44-3,035(2)-4,CL-3,035(5)-13,Ar-SE	0.95	32
SWC-V26L-AWN-G45-3,035(2)-4,CL-3,035(5)-13,Ar-SE-S	0.97	31
SWC-V26L-AWN-G46-3,035(2)-4,CL-3,035(5)-13,Ar-SE-S	0.99	30
SWC-V26L-AWN-G47-3,035(2)-4,CL-3,035(5)-13,Ar-SE-S	0.98	29
SWC-V26L-AWN-G48-4,CL-4,148(3)-13,Ar-SE-S	1.59	29
SWC-V26L-AWN-G49-3,CL-4,CL-3,148(5)-13,Ar-SE-S	1.26	33
SWC-V26L-AWN-G50-3,148(2)-4,CL-3,148(5)-13,Ar-SE	1.07	38
SWC-V26L-AWN-G51-3,148(2)-4,CL-3,148(5)-13,Ar-SE-S	1.08	36
SWC-V26L-AWN-G52-3,148(2)-4,CL-3,148(5)-13,Ar-SE-S	1.10	35
SWC-V26L-AWN-G53-3,148(2)-4,CL-3,148(5)-13,Ar-SE-S	1.09	34

2600 Series Classic Awning Window

Model Code	U-Value (W/m ² K)	Energy Rating
SWC-V26C-AWN-G1-4,035(2)-4,CL-11,Ar-SE	1.48	22
SWC-V26C-AWN-G2-4,035(2)-4,CL-11,Ar-SE-S	1.51	21
SWC-V26C-AWN-G3-4,035(2)-4,CL-11,Ar-SE-S	1.54	20
SWC-V26C-AWN-G4-3,035(2)-3,CL-3,CL-13,Ar-SE	1.19	27
SWC-V26C-AWN-G5-3,035(2)-3,CL-3,CL-13,Ar-SE-S	1.20	26
SWC-V26C-AWN-G6-3,035(2)-3,CL-3,CL-13,Ar-SE-S	1.21	26
SWC-V26C-AWN-G7-4,035(2)-4,CL-4,CL-11,Ar-SE	1.21	27
SWC-V26C-AWN-G8-4,035(2)-4,CL-4,CL-11,Ar-SE-S	1.22	26

Model Code	U-Value (W/m ² K)	Energy Rating
SWC-V26C-AWN-G9-4,035(2)-4,CL-4,CL-11,Ar-SE-S	1.24	25
SWC-V26C-AWN-G10-3,035(2)-3,035(4)-3,CL-13,Ar-SE	0.96	31
SWC-V26C-AWN-G11-3,035(2)-3,035(4)-3,CL-13,Ar-SE-S	0.97	30
SWC-V26C-AWN-G12-3,035(2)-3,035(4)-3,CL-13,Ar-SE-S	0.99	29
SWC-V26C-AWN-G13-4,035(2)-4,035(4)-4,CL-11,Ar-SE	1.00	30
SWC-V26C-AWN-G14-4,035(2)-4,035(4)-4,CL-11,Ar-SE-S	1.02	29
SWC-V26C-AWN-G15-4,035(2)-4,035(4)-4,CL-11,Ar-SE-S	1.03	28
SWC-V26C-AWN-G16-4,CL-4,148(3)-11,Ar-SE	1.64	31
SWC-V26C-AWN-G17-4,CL-4,148(3)-11,Ar-SE-S	1.66	29
SWC-V26C-AWN-G18-4,CL-4,148(3)-11,Ar-SE-S	1.69	27
SWC-V26C-AWN-G19-3,CL-3,148(3)-3,CL-13,Ar-SE	1.28	36
SWC-V26C-AWN-G20-3,CL-3,148(3)-3,CL-13,Ar-SE	1.28	35
SWC-V26C-AWN-G21-3,CL-3,148(3)-3,CL-13,Ar-SE	1.29	34
SWC-V26C-AWN-G22-3,CL-3,148(3)-3,148(5)-13,Ar-SE	1.08	39
SWC-V26C-AWN-G23-3,CL-3,148(3)-3,148(5)-13,Ar-SE-S	1.09	38
SWC-V26C-AWN-G24-3,CL-3,148(3)-3,148(5)-13,Ar-SE-S	1.10	37
SWC-V26C-AWN-G25-3,CL-3,CL-3,148(5)-13,Ar-SE	1.25	36
SWC-V26C-AWN-G26-3,CL-3,CL-3,148(5)-13,Ar-SE-S	1.26	36
SWC-V26C-AWN-G27-3,CL-3,CL-3,148(5)-13,Ar-SE-S	1.28	34
SWC-V26C-AWN-G28-4,CL-4,CL-4,148(5)-11,Ar-SE	1.29	35
SWC-V26C-AWN-G29-4,CL-4,CL-4,148(5)-11,Ar-SE-S	1.30	34
SWC-V26C-AWN-G30-4,CL-4,CL-4,148(5)-11,Ar-SE-S	1.31	33
SWC-V26C-AWN-G31-4,CL-4,148(3)-4,148(5)-11,Ar-SE	1.11	38
SWC-V26C-AWN-G32-4,CL-4,148(3)-4,148(5)-11,Ar-SE-S	1.13	37
SWC-V26C-AWN-G33-4,CL-4,148(3)-4,148(5)-11,Ar-SE-S	1.14	36
SWC-V26C-AWN-G34-4,035(2)-4,CL-13,Ar-SE-S	1.51	20
SWC-V26C-AWN-G35-4,CL-4,035(3)-13,Ar-SE	1.48	25
SWC-V26C-AWN-G36-4,CL-4,035(3)-13,Ar-SE-S	1.50	24
SWC-V26C-AWN-G37-4,CL-4,035(3)-13,Ar-SE-S	1.52	23
SWC-V26C-AWN-G38-4,CL-4,035(3)-13,Ar-SE-S	1.51	23
SWC-V26C-AWN-G39-3,035(2)-4,CL-3,CL-13,Ar-SE-S	1.19	25
SWC-V26C-AWN-G40-3,CL-4,CL-3,035(5)-13,Ar-SE	1.15	32
SWC-V26C-AWN-G41-3,CL-4,CL-3,035(5)-13,Ar-SE-S	1.17	31
SWC-V26C-AWN-G42-3,CL-4,CL-3,035(5)-13,Ar-SE-S	1.19	30
SWC-V26C-AWN-G43-3,CL-4,CL-3,035(5)-13,Ar-SE-S	1.18	29
SWC-V26C-AWN-G44-3,035(2)-4,CL-3,035(5)-13,Ar-SE	0.95	32
SWC-V26C-AWN-G45-3,035(2)-4,CL-3,035(5)-13,Ar-SE-S	0.97	31
SWC-V26C-AWN-G46-3,035(2)-4,CL-3,035(5)-13,Ar-SE-S	0.99	30
SWC-V26C-AWN-G47-3,035(2)-4,CL-3,035(5)-13,Ar-SE-S	0.98	30
SWC-V26C-AWN-G48-4,CL-4,148(3)-13,Ar-SE-S	1.59	29
SWC-V26C-AWN-G49-3,CL-4,CL-3,148(5)-13,Ar-SE-S	1.26	33
SWC-V26C-AWN-G50-3,148(2)-4,CL-3,148(5)-13,Ar-SE	1.07	38
SWC-V26C-AWN-G51-3,148(2)-4,CL-3,148(5)-13,Ar-SE-S	1.08	37
SWC-V26C-AWN-G52-3,148(2)-4,CL-3,148(5)-13,Ar-SE-S	1.10	36
SWC-V26C-AWN-G53-3,148(2)-4,CL-3,148(5)-13,Ar-SE-S	1.09	35

2600 Series Legacy Casement Window

Model Code	U-Value (W/m ² K)	Energy Rating
SWC-V26L-CAS-G1-4,035(2)-4,CL-11,Ar-SE	1.49	22
SWC-V26L-CAS-G2-4,035(2)-4,CL-11,Ar-SE-S	1.53	20
SWC-V26L-CAS-G3-4,035(2)-4,CL-11,Ar-SE-S	1.56	19
SWC-V26L-CAS-G4-3,035(2)-3,CL-3,CL-13,Ar-SE	1.20	27
SWC-V26L-CAS-G5-3,035(2)-3,CL-3,CL-13,Ar-SE-S	1.22	26
SWC-V26L-CAS-G6-3,035(2)-3,CL-3,CL-13,Ar-SE-S	1.23	25
SWC-V26L-CAS-G7-4,035(2)-4,CL-4,CL-11,Ar-SE	1.22	27
SWC-V26L-CAS-G8-4,035(2)-4,CL-4,CL-11,Ar-SE-S	1.24	26
SWC-V26L-CAS-G9-4,035(2)-4,CL-4,CL-11,Ar-SE-S	1.26	25
SWC-V26L-CAS-G10-3,035(2)-3,035(4)-3,CL-13,Ar-SE	0.97	30
SWC-V26L-CAS-G11-3,035(2)-3,035(4)-3,CL-13,Ar-SE-S	0.99	29
SWC-V26L-CAS-G12-3,035(2)-3,035(4)-3,CL-13,Ar-SE-S	1.01	28
SWC-V26L-CAS-G13-4,035(2)-4,035(4)-4,CL-11,Ar-SE	1.01	29
SWC-V26L-CAS-G14-4,035(2)-4,035(4)-4,CL-11,Ar-SE-S	1.03	28
SWC-V26L-CAS-G15-4,035(2)-4,035(4)-4,CL-11,Ar-SE-S	1.05	27
SWC-V26L-CAS-G16-4,CL-4,148(3)-11,Ar-SE	1.64	30
SWC-V26L-CAS-G17-4,CL-4,148(3)-11,Ar-SE-S	1.68	29
SWC-V26L-CAS-G18-4,CL-4,148(3)-11,Ar-SE-S	1.71	27
SWC-V26L-CAS-G19-3,CL-3,148(3)-3,CL-13,Ar-SE	1.29	36
SWC-V26L-CAS-G20-3,CL-3,148(3)-3,CL-13,Ar-SE	1.30	35
SWC-V26L-CAS-G21-3,CL-3,148(3)-3,CL-13,Ar-SE	1.31	33
SWC-V26L-CAS-G22-3,CL-3,148(3)-3,148(5)-13,Ar-SE	1.09	39
SWC-V26L-CAS-G23-3,CL-3,148(3)-3,148(5)-13,Ar-SE-S	1.11	37
SWC-V26L-CAS-G24-3,CL-3,148(3)-3,148(5)-13,Ar-SE-S	1.12	36
SWC-V26L-CAS-G25-3,CL-3,CL-3,148(5)-13,Ar-SE	1.27	36
SWC-V26L-CAS-G26-3,CL-3,CL-3,148(5)-13,Ar-SE-S	1.28	35
SWC-V26L-CAS-G27-3,CL-3,CL-3,148(5)-13,Ar-SE-S	1.29	34
SWC-V26L-CAS-G28-4,CL-4,CL-4,148(5)-11,Ar-SE	1.30	35
SWC-V26L-CAS-G29-4,CL-4,CL-4,148(5)-11,Ar-SE-S	1.31	34
SWC-V26L-CAS-G30-4,CL-4,CL-4,148(5)-11,Ar-SE-S	1.33	32
SWC-V26L-CAS-G31-4,CL-4,148(3)-4,148(5)-11,Ar-SE	1.13	38
SWC-V26L-CAS-G32-4,CL-4,148(3)-4,148(5)-11,Ar-SE-S	1.14	36
SWC-V26L-CAS-G33-4,CL-4,148(3)-4,148(5)-11,Ar-SE-S	1.16	35
SWC-V26L-CAS-G34-4,035(2)-4,CL-13,Ar-SE-S	1.53	19
SWC-V26L-CAS-G35-4,CL-4,035(3)-13,Ar-SE	1.49	25
SWC-V26L-CAS-G36-4,CL-4,035(3)-13,Ar-SE-S	1.52	23
SWC-V26L-CAS-G37-4,CL-4,035(3)-13,Ar-SE-S	1.54	22
SWC-V26L-CAS-G38-4,CL-4,035(3)-13,Ar-SE-S	1.53	22
SWC-V26L-CAS-G39-3,035(2)-4,CL-3,CL-13,Ar-SE-S	1.22	25
SWC-V26L-CAS-G40-3,CL-4,CL-3,035(5)-13,Ar-SE	1.16	31
SWC-V26L-CAS-G41-3,CL-4,CL-3,035(5)-13,Ar-SE-S	1.18	30
SWC-V26L-CAS-G42-3,CL-4,CL-3,035(5)-13,Ar-SE-S	1.20	29
SWC-V26L-CAS-G43-3,CL-4,CL-3,035(5)-13,Ar-SE-S	1.20	28
SWC-V26L-CAS-G44-3,035(2)-4,CL-3,035(5)-13,Ar-SE	0.97	31
SWC-V26L-CAS-G45-3,035(2)-4,CL-3,035(5)-13,Ar-SE-S	0.99	30
SWC-V26L-CAS-G46-3,035(2)-4,CL-3,035(5)-13,Ar-SE-S	1.01	29
SWC-V26L-CAS-G47-3,035(2)-4,CL-3,035(5)-13,Ar-SE-S	1.01	29
SWC-V26L-CAS-G48-4,CL-4,148(3)-13,Ar-SE-S	1.67	27
SWC-V26L-CAS-G49-3,CL-4,CL-3,148(5)-13,Ar-SE-S	1.28	33
SWC-V26L-CAS-G50-3,148(2)-4,CL-3,148(5)-13,Ar-SE	1.08	37
SWC-V26L-CAS-G51-3,148(2)-4,CL-3,148(5)-13,Ar-SE-S	1.10	36

Model Code	U-Value (W/m ² K)	Energy Rating
SWC-V26L-CAS-G52-3,148(2)-4,CL-3,148(5)-13,Ar-SE-S	1.11	38
SWC-V26L-CAS-G53-3,148(2)-4,CL-3,148(5)-13,Ar-SE-S	1.11	34

2600 Series Classic Casement Window

Model Code	U-Value (W/m ² K)	Energy Rating
SWC-V26C-CAS-G1-4,035(2)-4,CL-11,Ar-SE	1.49	22
SWC-V26C-CAS-G2-4,035(2)-4,CL-11,Ar-SE-S	1.53	20
SWC-V26C-CAS-G3-4,035(2)-4,CL-11,Ar-SE-S	1.56	19
SWC-V26C-CAS-G4-3,035(2)-3,CL-3,CL-13,Ar-SE	1.20	27
SWC-V26C-CAS-G5-3,035(2)-3,CL-3,CL-13,Ar-SE-S	1.22	26
SWC-V26C-CAS-G6-3,035(2)-3,CL-3,CL-13,Ar-SE-S	1.23	25
SWC-V26C-CAS-G7-4,035(2)-4,CL-4,CL-11,Ar-SE	1.22	27
SWC-V26C-CAS-G8-4,035(2)-4,CL-4,CL-11,Ar-SE-S	1.24	26
SWC-V26C-CAS-G9-4,035(2)-4,CL-4,CL-11,Ar-SE-S	1.26	25
SWC-V26C-CAS-G10-3,035(2)-3,035(4)-3,CL-13,Ar-SE	0.97	30
SWC-V26C-CAS-G11-3,035(2)-3,035(4)-3,CL-13,Ar-SE-S	0.99	29
SWC-V26C-CAS-G12-3,035(2)-3,035(4)-3,CL-13,Ar-SE-S	1.01	28
SWC-V26C-CAS-G13-4,035(2)-4,035(4)-4,CL-11,Ar-SE	1.01	29
SWC-V26C-CAS-G14-4,035(2)-4,035(4)-4,CL-11,Ar-SE-S	1.03	28
SWC-V26C-CAS-G15-4,035(2)-4,035(4)-4,CL-11,Ar-SE-S	1.05	27
SWC-V26C-CAS-G16-4,CL-4,148(3)-11,Ar-SE	1.64	30
SWC-V26C-CAS-G17-4,CL-4,148(3)-11,Ar-SE-S	1.68	29
SWC-V26C-CAS-G18-4,CL-4,148(3)-11,Ar-SE-S	1.71	27
SWC-V26C-CAS-G19-3,CL-3,148(3)-3,CL-13,Ar-SE	1.29	36
SWC-V26C-CAS-G20-3,CL-3,148(3)-3,CL-13,Ar-SE	1.30	35
SWC-V26C-CAS-G21-3,CL-3,148(3)-3,CL-13,Ar-SE	1.31	33
SWC-V26C-CAS-G22-3,CL-3,148(3)-3,148(5)-13,Ar-SE	1.09	39
SWC-V26C-CAS-G23-3,CL-3,148(3)-3,148(5)-13,Ar-SE-S	1.11	37
SWC-V26C-CAS-G24-3,CL-3,148(3)-3,148(5)-13,Ar-SE-S	1.12	36
SWC-V26C-CAS-G25-3,CL-3,CL-3,148(5)-13,Ar-SE	1.27	36
SWC-V26C-CAS-G26-3,CL-3,CL-3,148(5)-13,Ar-SE-S	1.28	35
SWC-V26C-CAS-G27-3,CL-3,CL-3,148(5)-13,Ar-SE-S	1.29	34
SWC-V26C-CAS-G28-4,CL-4,CL-4,148(5)-11,Ar-SE	1.30	35
SWC-V26C-CAS-G29-4,CL-4,CL-4,148(5)-11,Ar-SE-S	1.31	34
SWC-V26C-CAS-G30-4,CL-4,CL-4,148(5)-11,Ar-SE-S	1.33	32
SWC-V26C-CAS-G31-4,CL-4,148(3)-4,148(5)-11,Ar-SE	1.13	38
SWC-V26C-CAS-G32-4,CL-4,148(3)-4,148(5)-11,Ar-SE-S	1.14	36
SWC-V26C-CAS-G33-4,CL-4,148(3)-4,148(5)-11,Ar-SE-S	1.16	35
SWC-V26C-CAS-G34-4,035(2)-4,CL-13,Ar-SE-S	1.53	19
SWC-V26C-CAS-G35-4,CL-4,035(3)-13,Ar-SE	1.49	25
SWC-V26C-CAS-G36-4,CL-4,035(3)-13,Ar-SE-S	1.52	23
SWC-V26C-CAS-G37-4,CL-4,035(3)-13,Ar-SE-S	1.54	22
SWC-V26C-CAS-G38-4,CL-4,035(3)-13,Ar-SE-S	1.53	22
SWC-V26C-CAS-G39-3,035(2)-4,CL-3,CL-13,Ar-SE-S	1.22	25
SWC-V26C-CAS-G40-3,CL-4,CL-3,035(5)-13,Ar-SE	1.16	31
SWC-V26C-CAS-G41-3,CL-4,CL-3,035(5)-13,Ar-SE-S	1.18	30
SWC-V26C-CAS-G42-3,CL-4,CL-3,035(5)-13,Ar-SE-S	1.20	29
SWC-V26C-CAS-G43-3,CL-4,CL-3,035(5)-13,Ar-SE-S	1.20	28
SWC-V26C-CAS-G44-3,035(2)-4,CL-3,035(5)-13,Ar-SE	0.97	31

Model Code	U-Value (W/m ² K)	Energy Rating
SWC-V26C-CAS-G45-3,035(2)-4,CL-3,035(5)-13,Ar-SE-S	0.99	30
SWC-V26C-CAS-G46-3,035(2)-4,CL-3,035(5)-13,Ar-SE-S	1.01	29
SWC-V26C-CAS-G47-3,035(2)-4,CL-3,035(5)-13,Ar-SE-S	1.01	29
SWC-V26C-CAS-G48-4,CL-4,148(3)-13,Ar-SE-S	1.67	27
SWC-V26C-CAS-G49-3,CL-4,CL-3,148(5)-13,Ar-SE-S	1.28	33
SWC-V26C-CAS-G50-3,148(2)-4,CL-3,148(5)-13,Ar-SE	1.08	37
SWC-V26C-CAS-G51-3,148(2)-4,CL-3,148(5)-13,Ar-SE-S	1.10	36
SWC-V26C-CAS-G52-3,148(2)-4,CL-3,148(5)-13,Ar-SE-S	1.11	38
SWC-V26C-CAS-G53-3,148(2)-4,CL-3,148(5)-13,Ar-SE-S	1.11	34

2630 Series Legacy Fixed Window

Model Code	U-Value (W/m ² K)	Energy Rating
2630FIX-GO1	1.48	24
2630FIX-GO2	1.54	22
2630FIX-GO3	1.58	21
2630FIX-GO4	1.17	30
2630FIX-GO5	1.20	29
2630FIX-GO6	1.21	28
2630FIX-GO7	1.19	29
2630FIX-GO8	1.22	28
2630FIX-GO9	1.24	27
2630FIX-GO10	0.91	34
2630FIX-GO11	0.93	32
2630FIX-GO12	0.96	31
2630FIX-GO13	0.95	33
2630FIX-GO14	0.98	32
2630FIX-GO15	1.00	30
2630FIX-GO16	1.71	38
2630FIX-GO17	1.76	35
2630FIX-GO18	1.80	33
2630FIX-GO19	1.27	44
2630FIX-GO20	1.29	42
2630FIX-GO21	1.30	41
2630FIX-GO22	1.00	48
2630FIX-GO23	1.03	46
2630FIX-GO24	1.05	44
2630FIX-GO25	1.23	45
2630FIX-GO26	1.25	43
2630FIX-GO27	1.28	41
2630FIX-GO28	1.27	43
2630FIX-GO29	1.29	41
2630FIX-GO30	1.32	40
2630FIX-GO31	1.04	47
2630FIX-GO32	1.07	45
2630FIX-GO33	1.10	43
2630FIX-GO34	1.55	21
2630FIX-GO35	1.48	28
2630FIX-GO36	1.53	26
2630FIX-GO37	1.57	24

Model Code	U-Value (W/m ² K)	Energy Rating
2630FIX-GO38	1.55	24
2630FIX-GO39	1.20	27
2630FIX-GO40	1.13	35
2630FIX-GO41	1.15	34
2630FIX-GO42	1.18	32
2630FIX-GO43	1.17	31
2630FIX-GO44	0.90	35
2630FIX-GO45	0.93	34
2630FIX-GO46	0.96	32
2630FIX-GO47	0.96	32
2630FIX-GO48	1.71	30
2630FIX-GO49	1.27	36
2630FIX-GO50	1.04	42
2630FIX-GO51	1.06	40
2630FIX-GO52	1.08	39
2630FIX-GO53	1.08	38

5600 Series Double Horizontal Sliding Window

Model Code	U-Value (W/m ² K)	Energy Rating
SWC-V56S-DHS-G54-4,035(2)-4,CL-13,Ar-SS	1.54	23
SWC-V56S-DHS-G55-4,035(2)-4,CL-13,Ar-SS-S	1.57	22
SWC-V56S-DHS-G56-4,035(2)-4,CL-13,Ar-SS-S	1.59	21
SWC-V56S-DHS-G57-4,CL-4,035(3)-13,Ar-SS	1.54	27
SWC-V56S-DHS-G58-4,CL-4,035(3)-13,Ar-SS-S	1.57	25
SWC-V56S-DHS-G59-4,CL-4,035(3)-13,Ar-SS-S	1.59	24
SWC-V56S-DHS-G66-4,CL-4,148(3)-13,Ar-SS	1.73	33
SWC-V56S-DHS-G67-4,CL-4,148(3)-13,Ar-SS-S	1.77	31
SWC-V56S-DHS-G68-4,CL-4,148(3)-13,Ar-SS-S	1.79	29
SWC-V56S-DHS-G69-4,035(2)-4,148(4)-13,Ar-SS	1.53	23
SWC-V56S-DHS-G70-4,035(2)-4,148(4)-13,Ar-SS-S	1.56	21
SWC-V56S-DHS-G71-4,035(2)-4,148(4)-13,Ar-SS-S	1.58	20

6490 Series Picture Window

Model Code	U-Value (W/m ² K)	Energy Rating
6490PIC-GO54	1.50	26
6490PIC-GO55	1.55	24
6490PIC-GO56	1.59	23
6490PIC-GO57	1.50	30
6490PIC-GO58	1.55	28
6490PIC-GO59	1.59	26
6490PIC-GO60	1.70	38
6490PIC-GO61	1.75	35
6490PIC-GO62	1.77	33
6490PIC-GO63	1.25	31

Model Code	U-Value (W/m ² K)	Energy Rating
6490PIC-GO64	1.30	29
6490PIC-GO65	1.32	28

6490 Series Horizontal Sliding Window

Model Code	U-Value (W/m ² K)	Energy Rating
6490HS-GO54	1.64	21
6490HS-GO55	1.69	19
6490HS-GO56	1.71	18
6490HS-GO57	1.64	25
6490HS-GO58	1.69	23
6490HS-GO59	1.72	21
6490HS-GO60	1.83	31
6490HS-GO61	1.86	29
6490HS-GO62	1.88	27
6490HS-GO63	1.42	25
6490HS-GO64	1.45	24
6490HS-GO65	1.47	22

6490 Series Vertical Sliding Window

Model Code	U-Value (W/m ² K)	Energy Rating
6490VS-GO54	1.63	21
6490VS-GO55	1.68	19
6490VS-GO56	1.71	18
6490VS-GO57	1.63	25
6490VS-GO58	1.68	23
6490VS-GO59	1.71	21
6490VS-GO60	1.81	31
6490VS-GO61	1.85	29
6490VS-GO62	1.87	27
6490VS-GO63	1.40	25
6490VS-GO64	1.44	24
6490VS-GO65	1.46	23

7000 Opera Series Fixed Window

Model Code	U-Value (W/m ² K)	Energy Rating
OPERA-FIX-CI(4)-Arg(15.8)LowE(4, e=0.148)	1.68	40
OPERA-FIX-CI(4)-Arg(15.85/16"Grids)-LowE(4, e=0.148)	1.71	37
OPERA-FIX-CI(4)-Arg(15.85/8"Grids)-LowE(4, e=0.148)	1.74	35
OPERA-FIX-CI(4)-Arg(15.8)LowE(4, e=0.035)	1.48	31
OPERA-FIX-CI(4)-Arg(15.85/16"Grids)-LowE(4, e=0.035)	1.53	29

Model Code	U-Value (W/m ² K)	Energy Rating
OPERA-FIX-CI(4)-Arg(15.85/8"Grids)-LowE(4, e=0.035)	1.56	28
OPERA-FIX-CI(4)-Arg(15.8)LowE(4, e=0.164)	1.70	40
OPERA-FIX-CI(4)-Arg(15.85/16"Grids)-LowE(4, e=0.164)	1.74	38
OPERA-FIX-CI(4)-Arg(15.85/8"Grids)-LowE(4, e=0.164)	1.76	36
OPERA-FIX-LowE(4, e=0.039)Arg(15.8)-CI(4)	1.49	26
OPERA-FIX-LowE(4, e=0.039)Arg(15.8-5/16"Grids)-CI(4)	1.53	25
OPERA-FIX-LowE(4, e=0.039)Arg(15.8-5/8"Grids)-CI(4)	1.57	24

7000 Opera Series Sliding Door

Model Code	U-Value (W/m ² K)	Energy Rating
OPERA-PD-CI(4)-Arg(15.8)LowE(4, e=0.148)	1.76	36
OPERA-PD-CI(4)-Arg(15.85/16"Grids)-LowE(4, e=0.148)	1.81	33
OPERA-PD-CI(4)-Arg(15.85/8"Grids)-LowE(4, e=0.148)	1.84	31
OPERA-PD-CI(4)-Arg(15.8)LowE(4, e=0.035)	1.58	28
OPERA-PD-CI(4)-Arg(15.85/16"Grids)-LowE(4, e=0.035)	1.63	26
OPERA-PD-CI(4)-Arg(15.85/8"Grids)-LowE(4, e=0.035)	1.66	24
OPERA-PD-CI(4)-Arg(15.8)LowE(4, e=0.164)	1.78	36
OPERA-PD-CI(4)-Arg(15.85/16"Grids)-LowE(4, e=0.164)	1.83	33
OPERA-PD-CI(4)-Arg(15.85/8"Grids)-LowE(4, e=0.164)	1.86	31
OPERA-PD-LowE(4, e=0.039)Arg(15.8)-CI(4)	1.58	24
OPERA-PD-LowE(4, e=0.039)Arg(15.8-5/16"Grids)-CI(4)	1.64	21
OPERA-PD-LowE(4, e=0.039)Arg(15.8-5/8"Grids)-CI(4)	1.67	20

Notes: Windows are not intended for installation in storefronts, non-operable portions of curtain wall, fixed glazing cast into precast concrete panels, greenhouses, skylights or sloped glazing. Test procedures are designed to test the performance of the test specimen only and are not necessarily used to test the performance of the installation, particularly the perimeter sealant joint and anchoring of the assembly.

The materials, products or systems listed herein have been qualified to bear the QAI Listing Mark under the conditions stated with each Listing. Only those products bearing the QAI Listing Mark are considered to be listed by QAI. No warrantee is expressed or implied, and no guarantee is provided that any jurisdictional authority will accept the Listing found herein. The appropriate authorities should be contacted regarding the acceptability of any given Listing. Visit the QAI Online Listing Directory located at www.qai.org for the most up to date version of this Listing and to validate that this QAI Listing is active. Questions regarding this listing may be directed to info@qai.org. Please include the listing number in the request.