

## FIRE DOOR LISTING PROGRAM

**Class:** Fire Door Frames

**Customer:** Upstate Door Inc.  
**Location:** Warsaw, NY

**Listing No.** F428-1  
**Effective Date:** January 16, 2016  
**Last Revised:** No Revisions to Date  
**Expires:** N/A

**Standard(s):** **CAN/ULC S104** *Standard Method for Fire Tests of Door Assemblies*  
**UL10 (b)** *Fire Tests of Doors Assemblies*  
**UL10 (c)** *Fire Tests of Doors Assemblies*  
**NFPA 252** *Standard Methods of Fire Tests of Door Assemblies*

**Label:** Refer to the QAI - FD001 - Fire Door Labeling requirements



**Models:** FIRE DOOR FRAMES:

Frame:	Rating:
FF-90 Frame	90 minute
FF-90 Frame for SOSS® Invisible hinge	90 minute
FF-90 Frame with hollow metal header	90 minute

**Note:** Final acceptance of the product in the intended application is to be determined by the authority having jurisdiction.

Product is to be installed in accordance with the NFPA 80 and manufacturer’s published installation instructions by qualified installing personnel.

The materials, products or systems listed herein have been qualified to bear the QAI Listing Mark under the conditions stated with each Listing. Only those products bearing the QAI Listing Mark are considered to be listed by QAI.

No warrantee is expressed or implied, and no guarantee is provided that any jurisdictional authority will accept the Listing found herein. The appropriate authorities should be contacted regarding the acceptability of any given Listing.

Visit the QAI Online Listing Directory located at [www.qai.org](http://www.qai.org) for the most up to date version of this Listing and to validate that this QAI Listing is active.

Questions regarding this listing may be directed to [info@qai.org](mailto:info@qai.org). Please include the listing number in the request.

\*\*\*