

BUILDING PRODUCTS PROGRAM

Class:	<u>Plastic Piping and Accessories</u>
Customer:	Viega, LLC
Location:	2211 Viega Avenue, McPherson, Kansas 67460
Listing No.	P341-1
Effective Date:	March 20, 2016
Last Revised:	N/A
Expires:	N/A
Website:	www.viega.com
Product(s):	Cross-linked Polyethylene PEX Piping, Fittings and Valves
Standard(s):	ASTM E84 "Standard Test Method for Surface Burning Characteristics of Building Materials".
Models:	ViegaPEX™ (red white, blue, purple) ViegaPEX™ Ultra (red, white, blue, black) Viega PEX Press Fittings and Manifolds (polymer & metallic) Viega PEX Crimp Fittings and Manifolds (PolyAlloy® & metallic) Viega PEX Press Valves Viega PEX Crimp Valves
Marking(s):	All PEX tubing, connectors, angle stop valves, and other accessories (if sufficient space available) shall be permanently marked with the following: <ul style="list-style-type: none"> • Manufacturers name or trademark • Model Name • Standard: ASTM E84 • Flame Spread Rating < 25, Smoke Development Rating < 50 • Nominal Size • QAI Logo with 'us' indicator

The following outlines the performance of Viega PEX pipe determined in accordance with the noted standards.

ASTM E84 – Surface Burning Characteristics

Rating(s):	Limitations	Flame Spread Index	Smoke Developed Index
	2-inch maximum diameter tubing; Supported continuously with 23 gauge Viega PEX Pipe supports. Areas of exposed Viega pipe between PEX Pipe supports is to be encased with approved pipe insulations ¹ . Piping is to be clamped with standard support clamps following Viega installation instructions.	< 25	< 50

Note¹: List of approved pipe insulation providers:

The following list of insulation types (at minimum thickness of ½") are approved for use with ViegaPEX and ViegaPEX Ultra products when installed with Viega PEX fittings and valves of up to maximum 2 inch diameter. The insulation noted must be listed to ASTM C547 by an approved listing agency.

Insulation	Flame Spread Rating (according to ASTM E84)	Smoke Developed Rating (according to ASTM E84)
Johns Manville Micro-Lok	< 25	< 50
Johns Manville Micro-Lok HP		
Owens Corning Fiberglass		

Note: These products are subjected to limitations as specified above and must be installed in accordance with the manufacturers' instructions. Authorities having jurisdiction should be consulted regarding allowable applications. See manufacturer's listings for other standards listed under QAI certification programs.

The materials, products or systems listed herein have been qualified to bear the QAI Listing Mark under the conditions stated with each Listing. Only those products bearing the QAI Listing Mark are considered to be listed by QAI.

No warrantee is expressed or implied, and no guarantee is provided that any jurisdictional authority will accept the Listing found herein. The appropriate authorities should be contacted regarding the acceptability of any given Listing.

Visit the QAI Online Listing Directory located at www.qai.org for the most up to date version of this Listing and to validate that this QAI Listing is active.

Questions regarding this listing may be directed to info@qai.org. Please include the listing number in the request.
