

FIRE DOORS LISTING PROGRAM

Customer: Visser Manufacturing Ltd.
 Class: Fire Doors
 Location: Ottawa, ON
 Website: vissermfg.ca

Listing No. F449-1
 Project No. F449-1 Edition 1

Effective Date: January 1, 2018
 Last Revised Date: January 1, 2018

Standards: UL 10(b) *Fire Tests of Doors Assemblies.*
 UL 10(c) *Fire Tests of Doors Assemblies.*
 NFPA 252 *Standard Methods of Fire Tests of Door Assemblies.*

Product: 20 min Rated 'Category A' Positive Pressure Fire Doors

Labels: See [FD001 - Fire Door Labeling requirements](#)

Models: **20-MINUTE FLUSH DUTCH DOORS:**

Minimum 1-11/16" Thickness

Swing Type:	Maximum Dimensions		Panel Type:	Latching:
	Width:	Length:		
Single Swing	4'0" (1219 mm)	8'0" (2438 mm)	Flush	Single Point (Mortised or Cylindrical)

Notes:
 Maximum Leaf Height: 4'8"
 Maximum Total Height: 8'0"



Limitations: (Review Machining Report for further detail)

- Cylindrical Latches (Listed and labeled)
- Mortise Latches (Listed and labeled)
- Card Locks (Listed and labeled)
 - Miwa AL4HB or equivalent positive pressure rated card locks
 - Miwa ALV2 Series card lock approved with a maximum mortise cut-out of 1" x 4-3/8" x 6-7/8"
- Deadlock (Listed and labeled)
- Surface mounted and concealed overhead door closer (Listed and labeled)
- Floor door closer (Listed and labeled)
- Light Kit (Listed and labeled)
 - Listed Steel Lite Kit – max. 1296 sq. in. (max dimension of 54")
 - Glazing is allowed only in the top shelf of the dutch door
- Electrical Raceway
 - Maximum 3/8" diameter raceway.
- Viewers (Listed and labeled)
 - Two listed viewers up to 1" diameter each. Located a minimum of 5-1/2" apart or from edge.
- Protection Plates
 - Brass, bronze, steel, aluminum, PVC or decorative laminate protection plates. Maximum 1/8" thickness up to 48" height.

Notes: *Refer to QAI evaluation report F449-1 and the applicable test reports for test assembly configurations used for fire endurance testing.*

Refer to the [QAI FD002 - Fire Door Guidelines for general guidelines of fire door assemblies](#)

Final acceptance of the product in the intended application is to be determined by the authority having jurisdiction (AHJ).

Product is to be installed in accordance with the manufacturer's published installation instructions by qualified installing personnel.

The materials, products or systems listed herein have been qualified to bear the QAI Listing Mark under the conditions stated with each Listing. Only those products bearing the QAI Listing Mark are considered to be listed by QAI. No warranty is expressed or implied, and no guarantee is provided that any jurisdictional authority will accept the Listing found herein. The appropriate authorities should be contacted regarding the acceptability of any given Listing. Visit the QAI Online Listing Directory located at www.qai.org for the most up to date version of this Listing and to validate that this QAI Listing is active. Questions regarding this listing may be directed to info@qai.org. Please include the listing number in the request.
