

WINDOWS & DOORS LISTING PROGRAM

Customer: West Coast Designed Windows Ltd.
Class: Fenestration Products – Energy Performance
Location: Delta, British Columbia
Website: www.westcoastwindows.ca

Listing No. W484-1
Project No. W484-1 ED6
Effective Date: April 19, 2010
Last Revised Date: May 27, 2021
Expires: N/A

Standards: CSA A440.2-14 “Fenestration Energy Performance”

Product: Vinyl Windows

Markings: Products are marked with the following content in a permanent manner where it is readily visible after installation:

- a) Manufacturer’s name, Trademark or other recognized symbol or identification.
- b) QAI file Number: W484
- c) QAI logo shown here:



- d) “Evaluation for energy performance in accordance with CSA A440.2” / “Évalué pour la performance d’énergie en accord à la norme CSA A440.2”

Models / Ratings:

Casement Series Classic Plus Casement Window

Model Code	U-Value (W/m ² K)	Energy Rating
WCW-CPCA-4,366(2)-4,180(4)-4,CL-11AR90S1	1.00	27
WCW-CPCA-4,366(2)-4,CL-4,CL-11AR90S1	1.17	24
WCW-CPCA-4,366(2)-4,180(4)-4,i89(6)-11AR90S1	0.93	28
WCW-CPCA-4,366(2)-4,CL-6,CLLM-11AR90S1	0.99	27
WCW-CPCA-4,366(2)-4,180(4)-4,CL-11AR90S1-G<1	1.00	26
WCW-CPCA-4,366(2)-4,CL-4,CL-11AR90S1-G<1	1.17	23

Model Code	U-Value (W/m ² K)	Energy Rating
WCW-CPCA-4,366(2)-4,180(4)-4,i89(6)-11AR90S1-G<1	0.93	28
WCW-CPCA-4,366(2)-4,CL-6,CLLM-11AR90S1-G<1	0.99	26
WCW-CPCA-4,366(2)-4,180(4)-4,CL-11AR90S1-G≥1	1.00	25
WCW-CPCA-4,366(2)-4,CL-4,CL-11AR90S1-G≥1	1.17	22
WCW-CPCA-4,366(2)-4,180(4)-4,i89(6)-11AR90S1-G≥1	0.93	27
WCW-CPCA-4,366(2)-4,CL-6,CLLM-11AR90S1-G≥1	0.99	26

Casement Series Classic Plus Awning Window

Model Code	U-Value (W/m ² K)	Energy Rating
WCW-CPAW-4,366(2)-4,180(4)-4,CL-11AR90S1	1.00	27
WCW-CPAW-4,366(2)-4,CL-4,CL-11AR90S1	1.18	24
WCW-CPAW-4,366(2)-4,180(4)-4,i89(6)-11AR90S1	0.94	28
WCW-CPAW-4,366(2)-4,CL-6,CLLM-11AR90S1	1.00	27
WCW-CPAW-4,366(2)-4,180(4)-4,CL-11AR90S1-G<1	1.00	26
WCW-CPAW-4,366(2)-4,CL-4,CL-11AR90S1-G<1	1.18	23
WCW-CPAW-4,366(2)-4,180(4)-4,i89(6)-11AR90S1-G<1	0.94	28
WCW-CPAW-4,366(2)-4,CL-6,CLLM-11AR90S1-G<1	1.00	26
WCW-CPAW-4,366(2)-4,180(4)-4,CL-11AR90S1-G≥1	1.00	26
WCW-CPAW-4,366(2)-4,CL-4,CL-11AR90S1-G≥1	1.18	22
WCW-CPAW-4,366(2)-4,180(4)-4,i89(6)-11AR90S1-G≥1	0.94	27
WCW-CPAW-4,366(2)-4,CL-6,CLLM-11AR90S1-G≥1	1.00	26

Casement Series Classic Plus Fixed Casement Window

Model Code	U-Value (W/m ² K)	Energy Rating
WCW-CPFC-4,366(2)-4,180(4)-4,CL-11AR90S1	0.92	31
WCW-CPFC-4,366(2)-4,CL-4,CL-11AR90S1	1.13	26
WCW-CPFC-4,366(2)-4,180(4)-4,i89(6)-11AR90S1	0.84	32
WCW-CPFC-4,366(2)-4,CL-6,CLLM-11AR90S1	0.92	31
WCW-CPFC-4,366(2)-4,180(4)-4,CL-11AR90S1-G<1	0.92	20
WCW-CPFC-4,366(2)-4,CL-4,CL-11AR90S1-G<1	1.13	16
WCW-CPFC-4,366(2)-4,180(4)-4,i89(6)-11AR90S1-G<1	0.84	22
WCW-CPFC-4,366(2)-4,CL-6,CLLM-11AR90S1-G<1	0.92	20
WCW-CPFC-4,366(2)-4,180(4)-4,CL-11AR90S1-G≥1	0.92	29
WCW-CPFC-4,366(2)-4,CL-4,CL-11AR90S1-G≥1	1.13	24
WCW-CPFC-4,366(2)-4,180(4)-4,i89(6)-11AR90S1-G≥1	0.84	30
WCW-CPFC-4,366(2)-4,CL-6,CLLM-11AR90S1-G≥1	0.92	29

Vista 1000 Series Picture Window

Model Code	U-Value (W/m ² K)	Energy Rating
WCW-V1000-PC-3,272(2)-3,CL-14AR90ST	1.50	28
WCW-V1000-PC-3,366(2)-3,CL-14AR90ST	1.45	22
WCW-V1000-PC-3,366(2)-3,i89(4)-14AR90ST	1.20	28
WCW-V1000-PC-4,366(2)-4,CL-13AR90ST	1.44	22
WCW-V1000-PC-4,272(2)-4,CL-13AR90ST	1.48	28
WCW-V1000-PC-4,366(2)-4,i89(4)-13AR90ST	1.19	28
WCW-V1000-PC-5,272(2)-5,CL-11AR90ST	1.48	28
WCW-V1000-PC-5,366(2)-5,CL-11AR90ST	1.43	23
WCW-V1000-PC-5,366(2)-5,i89(4)-11AR90ST	1.20	28
WCW-V1000-PC-3,272(2)-6,CLLM-11AR90ST	1.47	29
WCW-V1000-PC-3,366(2)-6,CLLM-11AR90ST	1.42	23
WCW-V1000-PC-3,366(2)-6,i89L(4)-11AR90ST	1.19	27
WCW-V1000-PC-3,272(2)-3,i89(4)-14AR90ST	1.23	34
WCW-V1000-PC-4,272(2)-4,i89(4)-13AR90ST	1.22	33
WCW-V1000-PC-5,272(2)-5,i89(4)-11AR90ST	1.23	33

Vista 1000 Series Single Sliding Window

Model Code	U-Value (W/m ² K)	Energy Rating
WCW-V1000-SS-3,272(2)-3,CL-14AR90ST	1.65	N/A
WCW-V1000-SS-3,366(2)-3,CL-14AR90ST	1.61	N/A
WCW-V1000-SS-3,366(2)-3,i89(4)-14AR90ST	1.39	N/A
WCW-V1000-SS-4,366(2)-4,CL-13AR90ST	1.60	N/A
WCW-V1000-SS-4,272(2)-4,CL-13AR90ST	1.64	N/A
WCW-V1000-SS-4,366(2)-4,i89(4)-13AR90ST	1.38	N/A
WCW-V1000-SS-3,272(2)-6,CLLM-11AR90ST	1.63	N/A
WCW-V1000-SS-3,366(2)-6,CLLM-11AR90ST	1.59	N/A
WCW-V1000-SS-3,366(2)-6,i89L(4)-11AR90ST	1.39	N/A
WCW-V1000-SS-3,272(2)-3,i89(4)-14AR90ST	1.42	N/A
WCW-V1000-SS-4,272(2)-4,i89(4)-13AR90ST	1.41	N/A

Vista 1000 Series Single Hung Window

Model Code	U-Value (W/m ² K)	Energy Rating
WCW-V1000-SH-3,272(2)-3,CL-14AR90ST	1.64	N/A
WCW-V1000-SH-3,366(2)-3,CL-14AR90ST	1.60	N/A
WCW-V1000-SH-3,366(2)-3,i89(4)-14AR90ST	1.37	N/A
WCW-V1000-SH-4,366(2)-4,CL-13AR90ST	1.59	N/A
WCW-V1000-SH-4,272(2)-4,CL-13AR90ST	1.63	N/A
WCW-V1000-SH-4,366(2)-4,i89(4)-13AR90ST	1.36	N/A
WCW-V1000-SH-3,272(2)-6,CLLM-11AR90ST	1.62	N/A
WCW-V1000-SH-3,366(2)-6,CLLM-11AR90ST	1.58	N/A
WCW-V1000-SH-3,366(2)-6,i89L(4)-11AR90ST	1.38	N/A
WCW-V1000-SH-3,272(2)-3,i89(4)-14AR90ST	1.40	N/A
WCW-V1000-SH-4,272(2)-4,i89(4)-13AR90ST	1.39	N/A

Classic 3000 Series Picture Window

Model Code	U-Value (W/m ² K)	Energy Rating
WCW-C3000-PC-3,272(2)-3,CL-14AR90ST	1.49	N/A
WCW-C3000-PC-3,366(2)-3,CL-14AR90ST	1.45	N/A
WCW-C3000-PC-3,366(2)-3,i89(4)-14AR90ST	1.22	N/A
WCW-C3000-PC-3,366(2)-3,i89(4)-14AR90ST-G<1	1.22	N/A
WCW-C3000-PC-4,366(2)-4,CL-13AR90ST	1.44	N/A
WCW-C3000-PC-4,272(2)-4,CL-13AR90ST	1.48	N/A
WCW-C3000-PC-4,366(2)-4,i89(4)-13AR90ST	1.22	N/A
WCW-C3000-PC-4,366(2)-4,i89(4)-13AR90ST-G<1	1.22	N/A
WCW-C3000-PC-5,272(2)-5,CL-11AR90ST	1.48	N/A
WCW-C3000-PC-5,366(2)-5,CL-11AR90ST	1.44	N/A
WCW-C3000-PC-5,366(2)-5,i89(4)-11AR90ST	1.23	N/A
WCW-C3000-PC-3,272(2)-6,CLLM-11AR90ST	1.47	N/A
WCW-C3000-PC-3,366(2)-6,CLLM-11AR90ST	1.43	N/A
WCW-C3000-PC-3,366(2)-6,i89L(4)-11AR90ST	1.22	N/A
WCW-C3000-PC-3,272(2)-3,i89(4)-14AR90ST	1.25	N/A
WCW-C3000-PC-4,272(2)-4,i89(4)-13AR90ST	1.25	N/A
WCW-C3000-PC-5,272(2)-5,i89(4)-11AR90ST	1.26	N/A

Classic 3000 Series Casement Window

Model Code	U-Value (W/m ² K)	Energy Rating
WCW-C3000-CA-3,272(2)-3,CL-14AR90ST	1.48	N/A
WCW-C3000-CA-3,366(2)-3,CL-14AR90ST	1.45	N/A
WCW-C3000-CA-3,366(2)-3,i89(4)-14AR90ST	1.27	N/A
WCW-C3000-CA-3,366(2)-3,i89(4)-14AR90ST-G<1	1.27	N/A
WCW-C3000-CA-4,366(2)-4,CL-13AR90ST	1.44	N/A
WCW-C3000-CA-4,272(2)-4,CL-13AR90ST	1.47	N/A
WCW-C3000-CA-4,366(2)-4,i89(4)-13AR90ST	1.27	N/A
WCW-C3000-CA-4,366(2)-4,i89(4)-13AR90ST-G<1	1.27	N/A
WCW-C3000-CA-3,272(2)-6,CLLM-11AR90ST	1.47	N/A
WCW-C3000-CA-3,366(2)-6,CLLM-11AR90ST	1.43	N/A
WCW-C3000-CA-3,366(2)-6,i89L(4)-11AR90ST	1.26	N/A
WCW-C3000-CA-3,272(2)-3,i89(4)-14AR90ST	1.29	N/A
WCW-C3000-CA-4,272(2)-4,i89(4)-13AR90ST	1.29	N/A

Classic 3000 Series Awning Window

Model Code	U-Value (W/m ² K)	Energy Rating
WCW-C3000-AW-3,272(2)-3,CL-14AR90ST	1.49	N/A
WCW-C3000-AW-3,366(2)-3,CL-14AR90ST	1.46	N/A
WCW-C3000-AW-3,366(2)-3,i89(4)-14AR90ST	1.30	N/A
WCW-C3000-AW-3,366(2)-3,i89(4)-14AR90ST-G<1	1.30	N/A
WCW-C3000-AW-4,366(2)-4,CL-13AR90ST	1.46	N/A
WCW-C3000-AW-4,272(2)-4,CL-13AR90ST	1.49	N/A
WCW-C3000-AW-4,366(2)-4,i89(4)-13AR90ST	1.30	N/A
WCW-C3000-AW-4,366(2)-4,i89(4)-13AR90ST-G<1	1.30	N/A
WCW-C3000-AW-3,272(2)-6,CLLM-11AR90ST	1.48	N/A
WCW-C3000-AW-3,366(2)-6,CLLM-11AR90ST	1.45	N/A
WCW-C3000-AW-3,366(2)-6,i89L(4)-11AR90ST	1.29	N/A
WCW-C3000-AW-3,272(2)-3,i89(4)-14AR90ST	1.32	N/A
WCW-C3000-AW-4,272(2)-4,i89(4)-13AR90ST	1.32	N/A

Classic 3000 Series Balanced Sash (Fixed Casement) Window

Model Code	U-Value (W/m ² K)	Energy Rating
WCW-C3000-FC-3,272(2)-3,CL-14AR90ST	1.47	N/A
WCW-C3000-FC-3,366(2)-3,CL-14AR90ST	1.43	N/A

Model Code	U-Value (W/m ² K)	Energy Rating
WCW-C3000-FC-3,366(2)-3,i89(4)-14AR90ST	1.21	N/A
WCW-C3000-FC-3,366(2)-3,i89(4)-14AR90ST-G<1	1.21	N/A
WCW-C3000-FC-4,366(2)-4,CL-13AR90ST	1.42	N/A
WCW-C3000-FC-4,272(2)-4,CL-13AR90ST	1.45	N/A
WCW-C3000-FC-4,366(2)-4,i89(4)-13AR90ST	1.20	N/A
WCW-C3000-FC-4,366(2)-4,i89(4)-13AR90ST-G<1	1.20	N/A
WCW-C3000-FC-5,272(2)-5,CL-11AR90ST	1.45	N/A
WCW-C3000-FC-5,366(2)-5,CL-11AR90ST	1.42	N/A
WCW-C3000-FC-5,366(2)-5,i89(4)-11AR90ST	1.22	N/A
WCW-C3000-FC-3,272(2)-6,CLLM-11AR90ST	1.44	N/A
WCW-C3000-FC-3,366(2)-6,CLLM-11AR90ST	1.40	N/A
WCW-C3000-FC-3,366(2)-6,i89L(4)-11AR90ST	1.20	N/A
WCW-C3000-FC-3,272(2)-3,i89(4)-14AR90ST	1.24	N/A
WCW-C3000-FC-4,272(2)-4,i89(4)-13AR90ST	1.23	N/A
WCW-C3000-FC-5,272(2)-5,i89(4)-11AR90ST	1.24	N/A

Notes: Windows and doors are not intended for installation in storefronts, non-operable portions of curtain wall, fixed glazing cast into precast concrete panels, greenhouses, skylights or sloped glazing. Test procedures are designed to test the performance of the test specimen only and are not necessarily used to test the performance of the installation, particularly the perimeter sealant joint and anchoring of the assembly.

The materials, products or systems listed herein have been qualified to bear the QAI Listing Mark under the conditions stated with each Listing. Only those products bearing the QAI Listing Mark are considered to be listed by QAI. No warranty is expressed or implied, and no guarantee is provided that any jurisdictional authority will accept the Listing found herein. The appropriate authorities should be contacted regarding the acceptability of any given Listing. Visit the QAI Online Listing Directory located at www.qai.org for the most up to date version of this Listing and to validate that this QAI Listing is active. Questions regarding this listing may be directed to info@qai.org. Please include the listing number in the request.