Directory of Listed Products

🗟 Go to Directory Page

뮸

Class:	Fire Resistant Air Duct Insulation						
Customer:	CL4 Inc.						
Location:	London, ON						
Listing No.: Effective Date: Last Revised:	F405-1 January 6, 2012 January 6, 2012						
Expires:	N/A						
Standards:	CAN/ULC S102 "Method of Test for Surface Burning Characteristics of Building Materials and Assemblies"						
Product:	CL4FIRE [™] Foil Encapsulated Ductwrap Insulation						
Markings:	 Each container of the subject product, as delivered to the customer, is suitably marked using Permanent label stock with permanent adhesive with the following: 1. QAI logo with 'c' and 'us' indicator 2. Manufacturers name or trademark 3. City and state of manufacture 4. Model/Listing number or product description 5. QAI file number (F405) 6. Traceability Information: date of manufacture or serial number 7. Standards: See above 8. Applicable Ratings: See below 						
Models:	Product:	Model #:	# of Layers:	Thickness:	Density:	Flame Spread Index (FSI):	Smoke Developed Index (SDI)
	Foil Encapsulated	CL4FIRE™ 'Blue' Label	1	1-1/2″	8 pcf	10	10

Note:

Duct Wrap

Insulation

CL4FIRE™

'Red' Label

Refer to QAI evaluation report F405-1 and the applicable test reports for test assembly configurations used for fire endurance testing. Final acceptance of the product in the intended application is to be determined by the authority having jurisdiction (AHJ).

1-1/2"

6 pcf

10

10

The materials, products or systems listed in this directory have been qualified to bear the QAI Listing Mark under the conditions stated with each Listing. Only those products bearing the QAI Listing Mark are considered to be listed by QAI.

1

No warrantee is expressed or implied, and no guarantee is provided that any jurisdictional authority will accept the Listing found herein. The appropriate authorities should be contacted regarding the acceptability of any given Listing.

Questions regarding this listing may be directed to info@qai.org. Please include the listing number in the request.

Copyright QAI Laboratories, 2011