

FENESTRATION LISTING PROGRAM

Customer: Window Pro Inc.
Class: Fenestration Products – Energy Performance
Location: Etobicoke, ON
Website: <https://windowprocanada.com/>
Listing No. W510
Report No. W510-1 ED6
Effective Date: March 14, 2014
Last Revised Date: February 6, 2020
Expires: <N/A>
Standards: CSA A440.2 “Fenestration Energy Performance”
Product: Vinyl Windows
Markings: <Products are marked in a permanent manner where it is readily visible after installation with the following:
a) Manufacturer’s name or trademark
b) QAI file Number: W510
c) Evaluation for energy performance only to CSA A440.2.
d) Évaluation pour le performance d’énergie seulement a CSA A440.2.
e) QAI logo shown here:



Models / Ratings: See Below



Fenestration Product Model	Glazing Option Model Code	U-Value (W/m ² *K)	Energy Rating
L Series Casement Window	CAS_IS_3mm_ClrCard-Arg90-Card180#3-Arg90-ClrCard	1.24	36
L Series Casement Window	CAS_IS_3mm_ClrCard-Arg90-Card180#3-Arg90-ClrCard_Grids<1"	1.24	34
L Series Casement Window	CAS_IS_3mm_Card180#2-Arg90-ClrCard-Arg90-Card180#5	1.02	38
L Series Casement Window	CAS_IS_3mm_Card180#2-Arg90-ClrCard-Arg90-Card180#5_Grids<1"	1.02	36
L Series Casement Window	CAS_IS_4mm_Card180#2-Arg90-ClrCard-Arg90-Card180#5	1.07	36
L Series Casement Window	CAS_IS_4mm_Card180#2-Arg90-ClrCard-Arg90-Card180#5_Penc	1.07	35
L Series Casement Window	CAS_IS_4mm_Card180#2-Arg90-ClrCard-Arg90-Card180#5_Rect3/8	1.08	34
L Series Casement Window	CAS_IS_4mm_Card180#2-Arg90-ClrCard-Arg90-Card180#5_Rect5/8	1.08	34
L Series Casement Window	CAS_IS_3mm_Card180#2-Arg90-Card180#4-Arg90-i89#6	0.95	39
L Series Casement Window	CAS_IS_3mm_Card180#2-Arg90-Card180#4-Arg90-i89#6_Grids<1"	0.95	39
L Series Casement Window	CAS_IS_4mm_Card180#2-Arg90-Card180#4-Arg90-i89#6	0.99	37
L Series Casement Window	CAS_IS_4mm_Card180#2-Arg90-Card180#4-Arg90-i89#6_Penc	0.99	35
L Series Casement Window	CAS_IS_4mm_Card180#2-Arg90-Card180#4-Arg90-i89#6_Rect3/8	1.00	35
L Series Casement Window	CAS_IS_4mm_Card180#2-Arg90-Card180#4-Arg90-i89#6_Rect5/8	1.00	35

Fenestration Product Model	Glazing Option Model Code	U-Value (W/m ² *K)	Energy Rating
L Series Awning Window	AWN_ED_3mm_ClrCard-Arg90-Card180#3-Arg90-ClrCard	1.22	35
L Series Awning Window	AWN_ED_3mm_ClrCard-Arg90-Card180#3-Arg90-ClrCard_Grids<1"	1.22	34
L Series Awning Window	AWN_ED_3mm_Card180#2-Arg90-ClrCard-Arg90-Card180#5	1.01	38
L Series Awning Window	AWN_ED_3mm_Card180#2-Arg90-ClrCard-Arg90-Card180#5_Grids<1"	1.01	36
L Series Awning Window	AWN_ED_4mm_Card180#2-Arg90-ClrCard-Arg90-Card180#5	1.04	36
L Series Awning Window	AWN_ED_4mm_Card180#2-Arg90-ClrCard-Arg90-Card180#5_Penc	1.04	35
L Series Awning Window	AWN_ED_4mm_Card180#2-Arg90-ClrCard-Arg90-Card180#5_Rect3/8	1.04	35
L Series Awning Window	AWN_ED_4mm_Card180#2-Arg90-ClrCard-Arg90-Card180#5_Rect5/8	1.04	35
L Series Awning Window	AWN_ED_3mm_ClrCard-Arg90-D89#3	1.41	35
L Series Awning Window	AWN_ED_3mm_ClrCard-Arg90-D89#3_Grids<1"	1.41	32



Fenestration Product Model	Glazing Option Model Code	U-Value (W/m ² *K)	Energy Rating
L Series Low Fixed Frame Window	LF_ED_3MM_CLRCARD-ARG90-CARD180#3	1.56	40
L Series Low Fixed Frame Window	LF_IS_4mm_ClrCard-Arg90-Card180#3-Arg90-ClrCard_Penc	1.20	45
L Series Low Fixed Frame Window	LF_IS_4mm_ClrCard-Arg90-Card180#3 Arg90-ClrCard Rect5/8	1.20	42
L Series Low Fixed Frame Window	LF_ED_3MM_CLRCARD-ARG90-CARD180#3-ARG90-CLRCARD	0.91	48
L Series Low Fixed Frame Window	LF_ED_3MM_CLRCARD-ARG90-CARD180#3-ARG90-CLRCARD_GRIDS<1	0.91	45
L Series Low Fixed Frame Window	LF_ED_3MM_180#2-ARG90-CLRCARD-ARG90-CARD180#5	0.95	46
L Series Low Fixed Frame Window	LF_ED_3MM_180#2-ARG90-CLRCARD-ARG90-CARD180#5_GRIDS<1	0.95	43
L Series Low Fixed Frame Window	LF_ED_4MM_180#2-ARG90-CLRCARD-ARG90-CARD180#5	0.96	43
L Series Low Fixed Frame Window	LF_ED_4MM_180#2-ARG90-CLRCARD-ARG90-CARD180#5_PENC	0.96	43

Fenestration Product Model	Glazing Option Model Code	U-Value (W/m ² *K)	Energy Rating
L Series High Fixed Frame Window	HF_ED_3MM_CLRCARD-ARG90-CARD180#3-ARG90-CLRCARD	1.20	41
L Series High Fixed Frame Window	HF_ED_3MM_CLRCARD-ARG90-CARD180#3-ARG90-CLRCARD_GRIDS<1	1.20	39
L Series High Fixed Frame Window	HF_ED_3MM_180#2-ARG90-CLRCARD-ARG90-CARD180#5	0.94	44
L Series High Fixed Frame Window	HF_ED_3MM_180#2-ARG90-CLRCARD-ARG90-CARD180#5_GRIDS<1	0.94	42
L Series High Fixed Frame Window	HF_ED_4MM_180#2-ARG90-CLRCARD-ARG90-CARD180#5	0.97	43
L Series High Fixed Frame Window	HF_ED_4MM_180#2-ARG90-CLRCARD-ARG90-CARD180#5_PENC	0.97	40
L Series High Fixed Frame Window	HF_ED_4MM_180#2-ARG90-CLRCARD-ARG90-CARD180#5_RECT3/8	0.99	40
L Series High Fixed Frame Window	HF_ED_4MM_180#2-ARG90-CLRCARD-ARG90-CARD180#5_RECT5/8	0.99	40



Fenestration Product Model	Glazing Option Model Code	U-Value (W/m ² *K)	Energy Rating
L Series Single Slider Lift Out Window	SSLO_ED_3MM_CARD180#2-ARG90-i89#4	1.42	35
L Series Single Slider Lift Out Window	SSLO_ED_3MM_CARD180#2-ARG90-i89#4_GRIDS<1	1.42	32
L Series Single Slider Lift Out Window	SSLO_ED_4MM_CARD180#2-ARG90-i89#4	1.41	34
L Series Single Slider Lift Out Window	SSLO_ED_4MM_CARD180#2-ARG90-i89#4_GRIDS<1	1.41	31

Fenestration Product Model	Glazing Option Model Code	U-Value (W/m ² *K)	Energy Rating
L Series Single Slider Tilt Window	SST_ED_3MM_CARD180#2-ARG90-i89#4	1.43	35
L Series Single Slider Tilt Window	SST_ED_3MM_CARD180#2-ARG90-i89#4_GRIDS<1	1.43	32
L Series Single Slider Tilt Window	SST_ED_4MM_CARD180#2-ARG90-i89#4	1.41	35
L Series Single Slider Tilt Window	SST_ED_4MM_CARD180#2-ARG90-i89#4_GRIDS<1	1.41	32

Fenestration Product Model	Glazing Option Model Code	U-Value (W/m ² *K)	Energy Rating
L Series Single Hung Tilt Window	SHT_ED_3MM_CARD180#2-ARG90-i89#4	1.41	36
L Series Single Slider Tilt Window	SHT_ED_3MM_CARD180#2-ARG90-i89#4_GRIDS<1	1.41	33
L Series Single Slider Tilt Window	SHT_ED_4MM_CARD180#2-ARG90-i89#4	1.40	36
L Series Single Slider Tilt Window	SHT_ED_4MM_CARD180#2-ARG90-i89#4_GRIDS<1	1.40	33

Fenestration Product Model	Glazing Option Model Code	U-Value (W/m ² *K)	Energy Rating
L Series Double Hung Tilt Window	DHT_ED_3MM_CARD180#2-ARG90-i89#4	1.42	35
L Series Double Hung Tilt Window	DST_ED_3MM_CARD180#2-ARG90-i89#4_GRIDS<1	1.42	32
L Series Double Hung Tilt Window	DST_ED_4MM_CARD180#2-ARG90-i89#4	1.41	35
L Series Double Hung Tilt Window	DST_ED_4MM_CARD180#2-ARG90-i89#4_GRIDS<1	1.41	32



Fenestration Product Model	Glazing Option Model Code	U-Value (W/m ² *K)	Energy Rating
L Series Double Slider Tilt Window	DST_ED_3MM_CARD180#2-ARG90-i89#4	1.42	33
L Series Double Slider Tilt Window	DST_ED_3MM_CARD180#2-ARG90-i89#4_GRIDS<1	1.42	31
L Series Double Slider Tilt Window	DST_ED_4MM_CARD180#2-ARG90-i89#4	1.40	33
L Series Double Slider Tilt Window	DST_ED_4MM_CARD180#2-ARG90-i89#4_GRIDS<1	1.40	30
L Series Double Slider Tilt Window	DST_ED_3mm_ClrCard-Arg90-D89#3	1.50	35
L Series Double Slider Tilt Window	DST_ED_3mm_ClrCard-Arg90-D89#3_Grids<1"	1.50	32
L Series Double Slider Tilt Window	DST_ED_3mm_ClrCard-Arg90-ClrCard-Arg90-CARD180#5	1.58	29

Fenestration Product Model	Glazing Option Model Code	U-Value (W/m ² *K)	Energy Rating
L Series Double Slider Lift Out Window	DSLO_ED_3MM_CARD180#2-ARG90-i89#4	1.42	34
L Series Double Slider Lift Out Window	DSLO_ED_3MM_CARD180#2-ARG90-i89#4_GRIDS<1	1.42	31
L Series Double Slider Lift Out Window	DSLO_ED_4MM_CARD180#2-ARG90-i89#4	1.40	34
L Series Double Slider Lift Out Window	DSLO_ED_4MM_CARD180#2-ARG90-i89#4_GRIDS<1	1.40	31

Fenestration Product Model	Glazing Option Model Code	U-Value (W/m ² *K)	Energy Rating
L Series End Vent (Triple) Slider Tilt Window	EVS_ED_3MM_CARD180#2-ARG90-i89#4	1.43	35
L Series End Vent (Triple) Slider Tilt Window	EVS_ED_3MM_CARD180#2-ARG90-i89#4_GRIDS<1	1.43	32
L Series End Vent (Triple) Slider Tilt Window	EVS_ED_4MM_CARD180#2-ARG90-i89#4	1.41	35
L Series End Vent (Triple) Slider Tilt Window	EVS_ED_4MM_CARD180#2-ARG90-i89#4_GRIDS<1	1.41	32

Notes: Windows are not intended for installation in storefronts, non-operable portions of curtain wall, fixed glazing cast into precast concrete panels, greenhouses, skylights or sloped glazing. Test procedures are designed to test the performance of the test specimen only and are not necessarily used to test the performance of the installation, particularly the perimeter sealant joint and anchoring of the assembly.



LABORATORIES

CERTIFICATION TESTING INSPECTION

VANCOUVER, BC:	877.461.8378 ph.	604.527.8368 fx.
LOS ANGELES, CA:	909.483.0250 ph.	909.483.0336 fx.
WASHINGTON, DC:	540.636.9445 ph.	540.636.9414 fx.
TULSA, OK:	918.437.8333 ph.	918.437.8487 fx.
TORONTO, ON:	905.605.5444 ph.	
MIAMI, FL:	305.885.3328 ph.	
WEBSITE:	WWW.QAI.ORG	

The materials, products or systems listed herein have been qualified to bear the QAI Listing Mark under the conditions stated with each Listing. Only those products bearing the QAI Listing Mark are considered to be listed by QAI. No warrantee is expressed or implied, and no guarantee is provided that any jurisdictional authority will accept the Listing found herein. The appropriate authorities should be contacted regarding the acceptability of any given Listing. Visit the QAI Online Listing Directory located at www.qai.org for the most up to date version of this Listing and to validate that this QAI Listing is active. Questions regarding this listing may be directed to info@qai.org. Please include the listing number in the request.
