



## **BUILDING PRODUCT LISTING PROGRAM**

Customer: Duradek Canada Ltd.  
Class: Polyvinyl-Chloride Roofing  
Location: Surrey, BC Canada  
Website: [www.duradek.com](http://www.duradek.com)

Listing No. B1023-1  
Project No. B1023-1 Edition 4

Effective Date: August 12, 2011  
Last Revised Date: July 8, 2021  
Expires: N/A

Standards: ASTM D4434 "Standard Specification for Poly(vinyl Chloride) sheet Roofing"  
CAN/ULC S107 "Methods of Fire Tests of Roof Coverings"  
ANSI/SPRI ES-1 "Wind Design Standard for Edge Systems Used with Low Slope Roofing Systems"  
CGSB 37-GP-52M "Roofing and Waterproofing Membrane, Sheet Applied, Elastomeric" (for impact resistance only)  
ANSI/FM 4474 "Evaluating the Simulated Wind Uplift Resistance of Roof Assemblies Using Static Positive and/or Negative Differential Pressures"

Product: Duradek Ultra, Tiledek, and Okanagan V2V - Polyvinyl-Chloride (PVC) Roofing and Walking Deck Membrane

Markings: Each roll of Duradek Ultra, Tiledek, and Okanagan V2V is marked with a permanent label containing the following information:

- Manufacturers name or recognized trademark (Duradek)
- Product name or product number
- Batch Number for traceability
- QAI logo with 'c' and 'us' indicators
- QAI file number: B1023
- QAI logo shown here:





Models / Ratings:

Model	Nominal thickness	Surface	Roll Width(s)
Ultra	1.5 mm (60 mils)	Embossed	1.83 m (72 inches)
Okanagan V2V	1.5 mm (60 mils)	Embossed	1.83 m (72 inches)
Tiledek	1.5 mm (60 mils)	Adhered non-woven polyester fabric finish	1.83 m (72 inches)

Results:

Standard	Details	Rating
ASTM D4434	Nominally 1.5 mm (0.060 inch) thick	Type II
ANSI/SPRI ES-1	57 mm x 83 mm (2-1/4" x 3-1/4") PVC Metal Roof Edge Flashing system	Maximum test pressure of 14.6 kPa (305 psf) (factor of safety of 2)
CGSB 37-GP-52M	Impact Resistance Only	Pass
CAN/ULC S107	See CAN/ULC S107: Decking Assembly Details	See CAN/ULC S107: Decking Assembly Details

**CAN/ULC S107: Decking Assembly Details**

Rating:	Class A
Deck Slope:	1/4 : 12
Deck:	Non-combustible sheathing defined and installed in accordance with the applicable code.
Membrane:	Duradek Ultra or Okanagan V2V 1.5 mm (60 mils) adhered to the non-combustible substrate with Duradek D811 (solvent-based) or D763 (water-based) adhesive applied per Duradek installation instructions.

Rating:	Class A
Deck Slope:	1/4 : 12
Deck:	Non-combustible sheathing defined and installed in accordance with the applicable code.
Membrane:	Duradek Tiledek 1.5 mm (60 mils) adhered to the non-combustible substrate with Duradek D811 (solvent-based) or D763 (water-based) adhesive applied per Duradek installation instructions.
Surface Covering:	Non-combustible tile adhered to Duradek Tiledek per Duradek installation instructions.



Rating:	Class C
Deck Slope:	1/4 : 12
Deck:	15 mm (19/32") AC Exterior grade plywood, moisture content not greater than 8% fastened with #10 exterior wood screws. The fasteners are spaced 152 mm (6") OC along edges and 203 mm (8") OC along intermediate supports. All deck joints are covered evenly with Mapei PlaniPatch floor patch.
Membrane:	Duradek Ultra or Okanagan V2V 1.5 mm (60 mils) adhered to cement board with Duradek D811 (solvent-based) adhesive applied per Duradek installation instructions.

Rating:	Class C
Deck Slope:	1/4 : 12
Deck:	15 mm (19/32") AC Exterior grade plywood, moisture content not greater than 8% fastened with #10 exterior wood screws. The fasteners are spaced 152 mm (6") OC along edges and 203 mm (8") OC along intermediate supports. All deck joints are covered evenly with Mapei PlaniPatch floor patch.
Membrane:	Duradek Tiledek adhered to cement board with Duradek D811 (solvent-based) adhesive applied per Duradek installation instructions.
Surface Covering:	Non-combustible tile adhered to Duradek Tiledek per manufacturer's installation instructions.

**ANSI/FM 4474, Determined allowable uplift resistance**

System No.	Substrate <sup>3, 4</sup>	Adhesive <sup>5</sup>	Maximum Allowable Wind Uplift kPa (psf) <sup>1, 2</sup>
1	Cement board	Duradek D763	9.6 (200)
2	Cement board	Duradek D811	9.6 (200)
3	Plywood	Duradek D763	9.6 (200)
4	Plywood	Duradek D811	11.5 (240)

<sup>1</sup> A factor of safety of 2 is applied to the maximum allowable wind uplift results.

<sup>2</sup> The wind uplift test results can be related to the adhesion of the membrane to the substrate only. Results are not an indication of the bond of the substrate to the substructure and are not an indication of the strength of the deck substructure. The deck and framing to which the Duradek Ultra system is adhered must be designed for the applicable components and wind loads in accordance with the applicable code.



# LABORATORIES

CERTIFICATION TESTING INSPECTION

VANCOUVER, BC: 877.461.8378 ph. | 604.527.8368 fx.  
LOS ANGELES, CA: 909.483.0250 ph. | 909.483.0336 fx.  
WASHINGTON, DC: 540.636.9445 ph. | 540.636.9414 fx.  
TULSA, OK: 918.437.8333 ph. | 918.437.8487 fx.  
TORONTO, ON: 905.605.5444  
SEATTLE, WA: 425.512.8419  
WEBSITE: WWW.QAI.ORG

- <sup>3</sup> Plywood is minimum 5/8-inch-thick exterior-grade with tongue-and groove edges, complying with recognized standards.  
<sup>4</sup> Cement board is 'USG Durock Cement Board Next Gen' minimum 1/2-inch-thick (nominal).  
<sup>5</sup> Adhesive must be applied in accordance with the manufacturer's published installation instructions.

**Notes:** Products must be installed with the manufacturer's published installation instructions and in accordance with the building codes recognized by the authority having jurisdiction.

Listed manufacturers are subject to on-going inspections by QAI to ensure that the products outlined above remains as it is listed.

The materials, products or systems listed herein have been qualified to bear the QAI Listing Mark under the conditions stated with each Listing. Only those products bearing the QAI Listing Mark are considered to be listed by QAI. No warrantee is expressed or implied, and no guarantee is provided that any jurisdictional authority will accept the Listing found herein. The appropriate authorities should be contacted regarding the acceptability of any given Listing. Visit the QAI Online Listing Directory located at [www.qai.org](http://www.qai.org) for the most up to date version of this Listing and to validate that this QAI Listing is active. Questions regarding this listing may be directed to [info@qai.org](mailto:info@qai.org). Please include the listing number in the request.

\*\*\*