

## WINDOWS & DOORS LISTING PROGRAM

**Customer:** Century Glass (85) Ltd.  
**Class:** Fenestration Products – Energy Performance  
**Location:** Kamloops, Canada  
**Website:** <http://www.centuryglass.ca/>

**Listing No.** W418-10  
**Project No.** W418-10 ED6  
**Effective Date:** November 16, 2007  
**Last Revised Date:** April 30, 2018  
**Expires:** N/A

**Standards:** CSA A440.2 “Fenestration Energy Performance”

**Product:** Vinyl Windows

**Markings:** Products are marked with the following content in a permanent manner where it is readily visible after installation:

- a) Manufacturer’s name, Trademark or other recognized symbol or identification.
- b) QAI file number: W418-10
- c) QAI logo shown here:



- d) “Evaluation for energy performance in accordance with CSA A440.2” / “Évalué pour la performance d’énergie en accord à la norme CSA A440.2”

**Models / Ratings: 1638 Series Fixed Window**

Model Code	U-Value (W/m <sup>2</sup> K)	Energy Rating
1638-O-1	1.77	20
1638-O-2	1.87	15
1638-O-3	1.54	24
1638-O-4	1.63	20
1638-O-5	1.30	29
1638-O-6	1.35	27
1638-O-7	1.37	26
1638-O-8	1.40	24
1638-O-9	1.50	24
1638-O-10	1.51	21
1638-O-11	1.57	19
1638-O-12	1.60	17
1638-O-13	1.64	16
1638-O-14	1.22	30
1638-O-15	1.12	31
1638-O-16	1.39	26
1638-O-17	1.67	38
1638-O-18	1.67	35
1638-O-19	1.72	33
1638-O-20	1.75	31
1638-O-21	1.78	29

**2600 Series Fixed Casement Window**

Model Code	U-Value (W/m <sup>2</sup> K)	Energy Rating
2600-O-1	1.70	17
2600-O-2	1.77	14
2600-O-3	1.54	20
2600-O-4	1.59	17
2600-O-5	1.29	27
2600-O-6	1.33	25
2600-O-7	1.35	24
2600-O-8	1.38	23
2600-O-9	1.46	23
2600-O-10	1.46	20
2600-O-11	1.52	18
2600-O-12	1.55	17
2600-O-13	1.47	20
2600-O-14	1.19	28
2600-O-15	1.11	30
2600-O-16	1.35	25

### 2600 Series Awning Window

Model Code	U-Value (W/m <sup>2</sup> K)	Energy Rating
2600-A-1	1.65	18
2600-A-2	1.72	15
2600-A-3	1.48	21
2600-A-4	1.52	19
2600-A-5	1.33	24
2600-A-6	1.33	23
2600-A-7	1.35	22
2600-A-8	1.37	22
2600-A-9	1.46	21
2600-A-10	1.47	18
2600-A-11	1.50	17
2600-A-12	1.51	16
2600-A-13	1.54	15
2600-A-14	1.23	25
2600-A-15	1.15	27
2600-A-16	1.35	23

### 2600 Series Casement Window

Model Code	U-Value (W/m <sup>2</sup> K)	Energy Rating
2600-C-1	1.65	18
2600-C-2	1.72	15
2600-C-3	1.49	21
2600-C-4	1.54	18
2600-C-5	1.32	24
2600-C-6	1.35	23
2600-C-7	1.37	22
2600-C-8	1.38	21
2600-C-9	1.47	20
2600-C-10	1.48	18
2600-C-11	1.52	17
2600-C-12	1.54	16
2600-C-13	1.56	15
2600-C-14	1.22	25
2600-C-15	1.16	26
2600-C-16	1.36	23

**6490 Series Horizontally Sliding Window**

Model Code	U-Value (W/m <sup>2</sup> K)	Energy Rating
6490-XO-1	1.81	16
6490-XO-2	1.90	12
6490-XO-3	1.71	18
6490-XO-4	1.82	14
6490-XO-5	1.46	24
6490-XO-6	1.49	22
6490-XO-7	1.51	21
6490-XO-8	1.51	20
6490-XO-9	1.63	19
6490-XO-10	1.63	16
6490-XO-11	1.77	13
6490-XO-12	1.83	11
6490-XO-13	1.84	9
6490-XO-14	1.37	24
6490-XO-15	1.30	25
6490-XO-16	1.54	21
6490-XO-17	1.78	32
6490-XO-18	1.66	24
6490-XO-19	1.78	29
6490-XO-20	1.82	27
6490-XO-21	1.84	25
6490-XO-22	1.87	23
6490-XO-23	1.55	33
6490-XO-24	1.54	30
6490-XO-25	1.53	29

**6490 Series Single Hung (Vertically Sliding) Window**

Model Code	U-Value (W/m <sup>2</sup> K)	Energy Rating
6490-VS-1	1.80	16
6490-VS-2	1.89	12
6490-VS-3	1.71	18
6490-VS-4	1.81	14
6490-VS-5	1.45	24
6490-VS-6	1.54	21
6490-VS-7	1.57	20
6490-VS-8	1.61	18
6490-VS-9	1.62	20
6490-VS-10	1.63	16
6490-VS-11	1.77	13
6490-VS-12	1.83	11
6490-VS-13	1.89	9
6490-VS-14	1.37	24
6490-VS-15	1.29	26
6490-VS-16	1.53	21
6490-VS-17	1.77	32
6490-VS-18	1.65	24
6490-VS-19	1.76	30
6490-VS-20	1.80	27
6490-VS-21	1.82	26
6490-VS-22	1.85	24
6490-VS-23	1.53	33
6490-VS-24	1.51	31
6490-VS-25	1.51	30

**5200 Series Patio Door**

Model Code	U-Value (W/m <sup>2</sup> K)	Energy Rating
5200-PD-1	1.86	17
5200-PD-2	1.92	13
5200-PD-3	1.65	21
5200-PD-4	1.69	17

**1648 Series Fixed Window**

Model Code	U-Value (W/m <sup>2</sup> K)	Energy Rating
CENG-V1648-FIX-G01-3,036(2)-3,CL-13,Ar-SS	1.51	26
CENG-V1648-FIX-G01G3-3,036(2)-3,CL-13,Ar-SS	1.59	24
CENG-V1648-FIX-G02-3,036(2)-3,198(4)-13,Ar-SS	1.27	31
CENG-V1648-FIX-G02G1-3,036(2)-3,198(4)-13,Ar-SS	1.31	31
CENG-V1648-FIX-G02G2-3,036(2)-3,198(4)-13,Ar-SS	1.33	29
CENG-V1648-FIX-G02G3-3,036(2)-3,198(4)-13,Ar-SS	1.35	27
CENG-V1648-FIX-G03-3,036(2)-3,036(3)-13,Ar-SS	1.47	26
CENG-V1648-FIX-G04-3,022(2)-3,CL-13,Ar-SS	1.48	21
CENG-V1648-FIX-G04G1-3,022(2)-3,CL-13,Ar-SS	1.52	20
CENG-V1648-FIX-G04G2-3,022(2)-3,CL-13,Ar-SS	1.54	19
CENG-V1648-FIX-G04G3-3,022(2)-3,CL-13,Ar-SS	1.57	18
CENG-V1648-FIX-G05-3,036(2)-3,CL-3,198(6)-8,Ar,Ar-SS	1.21	31
CENG-V1648-FIX-G06-3,036(2)-3,CL-3,036(5)-8,Ar,Ar-SS	1.12	33
CENG-V1648-FIX-G07-3,036(2)-3,CL-3,CL-8,Ar,Ar-SS	1.39	28

Windows are not intended for installation in storefronts, non-operable portions of curtain wall, fixed glazing cast into precast concrete panels, greenhouses, skylights or sloped glazing. Test procedures are designed to test the performance of the test specimen only and are not necessarily used to test the performance of the installation, particularly the perimeter sealant joint and anchoring of the assembly.

**Notes:**

The materials, products or systems listed herein have been qualified to bear the QAI Listing Mark under the conditions stated with each Listing. Only those products bearing the QAI Listing Mark are considered to be listed by QAI. No warrantee is expressed or implied, and no guarantee is provided that any jurisdictional authority will accept the Listing found herein. The appropriate authorities should be contacted regarding the acceptability of any given Listing. Visit the QAI Online Listing Directory located at [www.qai.org](http://www.qai.org) for the most up to date version of this Listing and to validate that this QAI Listing is active. Questions regarding this listing may be directed to [info@qai.org](mailto:info@qai.org). Please include the listing number in the request.