


3980 North Fraser Way Burnaby, BC V5J 5K5 (604) 527-8378 ph. | (604) 527-8368 fx. www.qai.org

## QAI Listing B1072-1A Construction Solutions DBX1000M 4 in. Dryer Vent Box CAN/ULC S115, ASTM E814 1 Hour Membrane Penetration Assembly Non-Load Bearing



No.	COMPONENT	DESCRIPTION	
1	Gypsum Board	Туре:	Type X gypsum wallboard complying with ASTM C1396 and labeled by an approved agency.
		Thickness:	Single layer of 5/8 in. (16 mm) on each face of the wall.
		Application:	Sheathing is to be fastened to studs with #6 x 1-5/8 in. (41 mm) long coarse thread drywall screws spaced at 8 in. on center. Joints to be taped and mudded, and fastener heads to be mudded.
2	Wall Studs	Stud Type:	Minimum nominal 2 x 6 in. (38 x 140 mm) wood studs.
		Stud Spaced	Maximum 16 in. (406 mm) on center.
3	Insulation	Туре:	Mineral wool thermal insulation in compliance with ASTM C612 Type II, III or IVA. ASTM C612 Type II and III mineral wool insulation must also be non-combustible as defined by ASTM E136 and CAN/ULC-S114.
		Minimum Thickness:	2 inch (50 mm).
		Nominal Density:	Minimum 4.0 lb/ft <sup>3</sup> (64 kg/m <sup>3</sup> ).

Page 1 of 2 Visit the QAI Online Listing Directory located at <u>www.qai.org</u> for the most up to date version of this Listing and to validate that this QAI Listing is active.

> WWW.QAI.ORG info@qai.org



No.	COMPONENT	DESCRIPTION	
4	Dryer Vent Box	Certified Manufacturer: Certified Product:	Construction Solutions DBX1000M 4 in. Construction Solutions dryer vent box kit. 10 in. (254 mm) wide by 17 in. (432 mm) high by 3-1/2 in. (89 mm) deep with a 1-1/4 in. (32 mm) flange. A 3 x 5 in. (76 x 127 mm) oval cut out
		Box Dimensions:	for the dryer vent on the top and 1-1/8 in. (29 mm) knockouts on the top and bottom for gas hook up. The box is formed from 22 gauge galvanized steel.
		Trim Ring Dimensions:	9-7/8 in. (251 mm) wide by 16-7/8 in. (429 mm) high by 1-5/8 in. (41 mm) deep with a 1-5/16 in. (33 mm) flange. The trim ring is made from 25 gauge galvanized steel.
		Caulking:	PFP 4800DW
		Installation:	The dryer vent box is fastened to the 2 x 6 in. $(50 \times 152 \text{ mm})$ stud and sill through two holes on the side and bottom of the box using #8 x 1-1/2 in. (38 mm) wood screws. The galvanized steel dryer vent is inserted through the top of the box then caulked at the vent/box interface. The opening cut into the gypsum board shall be a maximum of 10-1/2 in. (267 mm) wide by 17-1/2 in. (445 mm) high. Only one box is permitted per stud cavity.
5	Vent Pipe	Size:	4 in. (101 mm) round.
		Туре:	26 gauge galvanized steel.

Visit the QAI Online Listing Directory located at <u>www.qai.org</u> for the most up to date version of this Listing and to validate that this QAI Listing is active.

WWW.QAI.ORG info@qai.org