QAI LABORATORIES
CERTIFICATION TESTING INSPECTION

VANCOUVER, BC: 877.461.8378 ph. | 604.527.8368 fx.
LOS ANGELES, CA: 909.483.0250 ph. | 909.483.0336 fx.
WASHINGTON, DC: 540.636.9445 ph. | 540.636.9414 fx.
TULSA, OK: 918.437.8333 ph. | 918.437.8487 fx.
TORONTO, ON 416.550.9280
SEATTLE, WA 425.512.8419
WEBSITE: WWW.QAI.ORG

ELECTRICAL LISTING PROGRAM

Customer:	Valley View Metal Shop Ltd.
Class:	Electrical Cord Reels
Location:	P.O. Box 366, Swan Lake, MB, R0G 2S0, Canada
Listing No.	E10625
Report No.	E10625-1702 Edition 3
Project No.	E10625-2102
Effective Date:	June 09, 2014
Last Revised Date:	May 14, 2021
Expires:	N/A

Standards:	CSA C22.2 No. 308	Cord Reels and Multi-Outlet Assemblies
	UL 355	Cord Reels

Product: Electrical Cord Reels.
Dry Locations Use, Permanently-Connected.

Markings: Products are marked in a permanent manner where it is readily visible after installation with the following:
- a) Manufacturer's name or trademark
- b) Model designation
- c) Month and year of manufacture
- d) Product ratings: voltage, frequency, watts
- e) QAI file Number: E10625
- f) The wording "Conforms to CSA C22.2 No. 308 and UL 355"
- g) Warning markings as required by the standards in English and French
- h) QAI Logo

Models / Ratings:

Model #	Voltage	Amps	Phase	Hz	Descriptions	Location
AlumaReel EC6 100	120Vac	15/4A	1 ph	60Hz	Electrical Cord Reels 18" x Φ9"	Dry Location
AlumaReel EC3 100	120Vac	15A	1 ph	60Hz	Electrical Cord Reels 18" x Φ9"	Dry Location

Note: AlumaReel EC6 100 has 3 more terminals for the purpose of control circuit, and is designed to accommodate the AlumaReel line of remote welder controls.

***