


**QAI Listing P321-1C Uponor PEX Filled Floor/Ceiling Assembly
 UL 263, ASTM E119, CAN/ULC S101
 2 Hour Fire Resistance Rated Restrained Floor/Ceiling Assembly
 Restricted-Load Bearing**



| No. | COMPONENT | DESCRIPTION |
|-----|---------------------|--|
| 1 | Concrete | Normal weight reinforced concrete slab and beam designed in accordance with ACI-318-89. Carbonate aggregate was used, min. compressive strength of 3500 psi, and unit weight of 145 +/- 5 pcf. Minimum slab thickness of 6-1/2 in. with the below requirements. 1 in. minimum concrete cover over the positive reinforcement for a 2 hour rating |
| 2 | Steel Reinforcement | Various sized grade 40 and 60 deformed steel bars located as required by ACI 318-89 design for positive and negative reinforcement. Min. concrete cover to be placed over positive reinforcement as described in item 1. |

| No. | COMPONENT | DESCRIPTION |
|-----|---------------------|--|
| 3 | Non-Metallic Tubing | Uponor Inc. AquaPEX (natural, red, blue) nominal 1/2 in. to 2 in. tubing; Pre-Insulated AquaPEX nominal 1/2 in. to 1 in. tubing; hePEX (natural) nominal 1/2 in. to 2 in. tubing; RCW PEX nominal 1/2 in. to 1 in. tubing. Installed perpendicular to and on the top side of the positive reinforcing bars. The tubing may be placed inside a flexible or rigid polyethylene or rigid PVC sleeve. The tubing may penetrate the floor membrane through a sill plate and into a stud cavity of a wall as necessary. Tubes may be supported by 1-1/2 in. wide by 3/8 in. thick PVC or steel brackets. The max. density of tubing shall be 14 in. ³ per ft. ³ of concrete. |

*Restricted-Load Bearing – Load rating for this assembly was calculated in accordance with the building code requirements for Reinforced Concrete of the American Concrete Institute (ACI 318-89). For jurisdictions employing the Limit States Design Method such as Canada, a load restriction factor shall be used.

Visit the QAI Online Listing Directory located at www.qai.org for the most up to date version of this Listing and to validate that this QAI Listing is active.