

FACTORY CONSTRUCTED BUILDINGS AND STRUCTURES LISTING PROGRAM	
Class:	Commercial/Industrial Structures – For Electrical Features Only
Customer:	Kent Homes, a Division of J.D. Irving Ltd.
Location:	Bouctouche, New Brunswick
Listing No.	REC589-3
Effective Date:	August 19, 2011
Last Revised:	October 10, 2014
Expires:	N/A
Standard:	<p>CSA A277 "Procedure for Factory Certification of Buildings" CSA C22.1 "Canadian Electrical Code, Part 1, Safety Standard for Electrical Installations"</p> <p><u>Note:</u> Standards above as provincially amended by New Brunswick, PEI, Nova Scotia, Newfoundland, Quebec, and Manitoba. Jurisdictions may require structures to comply with Provincial/Municipal Codes and lieu of the national codes.</p>
Product:	Commercial Industrial Structures – For electrical features only
Markings:	<p>All markings must be permanent and readily visible after installation</p> <ol style="list-style-type: none"> 1) The QAI label (item 1069, black print on silver background) is normally located in close proximity to the electrical panel 2) The specification nameplate is normally located in close proximity to the electrical panel and includes: <ul style="list-style-type: none"> • Manufacturer's name and address • Model designation or equivalent • Product serial number • Complete electrical rating • Fixed appliances and equipment that are installed in the factory 3) Other markings as required by CSA C22.1 <p><u>Note:</u> the QAI label and specification nameplate are available from QAI and must be applied at the factory</p>
Models:	<p>The scope of structures covered by this listing include:</p> <p>Buildings are: Commercial/Industrial structures comprised of single or multiple modules. Commercial/Industrial structures typically include but are not limited to office space, stores, construction camp facilities such as washroom facilities, dormitories, kitchens and dining trailers, equipment buildings, and other similar commercial or industrial buildings.</p>



	<p>Electrical Ratings: 347/600V, 60Hz, 4000A max, single or three phase systems</p> <p>The operation of the complete fire alarm system is not included in this report and QAI certification. This report does not include structures for use in hazardous locations. This report does not include services other than the electrical nor does it include vehicular lighting or brake wiring systems.</p> <p>Structures included in this Listing are manufactured at a central facility, complete with electrical wiring, for installation or connection to other modules in the field. These units, when completely assembled in the field, are equipped with normal facilities for connection to electrical services. QAI certification covers any factory installed electrical services and is intended to obviate the necessity of further inspection by the local regulatory authorities except for field service connections, any interconnections between modules, and for field installed features.</p>
Note:	<p>Interconnection of modules and connection to services must be finished on site as specified in the electrical permits and are subject to inspection from the local authorities having jurisdiction.</p> <p>Structures shall be installed under permit in accordance with the codes enforced by the authority having jurisdiction.</p>

The materials, products or systems listed herein have been qualified to bear the QAI Listing Mark under the conditions stated with each Listing. Only those products bearing the QAI Listing Mark are considered to be listed by QAI.

No warrantee is expressed or implied, and no guarantee is provided that any jurisdictional authority will accept the Listing found herein. The appropriate authorities should be contacted regarding the acceptability of any given Listing.

Visit the QAI Online Listing Directory located at www.qai.org for the most up to date version of this Listing and to validate that this QAI Listing is active. Questions regarding this listing may be directed to info@qai.org. Please include the listing number in the request.
