

WINDOWS LISTING PROGRAM

Customer: Eurosell Windows Ltd.
 Class: Windows – Energy Performance
 Location: Surrey, BC

Listing No. W481
 Project No. W481-1 Edition 4

Effective Date: January 8, 2013
 Last Revised Date: November 9, 2017

Standards: CSA A440.2 Energy Performance of Windows and other Fenestration Systems

Product: Vinyl Windows

Markings: Products are marked in a permanent manner where it is readily visible after installation with the following:

- a) Manufacturer’s name or trademark
- b) QAI logo with ‘c’ identifier
- c) QAI file Number: W481-1
- d) The wording “Evaluated for energy performance in accordance with CSA A440.2”
- e) The wording “Évalué pour la performance d’énergie en accord à la norme CSA A440.2”

Models / Ratings: 9000 Series Horizontal Slider

Glass Option	Model Code	Window U-Value (W/m ² K)	Energy Rating (ER)
1	AlkanHS-3mmLowE(e=0.035)-11.9mmArg-3mmClear	1.72	19
2	AlkanHS-3mmLowE(e=0.035)-11.9mmArg(11mmGrille)-3mm Clear	1.78	16
3	AlkanHS-3mmLowE(e=0.035)-11.9mmAir-3mmClear	1.91	15
4	AlkanHS-3mmLowE(e=0.042)-12.7mmArg-3mmClear	1.60	22
5	AlkanHS-3mmLowE(e=0.042)-12.7mmArg(11mmGrille)-3mmClear	1.66	20
6	AlkanHS-3mmLowE(e=0.022)-12.7mmArg-3mmClear	1.57	17
7	AlkanHS-3mmLowE(e=0.022)-12.7mmArg(11mmGrille)-3mmClear	1.63	15
8	AlkanHS-272(3)-Arg(6.34)-Cl(3)-Arg(9.51)-Cl(3)	1.56	22
9	AlkanHS-272(3)-Arg(6.34)-Cl(3)-Arg(9.51)-i89(3)	1.37	26



9000 Series Vertical Slider

Glass Option	Model Code	Window U-Value (W/m ² K)	Energy Rating (ER)
1	AlkanVS-3mmLowE(e=0.035)-11.9mmArg-3mmClear	1.71	19
2	AlkanVS-3mmLowE(e=0.035)-11.9mmArg(11mmGrille)-3mm Clear	1.77	16
3	AlkanVS-3mmLowE(e=0.035)-11.9mmAir-3mmClear	1.91	14
4	AlkanVS-3mmLowE(e=0.042)-12.7mmArg-3mmClear	1.60	22
5	AlkanVS-3mmLowE(e=0.042)-12.7mmArg(11mmGrille)-3mmClear	1.66	20
6	AlkanVS-3mmLowE(e=0.022)-12.7mmArg-3mmClear	1.57	16
7	AlkanVS-3mmLowE(e=0.022)-12.7mmArg(11mmGrille)-3mmClear	1.63	14
8	AlkanVS-272(3)-Arg(6.34)-Cl(3)-Arg(9.51)-Cl(3)	1.56	22
9	AlkanVS-272(3)-Arg(6.34)-Cl(3)-Arg(9.51)-i89(3)	1.36	26

5000 Series Picture Window

Glass Option	Model Code	Window U-Value (W/m ² K)	Energy Rating (ER)
1	5000PIC-272(3)-Arg(12.7)-Cl(3)	1.49	26
2	5000PIC-272(3)-Arg(12.7)-i89(3)	1.43	28
3	5000PIC-272(3)-Arg(12.7)-Cl(3)-Arg(12.7)-Cl(3)	1.15	33
4	5000PIC-272(3)-Arg(12.7)-Cl(3)-Arg(12.7)-Cl(3)Grille	1.20	30
5	5000PIC-SB60(3)-Arg(12.7)-Cl(3)-Arg(12.7)-Cl(3)	1.15	32

5000 Series Casement Window

Glass Option	Model Code	Window U-Value (W/m ² K)	Energy Rating (ER)
1	5000CAS-272(3)-Arg(12.7)-Cl(3)	1.47	23
2	5000CAS-272(3)-Arg(12.7)-i89(3)	1.39	24
3	5000CAS-272(3)-Arg(12.7)-Cl(3)-Arg(12.7)-Cl(3)	1.20	27
4	5000CAS-272(3)-Arg(12.7)-Cl(3)-Arg(12.7)-Cl(3)Grille	1.23	26
5	5000CAS-SB60(3)-Arg(12.7)-Cl(3)-Arg(12.7)-Cl(3)	1.20	26

5000 Series Awning Window

Glass Option	Model Code	Window U-Value (W/m ² K)	Energy Rating (ER)
1	5000AWN-272(3)-Arg(12.7)-Cl(3)	1.48	22
2	5000AWN-272(3)-Arg(12.7)-i89(3)	1.41	24
3	5000AWN-272(3)-Arg(12.7)-Cl(3)-Arg(12.7)-Cl(3)	1.21	27
4	5000AWN-272(3)-Arg(12.7)-Cl(3)-Arg(12.7)-Cl(3)Grille	1.23	26
5	5000AWN-SB60(3)-Arg(12.7)-Cl(3)-Arg(12.7)-Cl(3)	1.21	26

Notes: Listed products meet the energy requirements of the standards listed above. Windows are not intended for installation in storefronts, non-operable portions of curtain wall, fixed glazing cast into precast concrete panels, greenhouses, skylights or sloped glazing. Test procedures are designed to test the performance of the test specimen only and are not necessarily used to test the performance of the installation, particularly the perimeter sealant joint and anchoring of the assembly.

The materials, products or systems listed herein have been qualified to bear the QAI Listing Mark under the conditions stated with each Listing. Only those products bearing the QAI Listing Mark are considered to be listed by QAI. No warranty is expressed or implied, and no guarantee is provided that any jurisdictional authority will accept the Listing found herein. The appropriate authorities should be contacted regarding the acceptability of any given Listing. Visit the QAI Online Listing Directory located at www.qai.org for the most up to date version of this Listing and to validate that this QAI Listing is active. Questions regarding this listing may be directed to info@qai.org. Please include the listing number in the request.
