

FIRE DOOR LISTING PROGRAM

Customer: Masonite Architectural
 Class: Fire Doors
 Location: London, Ontario
 Website: www.masonitearchitectural.com

Listing No. F424
 Project No. F424-1 Edition 3

Effective Date: April 22, 2016
 Last Revised: July 4, 2017

Standards:	CAN/ULC-S104 UL 10(b) UL 10(c) NFPA 252	<i>Standard Method for Fire Tests of Door Assemblies. Fire Tests of Doors Assemblies. Fire Tests of Doors Assemblies. Standard Methods of Fire Tests of Door Assemblies.</i>
------------	--	--

Product: 20 min Rated Fire Doors

Label: See [FD001 - Fire Door Labeling requirements](#)

Models / Ratings: **20-MINUTE WOOD CORE PANEL DOORS:**

Minimum 2-1/4" Thickness

Swing Type:	Maximum Dimensions		Panel Type:	Latching:
	Width:	Length:		
Single Swing	3'0" (914 mm)	8'6" (2591 mm)	Flat or Raised	Single Point (Mortised or Cylindrical)
Pairs	6'0" (1829 mm)	8'6" (2591 mm)	Flat or Raised	3 or 4 point (Active: Mortised or Cylindrical) (Inactive: Mortised or Surface Mounted Automatic Flush Bolts)



Limitations: (Review Machining Report for further detail)

- Hinges
 - Per NFPA 80, Table 2-4.3.1
 - Continuous hinges
 - Pivot hinges
- Automatic or Manual Flush Bolts (Listed and Labeled)
 - Surface mounted or mortised flush bolts allowed
- Cylindrical Latches (Listed and Labelled)
 - Minimum latch bolt throw shall be ½" on single swing and ¾" on pairs
- Mortise Lockset (Listed and Labelled)
 - Maximum cutout 1-1/4" x 5" x 6-3/4"
 - Minimum latch bolt throw shall be ½" on single swing and ¾" on pairs
- Deadlock (Listed and Labelled)
 - Located a minimum of 6" above latch cutout
- Fire Exit Devices
 - Surface mounted or concealed vertical rod exit devices
- Light Kit (Listed and Labelled)
 - Steel lite kit – max. 1296 sq. in. (Max. 54" dimension) ¼" wire glass.
 - Steel lite kit – max. 1503 sq. in. (Max. 68" dimension) Fire Lite glazing. Maximum of 18 panels up to 1503 sq. in. total.
 - ¼" Fireglass 20, impact safety rated for U.S.A.
- Viewers (Listed and Labeled)
 - Max. 1" diameter placed in 1-3/4" thickness only
- Electrical Raceway
 - Max. 3/8" x 3/8" raceway
- Automatic Door Bottom (Listed and Labelled)
 - Surface mounted and mortised allowed

Notes: *Refer to QAI evaluation report F424-1 and the applicable test reports for test assembly configurations used for fire endurance testing.*

Refer to the [QAI FD002 - Fire Door Guidelines for general guidelines of fire door assemblies](#)

Final acceptance of the product in the intended application is to be determined by the authority having jurisdiction (AHJ).

Product is to be installed in accordance with the manufacturer's published installation instructions by qualified installing personnel.

The materials, products or systems listed herein have been qualified to bear the QAI Listing Mark under the conditions stated with each Listing. Only those products bearing the QAI Listing Mark are considered to be listed by QAI. No warrantee is expressed or implied, and no guarantee is provided that any jurisdictional authority will accept the Listing found herein. The appropriate authorities should be contacted regarding the acceptability of any given Listing. Visit the QAI Online Listing Directory located at www.qai.org for the most up to date version of this Listing and to validate that this QAI Listing is active. Questions regarding this listing may be directed to info@qai.org. Please include the listing number in the request.
