3980 North Fraser Way
Burnaby, BC
V5J 5K5 Canada
Ph. 604.527.8378 Fx. 918.437-8487

LISTING REPORT ADDENDUM

Applicant Listing Number:	B1092

Report Number:	B1092-1 Edition 7

Applicant:	Global Environmental Manufacturing (G.E.M.) Incorporated dba Euroshield
	9330 48th Steet SE
	Calgary, AB
	T2C 2R2 Canada
Contact Name:	Lesley Gustafson
Phone:	515-421-5210
Email:	lgustafson@euroshieldusa.com

Addendum Report: B1092-1 Edition 7

Project Number:	B1092-1 Edition 7
Office:	Burnaby
Date:	December 20, 2025
Issued By:	Matt Lansdowne, VP of Certification & Engineering
Reviewed By:	Kent Adamson, President

Addendum report B1092-1 Edition 7 modifies report B1092-1 Edition 6b with changes made the following documents:

- CERus-1013
- B1092 Listing Page
- CER Cross Reference Checklist
- Evaluation Report

SCOPE:

1.	Update to CERus-1013 and B1092 product listing to include new products GEM Beaumont Shake HP and Vermont Slate Loc HP for use in hail and impact applications (non roof-fire classification).

ALL REPORTS ARE THE CONFIDENTIAL PROPERTY OF CLIENTS. PUBLICATION OF STATEMENTS, CONCLUSIONS OR EXTRACTS FROM OR REGARDING OUR REPORTS IS NOT PERMITTED WITHOUT OUR WRITTEN APPROVAL. ANY LIABILITY ATTACHED THERETO IS LIMITED TO THE FEE CHARGED. THE RESULTS OF THIS EVALUATION REPORT PERTAIN ONLY TO THE SPECIFIC SAMPLE(S) EVALUATED.

JUSTIFICATION:

Beaumont Shake HP and Vermont Slate Loc HP products, are of identical formulation and profile geometry, with changes only to increase product thickness. As such, noted products are considered to comply with material property requirements, and provide increased resistance to wind uplift and impact. The increased thickness increases fuel load, as such, application for use in roof fire applications is not recognized in CERus-1013 or B1092 product listing..

CONCLUSION:

The addendums to QAI Listing report B1092-1 Edition 6b described in the scope above were found to comply with applicable requirements and are acceptable for listing.

Project Manager: Matt Lansdowne

Title: Director of Engineering

Signature: Matt Lansdowne

Reviewed by Kent Adamson

Title: President

Signature:

Approved By: Kent Adamson

Title: President

Signature:

ALL REPORTS ARE THE CONFIDENTIAL PROPERTY OF CLIENTS. PUBLICATION OF STATEMENTS, CONCLUSIONS OR EXTRACTS FROM OR REGARDING OUR REPORTS IS NOT PERMITTED WITHOUT OUR WRITTEN APPROVAL. ANY LIABILITY ATTACHED THERETO IS LIMITED TO THE FEE CHARGED. THE RESULTS OF THIS EVALUATION REPORT PERTAIN ONLY TO THE SPECIFIC SAMPLE(S) EVALUATED.