



## PLUMBING PRODUCTS LISTING PROGRAM

Customer: Reliance Worldwide Corporation DBA Cash Acme  
Class: Plastic Piping and Accessories  
Location: Cullman, Alabama, USA  
Website: <https://www.rwc.com/>

Listing No. P343-1  
Effective July 1, 2016  
Date:  
Last February 23, 2026  
Revised  
Expires: N/A

Standards: ASTM E84-18 *“Standard Test Method for Surface Burning Characteristics of Building Materials”.*  
CAN/ULC S102.2-18 *“Method of Test for Surface Burning Characteristics of Flooring, Floor Coverings, and Miscellaneous Materials and Assemblies”.*  
ASTM E119-24 *“Standard Test Methods for Fire Tests of Building Construction and Materials”.*  
CAN/ULC S101-14 *“Standard Methods of Fire Endurance Tests of Building Construction and Materials”.*  
UL 263-11 *“Fire Tests of Building Construction and Materials”.*

Products: Cross-linked Polyethylene PEX Piping, Fittings and Valves  
Polyvinyl Chloride (PVC) Testrite Tees  
SharkBite Max brass fittings

Markings: All PEX tubing, connectors, valves, and other accessories (if sufficient space available) shall be permanently marked with the following content applied to an area that is readily visible after installation:

- a) Manufacturer’s name or trademark
- b) Standard: ASTM E84, CAN/ULC S102.2
- c) Flame Spread Rating  $\leq 25$ , Smoke Developed Rating  $\leq 50$  (FSI  $\leq 25$  / SDI  $\leq 50$ )
- d) Nominal Size
- e) QAI logo with ‘c’ and ‘us’ identifier

Models: Cash Acme/SharkBite Type PEX-a (red, white, blue, natural, purple)  
Cash Acme/SharkBite Type PEX-b (red, white, blue)  
SharkBite EvoPEX (K-series) Push-to-Connect fittings  
13 to 25 mm (1/2” to 1”) plastic crimp (barb) fittings  
13 to 51 mm (1/2” to 2”) brass crimp (barb) fittings  
13 to 51 mm (1/2” to 2”) plastic expansion fittings  
13 to 51 mm (1/2” to 2”) brass expansion fittings  
SharkBite Universal (U-) Push-to-Connect fittings  
SharkBite 2XL (SB-series) Push-to-Connect fittings  
SharkBite 2XLR (UXL-series) Push-to-Connect fittings



SharkBite Max brass fittings  
SharkBite PEX Press (UCP- and UPP-) fittings

Rating(s): **The following outlines the performance of the Cash Acme PEX pipe determined in accordance with the noted standards.**

**ASTM E84 – Surface Burning Characteristics**

Limitations	Flame Spread Index	Smoke Developed Index
Maximum 51 mm (2-inch) nominal diameter PEX-a or PEX-b piping, installed with rated minimum 13 mm (1/2-inch) pipe insulation <sup>1</sup> . No spacing requirements between adjacent runs. Maximum SharkBite EvoPEX (k series), plastic crimp and plastic expansion fittings frequency of 1 every 152 mm (6-inches), encased with approved pipe insulations <sup>1</sup> . No spacing limitations on brass accessories.	< 25	< 50

1- See list of approved pipe insulation providers

**CAN/ULC S102.2 – Surface Burning Characteristics**

Limitations	Flame Spread Index	Smoke Developed Index
Maximum 51 mm (2-inch) nominal diameter PEX-a or PEX-b piping, installed with rated minimum 13 mm (1/2-inch) pipe insulation <sup>1</sup> . No spacing requirements between adjacent runs. Maximum SharkBite EvoPEX (k series), plastic crimp and plastic expansion fittings frequency of 1 every 152 mm (6-inches), encased with approved pipe insulations <sup>1</sup> . No spacing limitations on brass accessories.	< 25	< 50

1- See list of approved pipe insulation providers

The following list of insulation types (at minimum thickness of 13 mm (1/2”) are approved for use with Cash Acme/SharkBite PEX products (13 – 51 mm (1/2” -2”). The insulation noted must be listed to ASTM C547 by an approved listing agency. Values are based on ASTM E84 testing.

Insulation	Flame Spread Rating	Smoke Developed Rating
Johns Manville Micro-Lok	< 25	< 50
Johns Manville Micro-Lok HP		
Owens Corning Fiberglass		



**UL 263, ASTM E119, CAN/ULC S101 – Wall Assemblies**

QAI Design #	Wall Type	Load	Fire Endurance Period
<b>P343-1A</b>	Light Gauge Steel Stud	Non-Load Bearing	1 Hour
<b>P343-1B</b>	Wood Dimensional Lumber Stud	Restricted Load-Bearing	1 Hour

**UL 263, ASTM E119, CAN/ULC S101 – Floor / Ceiling Assemblies**

QAI Design #	Floor / Ceiling Type	Load	Fire Endurance Period
<b>P343-1C</b>	Wood Dimensional Lumber Joist	Restricted Load-Bearing	1 Hour
<b>P343-1D</b>	Concrete Slab and Beam	Load-Bearing	2 Hour

Note: Pipe sizes are nominal dimensions.

Note: The materials, products or systems listed herein have been qualified to bear the QAI Listing Mark under the conditions stated with each Listing. Only those products bearing the QAI Listing Mark are considered to be listed by QAI. No warranty is expressed or implied, and no guarantee is provided that any jurisdictional authority will accept the Listing found herein. The appropriate authorities should be contacted regarding the acceptability of any given Listing. Visit the QAI Online Listing Directory located at [www.qai.org](http://www.qai.org) for the most up to date version of this Listing and to validate that this QAI Listing is active. Questions regarding this listing may be directed to [info@qai.org](mailto:info@qai.org). Please include the listing number in the request.

\*\*\*