

## BUILDING PRODUCTS LISTING PROGRAM

Customer: South Shore Millwork, Inc.  
 Class: Fire Doors  
 Location: Norton, Massachusetts  
 Website: <http://southshoremillwork.com/>

Listing No. F437-1  
 Project No. F437-1 Edition 1

Effective Date: September 15, 2016  
 Last Revised Date: September 15, 2016  
 Expires: N/A

Standards: CAN/ULC-S104 UL 10(b) UL 10(c) NFPA 252	<i>Standard Method for Fire Tests of Door Assemblies. Fire Tests of Doors Assemblies. Fire Tests of Doors Assemblies. Standard Methods of Fire Tests of Door Assemblies.</i>
---	--

Product: 60 min Rated Fire Doors

Labels: See [FD001 - Fire Door Labeling requirements](#)

Models: **60-MINUTE LAMINATED CORE PANEL DOORS:**

### Minimum 1-3/4" Thickness

Swing Type:	Maximum Dimensions		Panel Type:	Latching:
	Width:	Length:		
Single Swing	3'6" (1067 mm)	9'0" (2743 mm)	Flush or Raised	<b>Single Point</b> (Mortised or Cylindrical)
	4'0" (1067 mm)	7'0" (2134 mm)		
	4'0" (1067 mm)	8'0" (2438 mm)		
Arched Top Single Swing	3'6" (1067 mm)	8'0" (2438 mm)		
Pairs	7'0" (2134 mm)	8'0" (2438 mm)	Flush or Raised	<b>3 or 4 point</b> (Active: Mortised or Cylindrical) (Inactive: Mortised (Manual) and Surface Mounted Flush Bolts)
	8'0" (2438 mm)	7'0" (2134 mm)		
Double Egress	7'0" (2134 mm)	8'0" (2438 mm)	Flush or Raised	<b>4 point</b> (Concealed or Surface Mounted)

### Temperature rise

- @30 min = 250°F MAX where lites do not exceed 100 in<sup>2</sup>
- @60 min = 250°C MAX where light do not exceed 100 in<sup>2</sup>

Limitations: (Review Machining Report for further detail)

- Surface Mounted Hardware
- Cylindrical Latches (Listed and Labelled)
- Mortise Lockset (Listed and Labelled)
  - [Max. mortise pocket 4-7/16" deep x 6-1/16" high x 1" thick]
- Listed Viewers
- Fire Exit Devices
  - Surface mounted vertical rod, RIM and concealed vertical rod exit devices
- Surface Mounted and concealed door closer (Listed and Labelled)
  - Max mortise 22-1/2" long by 1-3/8" deep by 1-1/4" wide
- Light Kit (Listed and Labelled)
  - Listed Steel Lite Kit – max. 1296 sq. in. (max dimension of 54")
  - BASF Proprietary steel channel light kit – max. 600 sq. in. (max. dimension of 36")
- Electric Raceway
- Surface Mounted and concealed door bottom (Listed and Labelled)
  - Max mortise 1-3/4" deep by 1" wide by full width of the door

Notes: *Refer to QAI evaluation report F437-1 and the applicable test reports for test assembly configurations used for fire endurance testing.*

*Refer to the [QAI FD002 - Fire Door Guidelines for general guidelines of fire door assemblies](#)*

*Final acceptance of the product in the intended application is to be determined by the authority having jurisdiction (AHJ).*

*Product is to be installed in accordance with the manufacturer's published installation instructions by qualified installing personnel.*

The materials, products or systems listed herein have been qualified to bear the QAI Listing Mark under the conditions stated with each Listing. Only those products bearing the QAI Listing Mark are considered to be listed by QAI. No warrantee is expressed or implied, and no guarantee is provided that any jurisdictional authority will accept the Listing found herein. The appropriate authorities should be contacted regarding the acceptability of any given Listing. Visit the QAI Online Listing Directory located at [www.qai.org](http://www.qai.org) for the most up to date version of this Listing and to validate that this QAI Listing is active. Questions regarding this listing may be directed to [info@qai.org](mailto:info@qai.org). Please include the listing number in the request.

\*\*\*