

VANCOUVER, BC: LOS ANGELES, CA: WASHINGTON, DC: TULSA, OK: TORONTO, ON SEATTLE. WA 877.461.8378 ph. | 604.527.8368 fx. 909.483.0250 ph. | 909.483.0336 fx. 540.636.9445 ph. | 540.636.9414 fx. 918.437.8333 ph. | 918.437.8487 fx. 416.550.9280

ONTO, ON 416.550.9280 ATTLE, WA 425.512.8419 WEBSITE: WWW.QAI.ORG

## **BUILDING PRODUCTS LISTING PROGRAM**

Customer: South Shore Millwork, Inc.

Class: Fire Door Frames

Location: Norton, Massachusetts

Website: http://southshoremillwork.com/

Listing No. F437-2

Project No. F437-2 Edition 1

Effective Date: September 15, 2016 Last Revised Date: September 15, 2016

Expires: N/A

Standards: CAN/ULC-S104 Standard Method for Fire Tests of Door Assemblies.

UL 10(b) Fire Tests of Doors Assemblies. UL 10(c) Fire Tests of Doors Assemblies.

NFPA 252 Standard Methods of Fire Tests of Door Assemblies.

Product: 90 min Rated Fire Door Frames

Labels: See FD001 - Fire Door Labeling requirements

Models: 90-MINUTE FIRE DOOR FRAMES:

## **MAXIMUM FRAME SIZES:**

Swing Type:	Maximum Dimensions	
	Width:	Height:
Single Swing	4'0" (1219 mm)	9'0" (2743 mm)

## LIMITATIONS:

Minimum Frame Leg Width: 4-5/8"

Maximum Frame Leg Width: Equivalent to wall thickness
Minimum Frame Leg Thickness: 3/4" (-1/16") [Single Core Layer]
Minimum Frame Leg Thickness: 3/4" (-1/16") [Single Core Layer]

2-1/4" [4 core layers for SOSS® Invisible Hinge]

Minimum Rabbet for Door: 1-7/8" (-1/16")

Minimum Stop Height: 5/8"

Minimum Stop Width: 1-1/4" (-1/16")

Strike Plates: Listed and labelled for rated opening

Hinges: Listed and labelled for rated opening

Door Closer: Listed and labelled for rated opening

Surface mounted door closers

Concealed door closers



VANCOUVER, BC: LOS ANGELES, CA: WASHINGTON, DC: TULSA, OK: TORONTO, ON SEATTLE, WA WERSITE- 877.461.8378 ph. | 604.527.8368 fx. 909.483.0250 ph. | 909.483.0336 fx. 540.636.9445 ph. | 540.636.9414 fx. 918.437.8333 ph. | 918.437.8487 fx. 416.550.9280 425.512.8419

WWW.QAI.ORG

Notes: Refer to QAI evaluation report F437-2 and the applicable test reports for test assembly configurations used for fire endurance testing.

Refer to the QAI FD002 - Fire Door Guidelines for general guidelines of fire door assemblies

Final acceptance of the product in the intended application is to be determined by the authority having jurisdiction (AHJ).

Product is to be installed in accordance with the manufacturer's published installation instructions by qualified installing personnel.

The materials, products or systems listed herein have been qualified to bear the QAI Listing Mark under the conditions stated with each Listing. Only those products bearing the QAI Listing Mark are considered to be listed by QAI. No warrantee is expressed or implied, and no guarantee is provided that any jurisdictional authority will accept the Listing found herein. The appropriate authorities should be contacted regarding the acceptability of any given Listing. Visit the QAI Online Listing Directory located at <a href="www.qai.org">www.qai.org</a> for the most up to date version of this Listing and to validate that this QAI Listing is active. Questions regarding this listing may be directed to <a href="mailto:info@qai.org">info@qai.org</a>. Please include the listing number in the request.

\*\*\*