

## BUILDING PRODUCTS LISTING PROGRAM

Customer: South Shore Millwork, Inc.  
 Class: Fire Door Frames  
 Location: Norton, Massachusetts  
 Website: <http://southshoremillwork.com/>

Listing No. F437-2  
 Project No. F437-2 Edition 1

Effective Date: September 15, 2016  
 Last Revised Date: September 15, 2016  
 Expires: N/A

Standards:	CAN/ULC-S104 UL 10(b) UL 10(c) NFPA 252	<i>Standard Method for Fire Tests of Door Assemblies. Fire Tests of Doors Assemblies. Fire Tests of Doors Assemblies. Standard Methods of Fire Tests of Door Assemblies.</i>
------------	--	--

Product: 90 min Rated Fire Door Frames

Labels: See [FD001 - Fire Door Labeling requirements](#)

Models: **90-MINUTE FIRE DOOR FRAMES:**

### MAXIMUM FRAME SIZES:

Swing Type:	Maximum Dimensions	
	Width:	Height:
<b>Single Swing</b>	3'0" (914 mm)	8'0" (2438 mm)

### LIMITATIONS:

Minimum Frame Leg Width:	9"
Maximum Frame Leg Width:	Equivalent to wall thickness
Minimum Frame Leg Thickness:	1-3/8"
Minimum Rabbet for Door:	2-5/8"
Minimum Stop Thickness:	5/8"
Minimum Stop Width:	1-1/2"

Strike Plates: Listed and labelled for rated opening

Hinges: Listed and labelled for rated opening

Door Closer: Listed and labelled for rated opening

- Surface mounted door closers
- Concealed door closers

Notes: *Refer to QAI evaluation report F437-2 and the applicable test reports for test assembly configurations used for fire endurance testing.*

*Refer to the [QAI FD002 - Fire Door Guidelines for general guidelines of fire door assemblies](#)*

*Final acceptance of the product in the intended application is to be determined by the authority having jurisdiction (AHJ).*

*Product is to be installed in accordance with the manufacturer's published installation instructions by qualified installing personnel.*

The materials, products or systems listed herein have been qualified to bear the QAI Listing Mark under the conditions stated with each Listing. Only those products bearing the QAI Listing Mark are considered to be listed by QAI. No warrantee is expressed or implied, and no guarantee is provided that any jurisdictional authority will accept the Listing found herein. The appropriate authorities should be contacted regarding the acceptability of any given Listing. Visit the QAI Online Listing Directory located at [www.qai.org](http://www.qai.org) for the most up to date version of this Listing and to validate that this QAI Listing is active. Questions regarding this listing may be directed to [info@qai.org](mailto:info@qai.org). Please include the listing number in the request.

\*\*\*