

VANCOUVER, BC: LOS ANGELES, CA: WASHINGTON, DC: TULSA, OK: TORONTO, ON SEATTLE, WA WEBSITE: 877.461.8378 ph. | 604.527.8368 fx. 909.483.0250 ph. | 909.483.0336 fx. 540.636.9445 ph. | 540.636.9414 fx. 918.437.8333 ph. | 918.437.8487 fx. 416.550.9280 425.512.8419 WWW.QAL.ORG

## FIRE DOOR LISTING PROGRAM

Customer: Ferche Millwork, Inc. Class: Fire Door Frames Location: Rice, Minnesota Website: http://www.ferche.com/

Listing No. F438-1 Project No. F438-1 Edition 1

Effective Date: October 24, 2016 Last Revised Date: October 24, 2016 Expires: N/A

Standards:	CAN/ULC-S104	Standard Method for Fire Tests of Door Assemblies.
	UL 10(b)	Fire Tests of Doors Assemblies.
	UL 10(c)	Fire Tests of Doors Assemblies.
	NFPA 252	Standard Methods of Fire Tests of Door Assemblies.

- Product: 90 min Rated Fire Door Frames
- Labels: See FD001 Fire Door Labeling requirements

Models: 90-MINUTE FIRE DOOR FRAMES:

## MAXIMUM FRAME SIZES:

Swing Type	Maximum Dimensions		
Swing Type:	Width:	Height:	
Single Swing	4'0" (1219 mm)	9'0" (2743 mm)	

## LIMITATIONS:

Minimum Frame Leg Width:	4-5/8"
Maximum Frame Leg Width:	Equivalent to wall thickness
Minimum Frame Leg Thickness:	3/4" (-1/16") [Single Core Layer]
Minimum Frame Leg Thickness:	3/4" (-1/16") [Single Core Layer]
	2-1/4" [4 core layers for SOSS® Invisible Hinge]
Minimum Rabbet for Door:	1-7/8" (-1/16")
Minimum Stop Height:	5/8"
Minimum Stop Width:	1-1/4" (-1/16")

Strike Plates: Listed and labelled for rated opening

Hinges: Listed and labelled for rated opening

Door Closer: Listed and labelled for rated opening

- Surface mounted door closers
- Concealed door closers



VANCOUVER, BC: 877.461.8378 ph. | 604.527.8368 fx. LOS ANGELES, CA: 909.483.0250 ph. | 909.483.0336 fx. WASHINGTON, DC: 540.636.9445 ph. | 540.636.9414 fx. TULSA, OK: 918.437.8333 ph. | 918.437.8487 fx. TORONTO, ON 416.550.9280 SEATTLE, WA 425.512.8419 WEBSITE: WWW.QAI.ORG

## Notes: Refer to QAI evaluation report F438-1 and the applicable test reports for test assembly configurations used for fire endurance testing.

Refer to the <u>QAI FD002</u> - Fire Door Guidelines for general guidelines of fire door <u>assemblies</u>

Final acceptance of the product in the intended application is to be determined by the authority having jurisdiction (AHJ).

Product is to be installed in accordance with the manufacturer's published installation instructions by qualified installing personnel.

The materials, products or systems listed herein have been qualified to bear the QAI Listing Mark under the conditions stated with each Listing. Only those products bearing the QAI Listing Mark are considered to be listed by QAI. No warrantee is expressed or implied, and no guarantee is provided that any jurisdictional authority will accept the Listing found herein. The appropriate authorities should be contacted regarding the acceptability of any given Listing. Visit the QAI Online Listing Directory located at <u>www.qai.org</u> for the most up to date version of this Listing and to validate that this QAI Listing is active. Questions regarding this listing may be directed to <u>info@qai.org</u>. Please include the listing number in the request.

\*\*\*