

VANCOUVER, BC: LOS ANGELES, CA: WASHINGTON, DC: TULSA, OK: TORONTO, ON SEATTLE, WA WERSITE- 877.461.8378 ph. | 604.527.8368 fx. 909.483.0250 ph. | 909.483.0336 fx. 540.636.9445 ph. | 540.636.9414 fx. 918.437.8333 ph. | 918.437.8487 fx. 416.550.9280 425.512.8419

WWW.QAI.ORG

# FIRE DOOR LISTING PROGRAM

Customer: Syntegra, LLC

Class: Hollow Metal Fire Doors

Location: San Dimas, CA

Website: www.syntegrausa.com

Listing No. F420-2

Project No. F420-2 Edition 2 Effective Date: November 10, 2015

Last Revised: July 25, 2016

Standards: CAN/ULC-S104 Standard Method for Fire Tests of Door Assemblies.

UL 10(b) Fire Tests of Doors Assemblies.
UL 10(c) Fire Tests of Doors Assemblies.

NFPA 252 Standard Methods of Fire Tests of Door Assemblies.

Product: 90 min Rated Steel Stiffened Hollow Metal Fire Doors

Label: See FD001 - Fire Door Labeling requirements



# Models /

## 90 MINUTE STEEL STIFFENED HOLLOW METAL FIRE DOORS:

Ratings:

Hollow Metal Type (14, 16, 18, 20 gauge) steel stiffened swinging flush fire door

#### **MAXIMUM DOOR SIZES:**

### Minimum 1-3/4" Thickness

Swing	Maximum Dimensions	
Type:	Width:	Length:
Single Swing	Not Permitted	
Pairs	8'6" (2591 mm)	10'0" (2540 mm)
Double Egress	8'6" (2591 mm)	10'0" (2540 mm)



VANCOUVER, BC: LOS ANGELES, CA: WASHINGTON, DC: TULSA, OK: TORONTO, ON SEATTLE, WA WERSITE- 877.461.8378 ph. | 604.527.8368 fx. 909.483.0250 ph. | 909.483.0336 fx. 540.636.9445 ph. | 540.636.9414 fx. 918.437.8333 ph. | 918.437.8487 fx. 416.550.9280 425.512.8419

WWW.QAI.ORG

Limitations: (Review Machining Report for further detail)

- Mortised Latch
  - Syntegra LLC Hardware
    - LX Series Latch Hardware
    - PX Series Integrated Hardware
    - XT Series Integrated Exit Hardware
- Surface Mounted and Mortised Fire Exit Devices
- Viewers (Maximum size of 1" diameter)
- Surface Mounted and Concealed Door Closer
- Surface Mounted and Concealed Door Bottoms
- Glass Lights
  - Listed Steel Lite Kit max. 1296 sq. in. (max dimension of 54") or maximum size limitation for listed lite kit assembly
- Louvers are not permitted

Notes: Refer to QAI evaluation report F420-2 and the applicable test reports for test assembly configurations used for fire endurance testing.

Refer to the QAI FD002 - Fire Door Guidelines for general guidelines of fire door assemblies

Final acceptance of the product in the intended application is to be determined by the authority having jurisdiction (AHJ).

Product is to be installed in accordance with the manufacturer's published installation instructions by qualified installing personnel.

The materials, products or systems listed herein have been qualified to bear the QAI Listing Mark under the conditions stated with each Listing. Only those products bearing the QAI Listing Mark are considered to be listed by QAI. No warrantee is expressed or implied, and no guarantee is provided that any jurisdictional authority will accept the Listing found herein. The appropriate authorities should be contacted regarding the acceptability of any given Listing. Visit the QAI Online Listing Directory located at <a href="www.qai.org">www.qai.org</a> for the most up to date version of this Listing and to validate that this QAI Listing is active. Questions regarding this listing may be directed to <a href="mailto:info@qai.org">info@qai.org</a>. Please include the listing number in the request.

\*\*\*