

FACTORY CONSTRUCTED BUILDINGS AND STRUCTURES LISTING PROGRAM

Customer: Clément & Frère Ltée
Class: Business Commercial Industrial Structures – For Electrical Features Only
Location: Louiseville, Quebec
Website: <http://www.clementetfrere.com/>

Listing No. REC650-1
Project No. REC650-1, Edition 2
Effective Date: December 19, 2016
Last Revised Date: July 30, 2020
Expires: N/A

Standards: CSA A277 “Procedure for Certification of Prefabricated Buildings, Modules, and Panels”

CSA C22.1 “Canadian Electrical Code, Part I, Safety Standard for Electrical Installations”

CSA C22.10 Québec Construction Code, Chapter V – Electricity (CSA C22.1 “Canadian Electrical Code, Part I, Safety Standard for Electrical Installations” with Quebec amendments)

Note: Unless otherwise specified, the Standards/Codes noted are the most current versions in effect.

Product: Business Commercial Industrial Structures – For Electrical Features Only

Markings: 1. The QAI label (item 1069 – black lettering with silver background) is normally located in close proximity to the electrical panel.

QAI logo shown here:



2. The specification nameplate (item 1070, 8-1/2” x 7” size) is located in close proximity to the electrical panel and includes:

- Manufacturer’s Name and Address
- Date of Manufacture
- Model Serial Number or Product Code
- Factory Installed Appliances
- Site Installed Components, Assemblies, and Systems
- Electrical Systems Voltage, Frequency, and Amperage

Other Markings as required by the relevant codes.

Note: The QAI label and specification nameplate are available from QAI and must be applied at the factory.

Models / Ratings: The scope of prefabricated buildings covered by this listing include:

Structures:

Business Commercial Industrial Structures comprised of single or multiple modules complete with electrical wiring. Structures included in this listing typically include but are not limited to office space, stores, construction camp facilities such as washroom facilities, dormitories, kitchens and dining trailers, equipment buildings, and other similar commercial or industrial buildings.

Electrical Ratings:

Up to a maximum of 120/240V, 60Hz, 200A or 120/208V, 60Hz, 200A

The operation of the complete fire alarm system is not included in this report and QAI certification. This report does not include structures for use in hazardous locations. This report does not include services other than the electrical nor does it include vehicular lighting or brake wiring systems.

Structure included in this Listing are manufactured at a central facility, complete with electrical wiring, for installation or connection to other modules in the field. These units, when completely assembled in the field, are equipped with normal facilities for connection to electrical services. QAI certification covers any factory installed electrical services and is intended to obviate the necessity of further inspection by the local regulatory authorities except for field service connections, any interconnections between modules, and for field installed features.

Notes: Interconnection of modules and connection to services must be finished on site as specified in the electrical permits and are subject to inspection from the local authorities having jurisdiction.

Structures shall be installed under permit in accordance with the codes enforced by the authority having jurisdiction.

The materials, products or systems listed herein have been qualified to bear the QAI Listing Mark under the conditions stated with each Listing. Only those products bearing the QAI Listing Mark are considered to be listed by QAI. No warrantee is expressed or implied, and no guarantee is provided that any jurisdictional authority will accept the Listing found herein. The appropriate authorities should be contacted regarding the acceptability of any given Listing. Visit the QAI Online Listing Directory located at www.qai.org for the most up to date version of this Listing and to validate that this QAI Listing is active. Questions regarding this listing may be directed to info@qai.org. Please include the listing number in the request.
