

FIRE DOOR LISTING PROGRAM

Class: Wood Doors

Customer: Leadwin Doors Ltd.
Location: Surrey, BC

Listing No. F427-1
Effective Date: June 22, 2015
Last Revised: June 22, 2015
Expires: N/A

Product: Category "B" - 20 Minute Wood Fire Doors

Standard(s): CAN/ULC S104 *Standard Method for Fire Tests of Door Assemblies*
UL 10b *Fire Tests of Doors Assemblies*
UL 10c *Fire Tests of Doors Assemblies*
NFPA 252 *Standard Methods of Fire Tests of Door Assemblies*

Label: See FD001 - Fire Door Labeling requirements



Models: **L20 MDF-R**

MAXIMUM DOOR SIZES:**Minimum 1-3/4" Slab Thickness**

Swing Type:	Maximum Dimensions		Panel Type:
	Width:	Length:	
Single Swing	3'0" (914 mm)	8'0" (2438 mm)	Flush
	3'6" (1067 mm)	7'0" (2134 mm)	
Pairs	Not Allowed		
Double Egress	Not Allowed		

Hardware:

- Cylindrical Latch
- Mortised Latch
 - Assa Abloy VingCard Classic ANSI lock
 - Assa Abloy VingCard Original ANSI lock
 - Assa Abloy VingCard Signature ANSI lock
 - Schlage L Series Mortise Lock (L1 Template)
 - Yale 8600/8700 Series Mortise Lock
 - Sargent 7900 Series Mortise Lock
- Surface Mounted and Mortised Fire Exit Devices
- Vision Panel (up to 1296 in²)
- Viewers (Maximum size of 1" diameter)

- Surface Mounted and Mortised Door Bottoms
- Listed Category "G" Edge Sealing required for positive pressure doors

Note: *Refer to the QAI FD002 - Fire Door Guidelines for general guidelines of fire door assemblies*

Final acceptance of the product in the intended application is to be determined by the authority having jurisdiction (AHJ).

Product is to be installed in accordance with the manufacturer's published installation instructions by qualified installing personnel.

The materials, products or systems listed herein have been qualified to bear the QAI Listing Mark under the conditions stated with each Listing. Only those products bearing the QAI Listing Mark are considered to be listed by QAI.

No warrantee is expressed or implied, and no guarantee is provided that any jurisdictional authority will accept the Listing found herein. The appropriate authorities should be contacted regarding the acceptability of any given Listing.

Visit the QAI Online Listing Directory located at www.qai.org for the most up to date version of this Listing and to validate that this QAI Listing is active.

Questions regarding this listing may be directed to info@qai.org. Please include the listing number in the request.

FORM History

History Date	Version	Change Description	Reviewed By	Approved By
04/17/2014	3.0	Added disclaimer to form.	J. Johnson	K. Adamson