VANCOUVER, BC: LOS ANGELES, CA: WASHINGTON, DC: TULSA, OK: TORONTO, ON WEBSITE: 877.461.8378 ph. | 604.527.8368 fx. 909.483.0250 ph. | 909.483.0336 fx. 540.636.9445 ph. | 540.636.9414 fx. 918.437.8333 ph. | 918.437.8487 fx. 416.550.9280

WWW.QAI.ORG

## **FIRE DOOR LISTING PROGRAM**

Customer: Jeld-Wen Inc.

Class: Fire Resistant Doors and Frames

Location: Klamath Falls, Oregon Website: <a href="https://www.jeld-wen.com">www.jeld-wen.com</a>

Listing No. F441

Projects No. F441-1 Edition 4 F441-2 Edition 3

Effective Date: May 9, 2017 Last Revised Date: August 15, 2018

Standards: UL 10B Fire Tests of Door Assemblies

UL 10C Positive Pressure Fire Tests of Door Assemblies
NFPA 252 Standard Methods of Fire Tests of Door Assemblies
CAN/ULC S104 Standard Method for Fire Tests of Door Assemblies

Product: 20 to 90 minute Neutral & Positive Pressure Rated Category "A" and "B" Wood

and Composite Fire Doors and Category "C" Fire Door Frames with and without

Hose Stream.

Markings: See <u>FD001 - Fire Door Labeling requirements</u>

Models / Ratings: Fire Resistance Rated Doors

Spec. Owner	Fire Rating	Category	Listing #	Description
Jeld-Wen	20 minute no hose stream	Α	F441-1-1-20	Wood Core
Jeld-Wen	20 minute single swing: hose stream standard pair: no hose stream	В	F441-1-2-20	Wood Core
BASF SE	20 minute	А	F411-1-1-20	Wood Core
BASF SE	20 minute	А	F411-1-2-20	Composite Core
BASF SE	45 minute	Α	F411-1-1-45	Composite Core
BASF SE	60 minute	Α	F411-1-1-60	Composite Core
BASF SE	90 minute	А	F411-1-1-90	Composite Core

## **Fire Resistance Rated Door Frames**

Spec Owner	Fire Rating	Category	Listing #	Description
BASF SE	20 minute	С	F411-2-20	Composite Frame
BASF SE	45 minute	С	F411-2-45	Composite Frame
BASF SE	60 minute	С	F411-2-60	Composite Frame
BASF SE	90 minute	С	F411-2-90	Composite Frame



VANCOUVER, BC: LOS ANGELES, CA: WASHINGTON, DC: TULSA, OK: TORONTO, ON WEBSITE:

877.461.8378 ph. | 604.527.8368 fx. 909.483.0250 ph. | 909.483.0336 fx. 540.636.9445 ph. | 540.636.9414 fx. 918.437.8333 ph. | 918.437.8487 fx. 416.550.9280 WWW.QAI.ORG

- Notes: Refer to QAI evaluation reports F441-1 and F441-2 and the applicable test reports for test assembly configurations used for fire endurance testing.
  - Refer to the QAI FD002 Fire Door Guidelines for general guidelines of fire door <u>assemblies</u>
  - Final acceptance of the product in the intended application is to be determined by the authority having jurisdiction (AHJ).
  - Product is to be installed in accordance with the manufacturer's published installation instructions by qualified installing personnel.

The materials, products or systems listed herein have been qualified to bear the QAI Listing Mark under the conditions stated with each Listing. Only those products bearing the QAI Listing Mark are considered to be listed by QAI. No warrantee is expressed or implied, and no guarantee is provided that any jurisdictional authority will accept the Listing found herein. The appropriate authorities should be contacted regarding the acceptability of any given Listing. Visit the QAI Online Listing Directory located at www.qai.org for the most up to date version of this Listing and to validate that this QAI Listing is active. Questions regarding this listing may be directed to info@gai.org. Please include the listing number in the request.

\*\*\*