

## FIRE DOOR LISTING PROGRAM

Customer: Genesis Hospitality Corporation  
 Class: Fire Doors  
 Location: Loveland, Colorado  
 Listing No. F426  
 Project No. F426-1, Edition 2  
 Effective Date: December 1, 2017  
 Last Revised Date: December 30, 2022  
 Expires: <N/A>

Standards: CAN/ULC-S104 *Standard Method for Fire Tests of Door Assemblies.*  
 UL 10(b) *Fire Tests of Doors Assemblies.*  
 UL 10(c) *Positive Pressure Fire Tests of Door Assemblies.*  
 NFPA 252 *Standard Methods for Fire Tests of Door Assemblies.*

Product: 60 min Rated Positive Pressure Fire Doors

Markings: See [FD001 - Fire Door Labeling requirements](#)

Models / Ratings:

### 60 MINUTE LAMINATED CORE PANEL AND FLUSH DOORS

#### Minimum 1-3/4" Thickness

Swing Type:	Maximum Dimensions		Panel Type:	Latching:
	Width:	Length:		
Single Swing	3'6" (1067 mm)	8'0" (2438 mm)	Flush Milled, Flat or Raised	<b>Single Point</b> (Mortised or Cylindrical)
	4'0" (1219 mm)	7'0" (2134 mm)		
	3'6" (1067 mm)	9'0" (2743 mm)	Flat or Raised	
	4'0" (1219 mm)	8'0" (2438 mm)		
Arched Top Single Swing	3'6" (1067 mm)	9'0" (2743 mm)	Flat or Raised	
Pairs	7'0" (2134 mm)	8'0" (2438 mm)	Flat or Raised	
	8'0" (2438 mm)	7'0" (2134 mm)		
Double Egress	7'0" (2134 mm)	8'0" (2438 mm)	Flat or Raised	<b>4 Point</b> (Concealed or Surface Mounted)

\*All door assemblies are certified for Shallow Arch door construction

#### Temperature rise

- @30 min = 250°F MAX where light do not exceed 100 in<sup>2</sup>
- @60 min = 450°F MAX where light do not exceed 100 in<sup>2</sup>

Limitations: (Review Machining Report for further detail)

- Surface Mounted Hardware
- Cylindrical Latches (Listed and Labelled)
- Mortise manual or automatic flush bolts
- Mortise Lockset (Listed and Labelled)
- Listed Viewers
- Fire Exit Devices
  - Surface mounted vertical rod, RIM and concealed vertical rod exit devices
- Surface Mounted and concealed door closer (Listed and Labelled)
- Light Kit (Listed and Labelled)
  - Listed Steel Lite Kit – max. 1296 sq. in. (max dimension of 54")
  - BASF Proprietary steel channel light kit – max. 1296 sq. in. (max. dimension of 54")
- Electric Raceway
- Surface Mounted and concealed door bottom (Listed and Labelled)

Max mortise 1-3/4" deep by 1" wide by full width of the door

Notes:

*Refer to QAI evaluation report F426-1 and the applicable test reports for test assembly configurations used for fire endurance testing.*

*Refer to the [QAI FD002 - Fire Door Guidelines for general guidelines of fire door assemblies](#)*

*Final acceptance of the product in the intended application is to be determined by the authority having jurisdiction (AHJ).*

*Product is to be installed in accordance with the manufacturer's published installation instructions by qualified installing personnel.*

The materials, products or systems listed herein have been qualified to bear the QAI Listing Mark under the conditions stated with each Listing. Only those products bearing the QAI Listing Mark are considered to be listed by QAI. No warranty is expressed or implied, and no guarantee is provided that any jurisdictional authority will accept the Listing found herein. The appropriate authorities should be contacted regarding the acceptability of any given Listing. Visit the QAI Online Listing Directory located at [www.qai.org](http://www.qai.org) for the most up to date version of this Listing and to validate that this QAI Listing is active. Questions regarding this listing may be directed to [info@qai.org](mailto:info@qai.org). Please include the listing number in the request.

\*\*\*