

VANCOUVER, BC: 877.461.8378 ph. | 604.527.8368 fx. LOS ANGELES, CA: 909.483.0250 ph. | 909.483.0336 fx. TULSA, OK: 918.437.8333 ph. | 918.437.8487 fx. TORONTO, ON 905.605.5444 WEBSITE: WWW.QAI.ORG

FIRE DOOR LISTING PROGRAM

Class: Location: Listing No. Project No.	F426-1, Edition 2 December 1, 20 December 30, 20	2 17		
Standards:	CAN/ULC-S104 UL 10(b) UL 10(c) NFPA 252	Standard Method for Fire Tests of Door Assemblies. Fire Tests of Doors Assemblies. Positive Pressure Fire Tests of Door Assemblies. Standard Methods for Fire Tests of Door Assemblies.		
Product:	90 min Rated Positive Pressure Fire Doors			
Markings:	See FD001 - Fire Door Labeling requirements			

Models / Ratings:

90 MINUTE LAMINATED CORE PANEL AND FLUSH DOORS

Minimum 1-3/4" Thickness

Swing Type:	Maximum I	Dimensions	Panel Type:	Latching:
	Width:	Length:		
Single	3'6" (1067 mm)	9'0" (2438 mm)	Flat or	Single Point
Swing	4'0" (1067 mm)	7'0" (2134 mm)	Raised	(Mortised or Cylindrical)
Pairs	6'0" (2134 mm)	8'0" (2438 mm)	Flat or Raised	3 Point (Active: Mortised or Cylindrical) (Inactive: Surface Mounted Flush Bolts)
	7'0" (2134 mm)	8'0" (2438 mm)	Flat or	4 Point
	8'0" (2438 mm)	7'0" (2134 mm)	Raised	(Active: Mortised or Cylindrical)
	7'0" (2134 mm)	9'0" (2438 mm)	Flush	(Inactive: Surface Mounted Flush Bolts)

Minimum 2-1/4" Thickness

Swing Type:	Maximum Dimensions		Panel	Latching:
	Width:	Length:	Туре:	
Single Swing	4'0" (1067 mm)	10'0" (3048 mm)	Flush	2 Point
Double Egress	8'0" (2438 mm)	10'0" (3048 mm)	Flush	(Concealed or Surface Mounted) 4 Point
Double Igloce			1 Idolf	(Concealed or Surface Mounted)



VANCOUVER, BC: LOS ANGELES, CA: TULSA, OK: TORONTO, ON WEBSITE: 877.461.8378 ph. | 604.527.8368 fx. 909.483.0250 ph. | 909.483.0336 fx. 918.437.8333 ph. | 918.437.8487 fx. 905.605.5444 WWW.OALORG

Temperature rise

- @30 min = 250°F MAX where light do not exceed 100 in²
- @60 min = 450°F MAX where light do not exceed 100 in²

Limitations: (Review Machining Report for further detail)

- Cylindrical Latches (Listed and Labelled)
- Mortise Lockset (Listed and Labelled)
- Fire Exit Devices
 - Surface mounted vertical rod, RIM and concealed vertical rod exit devices
- Surface Mounted and concealed door closer (Listed and Labelled)
- Mortise manual or automatic flush bolts
- Light Kit (Listed and Labelled)
 - Listed Steel Lite Kit max. 1080 sq. in. (max. dimension of 36")
 - BASF Proprietary steel channel light kit max. 600 sq. in.
- Electric Raceway (Can only be installed in the Mid Rail, never through the door core)
- Surface Mounted and concealed door bottom (Listed and Labelled)
 - Max mortise 1-3/4" deep by 1" wide by full width of the door

Notes:

Refer to QAI evaluation report F426-1 and the applicable test reports for test assembly configurations used for fire endurance testing.

Refer to the <u>QAI FD002</u> - Fire Door Guidelines for general guidelines of <u>fire door assemblies</u>

Final acceptance of the product in the intended application is to be determined by the authority having jurisdiction (AHJ).

Product is to be installed in accordance with the manufacturer's published installation instructions by qualified installing personnel.

The materials, products or systems listed herein have been qualified to bear the QAI Listing Mark under the conditions stated with each Listing. Only those products bearing the QAI Listing Mark are considered to be listed by QAI. No warranty is expressed or implied, and no guarantee is provided that any jurisdictional authority will accept the Listing found herein. The appropriate authorities should be contacted regarding the acceptability of any given Listing. Visit the QAI Online Listing Directory located at <u>www.qai.org</u> for the most up to date version of this Listing and to validate that this QAI Listing is active. Questions regarding this listing may be directed to <u>info@qai.org</u>. Please include the listing number in the request.
