

VANCOUVER, BC: LOS ANGELES, CA: WASHINGTON, DC: TULSA, OK: TORONTO, ON SEATTLE, WA WEBSITE: 877.461.8378 ph. | 604.527.8368 fx. 909.483.0250 ph. | 909.483.0336 fx. 540.636.9445 ph. | 540.636.9414 fx. 918.437.8333 ph. | 918.437.8487 fx. 416.550.9280 425.512.8419 WWW.QALORG

## FIRE DOORS LISTING PROGRAM

Customer: Doorland 2000 Inc. Class: Fire Doors Location: Woodbridge, ON Website: www.doorlandgroup.com

Listing No. F447-1 Project No. F447-1 Edition 1

Effective Date: October 27, 2017 Last Revised Date: October 27, 2017

> Standards: CAN/ULC-S104 UL 10(b) UL 10(c) NFPA 252

Standard Method for Fire Tests of Door Assemblies. Fire Tests of Door Assemblies. Fire Tests of Door Assemblies. Standard Methods of Fire Tests of Door Assemblies.

- Product: 45 min Rated 'Category A' and 'Category B' Positive Pressure Fire Doors
- Labels: See <u>FD001 Fire Door Labeling requirements</u>

## Models: 45-MINUTE MINERAL CORE FLUSH ACOUSTICAL CORE DOORS:

## Minimum 1-3/4" Thickness

Cin	Swing Type:	Maximum Dimensions		Panel	l staking.
Swin		Width:	Length:	Туре:	Latching:
Single	e Swing	3'0" (914 mm)	7'0" (2134 mm)	Flush	Single Point (Mortised or Cylindrical)



.

VANCOUVER, BC: LOS ANGELES, CA: WASHINGTON, DC: TULSA, OK: TORONTO, ON SEATTLE, WA WEBSITE: 877.461.8378 ph. | 604.527.8368 fx. 909.483.0250 ph. | 909.483.0336 fx. 540.636.9445 ph. | 540.636.9414 fx. 918.437.8333 ph. | 918.437.8487 fx. 416.550.9280 425.512.8419 WWW.OALORG

## Limitations: (Review Machining Report for further detail)

- Cylindrical Latches (Listed and labeled)
- Mortise Lockset (Listed and labeled)
- Fire Exit Devices (Listed and labeled)
  - Surface mounted vertical rod and RIM exit devices.
  - Surface mounted door closer (Listed and labeled)
- Light Kit (Listed and labeled)
  - Listed Steel Lite Kit max. 100 sq. in. listed glazing (max dimension of 33").
- Viewers (Listed and labeled)
- Surface Mounted and mortised automatic door bottom (Listed and labeled)
- Protection Plates
  - Brass, bronze, steel, or aluminum may be installed on one or both sides of the door at a maximum size of 16" high x width of door.
- Notes: Refer to QAI evaluation report F447-1 and the applicable test reports for test assembly configurations used for fire endurance testing.

Refer to the <u>QAI FD002</u> - Fire Door Guidelines for general guidelines of fire door <u>assemblies</u>

Final acceptance of the product in the intended application is to be determined by the authority having jurisdiction (AHJ).

Product is to be installed in accordance with the manufacturer's published installation instructions by qualified installing personnel.

The materials, products or systems listed herein have been qualified to bear the QAI Listing Mark under the conditions stated with each Listing. Only those products bearing the QAI Listing Mark are considered to be listed by QAI. No warrantee is expressed or implied, and no guarantee is provided that any jurisdictional authority will accept the Listing found herein. The appropriate authorities should be contacted regarding the acceptability of any given Listing. Visit the QAI Online Listing Directory located at <u>www.qai.org</u> for the most up to date version of this Listing and to validate that this QAI Listing is active. Questions regarding this listing may be directed to <u>info@qai.org</u>. Please include the listing number in the request.

\*\*\*