

FIRE DOORS LISTING PROGRAM

Customer: Doortech Manufacturing and Distribution Ltd.
 Class: Fire Doors and Fire Door Frames
 Location: Winnipeg, Manitoba
 Website: www.doortechltd.ca

Listing No. F450

Effective Date: January 19, 2018
 Last Revised: February 16, 2018

| | |
|-------------------------|--|
| Standards: CAN/ULC-S104 | <i>Standard Method for Fire Tests of Door Assemblies.</i> |
| UL 10(b) | <i>Fire Tests of Doors Assemblies.</i> |
| UL 10(c) | <i>Fire Tests of Doors Assemblies.</i> |
| NFPA 252 | <i>Standard Methods of Fire Tests of Door Assemblies.</i> |
| NFPA 257 | <i>Standard on Fire Test for Window and Glass Block Assemblies</i> |
| UL 9 | <i>Standard for Fire Tests of Window Assemblies</i> |

Label: See [FD001 - Fire Door Labeling requirements](#)

Models / Ratings: **Fire Doors:**

| <u>Manufacturing/Machining Specifications:</u> | <u>Listing No.:</u> | <u>Criteria:</u> |
|---|----------------------------|-------------------------|
| 20 minute Fire Rated Door | F450-1-20 | CPL |
| 90 minute Fire Rated Door | F450-1-90 | CPL |

Fire Door Frames:

| <u>Manufacturing/Machining Specifications:</u> | <u>Listing No.:</u> | <u>Criteria:</u> |
|--|----------------------------|-------------------------|
| 45 minute Fire Rated Transom Sidelight and Window Frames | F450-2-45 | CPL |
| 45 minute Fire Rated Pressed Steel Frame with Transom and Panels | F450-2-45 | CPL |
| 60 minute Fire Rated Pressed Steel Frame with Transom and Panels | F450-2-60 | CPL |
| 90 minute Fire Rated Pressed Steel Frame with Transom and Panels | F450-2-90 | CPL |
| 180 minute Fire Rated Hollow Metal Door Frame | F450-2-90 | CPL |
| 180 minute Fire Rated Hollow Metal Door Frame | F450-2-180 | CPL |



LABORATORIES

CERTIFICATION TESTING INSPECTION

VANCOUVER, BC: 877.461.8378 ph. | 604.527.8368 fx.
LOS ANGELES, CA: 909.483.0250 ph. | 909.483.0336 fx.
WASHINGTON, DC: 540.636.9445 ph. | 540.636.9414 fx.
TULSA, OK: 918.437.8333 ph. | 918.437.8487 fx.
TORONTO, ON: 416.550.9280
SEATTLE, WA: 425.512.8419
WEBSITE: WWW.QAI.ORG

The materials, products or systems listed herein have been qualified to bear the QAI Listing Mark under the conditions stated with each Listing. Only those products bearing the QAI Listing Mark are considered to be listed by QAI. No warrantee is expressed or implied, and no guarantee is provided that any jurisdictional authority will accept the Listing found herein. The appropriate authorities should be contacted regarding the acceptability of any given Listing. Visit the QAI Online Listing Directory located at www.qai.org for the most up to date version of this Listing and to validate that this QAI Listing is active. Questions regarding this listing may be directed to info@qai.org. Please include the listing number in the request.
