VANCOUVER, BC: LOS ANGELES, CA: WASHINGTON, DC: TULSA, OK: TORONTO, ON WEBSITE: 877.461.8378 ph. | 604.527.8368 fx. 909.483.0250 ph. | 909.483.0336 fx. 540.636.9445 ph. | 540.636.9414 fx. 918.437.8333 ph. | 918.437.8487 fx. 416.550.9280

N 416.550.9280 E: WWW.QAI.ORG

FIRE DOORS LISTING PROGRAM

Customer: Doortech Mfg and Distribution Ltd.

Class: Fire Doors

Location: Winnipeg, Manitoba Website: www.doortechltd.ca

Listing No. F450-1

Project No. F450-1 Edition 2

Effective Date: January 19, 2018 Last Revised Date: February 16, 2018

Standards: CAN/ULC-S104 Standard Method for Fire Tests of Door Assemblies

UL 10(b) Fire Tests of Doors Assemblies.
UL 10(c) Fire Tests of Doors Assemblies.

NFPA 252 Standard Methods of Fire Tests of Door Assemblies.

Product: 90 min Rated 'Category B' Fire Doors, Neutral and Positive Pressure

Labels: See FD001 - Fire Door Labeling requirements

Models: 90-MINUTE HOLLOW METAL FIRE DOORS:

1-3/4" to 2" Thickness

Swing Type:	Maximum Dimensions		Panel	Latablass
	Width:	Length:	Type:	Latching
Single Swing	5'0" (1524 mm)	12'0" (3658 mm)	Flush	Single Point (Mortised or Cylindrical)
Pairs	10'0" (3048 mm)	12'0" (3658 mm)	Flush	3 or 4 Point (Active: Mortised or Cylindrical) (Inactive: Mortised (Manual) and Surface Mounted Flushbolts)

Temperature Rise

@30 min = 450°F MAX where lites do not exceed 100 in²



VANCOUVER, BC: LOS ANGELES, CA: WASHINGTON, DC: TULSA, OK: TORONTO, ON WEBSITE: 877.461.8378 ph. | 604.527.8368 fx. 909.483.0250 ph. | 909.483.0336 fx. 540.636.9445 ph. | 540.636.9414 fx. 918.437.8333 ph. | 918.437.8487 fx. 416.550.9280 WWW.QAI.ORG

Limitations: (Review Machining Report for further detail)

- Cylindrical Latches (Listed and Labeled)
- Deadbolts (Listed and Labeled)
- Surface Mounted Door Closer (Listed and Labeled)
- Surface Mounted Door Bottom (Listed and Labeled)
- Surface Mounted Flushbolts (Listed and Labeled)
- Fire Exit Devices
 - Surface mounted vertical rod
- Light Kit (Listed and Labeled)
 - o Listed Steel Lite Kit max. 100 sq. in. (max. dimension of 33")

Notes: Refer to QAI evaluation report F450-1 and the applicable test reports for test assembly configurations used for fire endurance testing.

Refer to the QAI FD002 - Fire Door Guidelines for general guidelines of fire door assemblies

Final acceptance of the product in the intended application is to be determined by the authority having jurisdiction (AHJ).

Product is to be installed in accordance with the manufacturer's published installation instructions by qualified installing personnel.

The materials, products or systems listed herein have been qualified to bear the QAI Listing Mark under the conditions stated with each Listing. Only those products bearing the QAI Listing Mark are considered to be listed by QAI. No warrantee is expressed or implied, and no guarantee is provided that any jurisdictional authority will accept the Listing found herein. The appropriate authorities should be contacted regarding the acceptability of any given Listing. Visit the QAI Online Listing Directory located at www.qai.org for the most up to date version of this Listing and to validate that this QAI Listing is active. Questions regarding this listing may be directed to info@qai.org. Please include the listing number in the request.
