

VANCOUVER, BC: LOS ANGELES, CA: WASHINGTON, DC: TULSA, OK: TORONTO, ON WEBSITE: 877.461.8378 ph. | 604.527.8368 fx. 909.483.0250 ph. | 909.483.0336 fx. 540.636.9445 ph. | 540.636.9414 fx. 918.437.8333 ph. | 918.437.8487 fx. 416.550.9280 WWW.QALORG

FIRE DOOR FRAME LISTING PROGRAM

Customer: Grandoor Frames LLC Class: Fire Resistant Door Frames Location: San Antonio, Texas Website: www.grandoors.com

Listing No. F444-2 Project No. F444-2 Edition 1

Effective Date: September 19, 2018 Last Revised Date: September 19, 2018

Standards:UL 10BFire Tests of Door AssembliesUL 10CPositive Pressure Fire Tests of Door AssembliesNFPA 252Standard Methods of Fire Tests of Door AssembliesCAN/ULC S104Standard Method for Fire Tests of Door Assemblies

- Product: 45 minute Positive and Neutral Pressure Rated Category "C" Fire Door Frames with Hose Stream.
- Markings: See FD001 Fire Door Labeling requirements

Models: 45 MINUTE FIRE DOOR FRAMES:

MgO Board Core:

Swing Type	Maximum Dimensions	
	Width	Height
Single Swing	4'0" (1219 mm)	9'0" (2743 mm)
Pairs	Not Permitted	
Double Egress	Not Permitted	

LIMITATIONS:

Minimum Frame Leg Width:4-1/2"Maximum Frame Leg Width:Equivalent to wall thicknessMinimum Frame Leg Thickness:3/4"

Minimum Rabbet for Door:	1-3/4"
Minimum Stop Height:	5/8"
Minimum Stop Width:	5/8"

Installation:

Follow NFPA 80 Installation guidelines and details outlined in QAI Machining Specifications Report.



VANCOUVER, BC: 877.461.8378 ph. | 604.527.8368 fx. LOS ANGELES, CA: 909.483.0250 ph. | 909.483.0336 fx. WASHINGTON, DC: 540.636.9445 ph. | 540.636.9414 fx. TULSA, OK: 918.437.8333 ph. | 918.437.8487 fx. TORONTO, ON 416.550.9280 WEBSITE: WWW.QAL.ORG

- Notes: Refer to QAI evaluation report F444-2 and the applicable test reports for test assembly configurations used for fire endurance testing.
 - Refer to the <u>QAI FD002</u> Fire Door Guidelines for general guidelines of fire door <u>assemblies</u>
 - Final acceptance of the product in the intended application is to be determined by the authority having jurisdiction (AHJ).
 - Product is to be installed in accordance with the manufacturer's published installation instructions by qualified installing personnel.

The materials, products or systems listed herein have been qualified to bear the QAI Listing Mark under the conditions stated with each Listing. Only those products bearing the QAI Listing Mark are considered to be listed by QAI. No warrantee is expressed or implied, and no guarantee is provided that any jurisdictional authority will accept the Listing found herein. The appropriate authorities should be contacted regarding the acceptability of any given Listing. Visit the QAI Online Listing Directory located at <u>www.qai.org</u> for the most up to date version of this Listing and to validate that this QAI Listing is active. Questions regarding this listing may be directed to <u>info@qai.org</u>. Please include the listing number in the request.
