

FIRE DOOR LISTING PROGRAM

Customer: Windsor Building Supplies Ltd.
 Class: Fire rated Doors
 Locations: Langley, BC (Head Office)
 Chilliwack, BC
 Duncan, BC
 Parksville, BC
 Website: www.windsorplywood.com

Listing No. F455-1-20-5
 Project No. F455-1 Edition 1

Effective Date: April 1, 2019
 Last Revised Date: April 1, 2019

Standards:	UL 10B	<i>Fire Tests of Door Assemblies</i>
	UL 10C	<i>Positive Pressure Fire Tests of Door Assemblies</i>
	NFPA 252	<i>Standard Methods of Fire Tests of Door Assemblies</i>
	CAN/ULC S104	<i>Standard Method for Fire Tests of Door Assemblies</i>

Product: 20 Minute Positive Pressure rated Category “B” Fire Doors with Hose Stream
 “Lynden 20 Min L20 MDF-R Fire Door”

Markings: See [FD001 - Fire Door Labeling requirements](#)

Models: **20 MINUTE WOOD CORE FIRE DOORS CATEGORY B:**

Minimum 1-3/4” Thickness

Swing Type:	Maximum Dimensions		Panel Type:	Latching:
	Width:	Height:		
Single Swing	3'0" (914 mm)	7'0" (2134 mm)	Flush	Single Point (Mortised or Cylindrical) (Concealed or Surface Mounted Fire Exit Devices)
Pairs	NOT PERMITTED			
Double Egress	NOT PERMITTED			

The above Category B Fire Doors are required to be installed with Category G gasket when used in Positive Pressure applications. Category G gasket is to be approved and listed for use with wood door types.

Additions / Limitations:
(Review Machining Specifications Report for details)

Latch Sets (Listed and labeled for rated opening and wood door type)

- Cylindrical Latches.
- Mortised Latches.

Deadbolts (Listed and labeled for rated opening and wood door type)

- Cylindrical Deadbolts.
- Interconnected Deadbolts.
- Minimum 5" between hardware cutouts.

Hinges (Listed and labeled for rated opening and wood door type)

- Hinges as per NFPA 80.
- Continuous hinges.

Fire Exit Devices (Listed and labeled for rated opening and wood door type)

- Mortise type, Rim type or Surface Mounted Fire Exit Devices.
- Concealed Vertical Rods not permitted.

Door Closers (Listed and labeled for rated opening and wood door type)

- Surface Mounted only.

Surface Mounted Protection Plates

- Steel, brass, bronze, aluminum, listed polycarbonate or listed laminate maximum 16" high.

Louvers

- Not permitted.

Metal Edges

- Surface Mounted only.

Viewers (Listed and labeled for rated opening and wood door type)

- Maximum size of 1" diameter, minimum 5" between viewers.

Glass Lites (Listed and labeled for rated opening and wood door type)

- Glazing material shall be listed and labeled for rated opening, lite kit and wood door type.
- Glazing installed in accordance with NFPA 80, and the listed lite kit frame installation instructions.
- Minimum 5" between lite and edge of door or any other cutout.
- Maximum Area: 1296 sq. in.
- Maximum Width: 24"
- Maximum Height: 54"

Door Bottoms Seals (Listed and labeled for rated opening and wood door type)

- Surface mounted and mortised automatic door bottom units.
- Firestop bottom rail required for mortised automatic door bottoms.

Electric Raceway

- Not Permitted.

Electric Strikes, Magnetic Switches and Electrical Power Transfers (EPT)

- Not Permitted.

Moldings / Plant-Ons

- Wood - Douglas Fir or denser species.
- Not to exceed 20% of area of door.

Notes: *Refer to QAI evaluation reports F455-1 and the applicable test reports for test assembly configurations used for fire endurance testing.*

Refer to the [QAI FD002 - Fire Door Guidelines for general guidelines of fire door assemblies](#)

Final acceptance of the product in the intended application is to be determined by the authority having jurisdiction (AHJ).

Product is to be installed in accordance with the manufacturer's published installation instructions by qualified installing personnel.

Note: The materials, products or systems listed herein have been qualified to bear the QAI Listing Mark under the conditions stated with each Listing. Only those products bearing the QAI Listing Mark are considered to be listed by QAI. No warrantee is expressed or implied, and no guarantee is provided that any jurisdictional authority will accept the Listing found herein. The appropriate authorities should be contacted regarding the acceptability of any given Listing. Visit the QAI Online Listing Directory located at www.qai.org for the most up to date version of this Listing and to validate that this QAI Listing is active. Questions regarding this listing may be directed to info@qai.org. Please include the listing number in the request.
