

ELECTRICAL LISTING PROGRAM

Customer: Technostrobe Inc.
 Class: LED Luminaires
 Location: Coteau-du-Lac, QC , Canada
 Listing No. E11084
 Report No. E11084-1901
 Project No. E11084-1901
 Effective Date: December 20, 2019
 Last Revised N/A
 Date:
 Expires: N/A

Standards: CSA C22.2 No. 250.0 Luminaires
 UL 1598 Luminaires

Product: LED Luminaires
 Wet Locations Use, Permanently Connected.

Markings: Products are marked in a permanent manner where it is readily visible after installation with the following:

- a) Manufacturer's name or trademark
- b) Model designation
- c) Month and year of manufacture
- d) Product ratings: voltage, frequency, watts
- e) QAI file Number: E11084
- f) The wording "Conforms to CSA C22.2 No. 250.0 and UL 1598"
- g) Warning markings as required by the standards in English and French



h) QAI Logo

Models /
Ratings:

Model	Descriptions	V	Phase	Hz	W	Location
LED-B-HYBRID-G5	Medium intensity LED based beacon system	120Vac, 240Vac	1 ph	60	130(260Wmax) Marker Load 300Wmax	Wet Location
LED-RED-STD-G3	Low intensity LED based beacon system	120Vac, 240Vac	1 ph	60	30(60Max)	Wet Location
LED-RED-STD-G3-SEC	Low intensity LED based beacon system	120Vac, 240Vac	1 ph	60	30(60Max)	Wet Location

The materials, products or systems listed herein have been qualified to bear the QAI Listing Mark under the conditions stated with each Listing. Only those products bearing the QAI Listing Mark are considered to be listed by QAI. No warrantee is expressed or implied, and no guarantee is provided that any jurisdictional authority will accept the Listing found herein. The appropriate authorities should be contacted regarding the acceptability of any given Listing. Visit the QAI Online Listing Directory located at www.qai.org for the most up to date version of this Listing and to validate that this QAI Listing is active. Questions



LABORATORIES

CERTIFICATION TESTING INSPECTION

VANCOUVER, BC: 877.461.8378 ph. | 604.527.8368 fx.
LOS ANGELES, CA: 909.483.0250 ph. | 909.483.0336 fx.
WASHINGTON, DC: 540.636.9445 ph. | 540.636.9414 fx.
TULSA, OK: 918.437.8333 ph. | 918.437.8487 fx.
TORONTO, ON: 416.550.9280
SEATTLE, WA: 425.512.8419
WEBSITE: WWW.QAI.ORG

regarding this listing may be directed to info@qai.org. Please include the listing number in the request.
